## Retail Food Inspection Report

Floyd County Health Department Telephone (812) 948-4726

Establishment Name BAPTIST HEALTH FLOYD FOOD AND NUTRITIONAL							Telephone Number 812-948-4815	Date of Inspection	ID#	
Address 1850 STATE ST, NEW ALBANY IN 47150						Ow	<sup>n</sup> 812-944-7701	11/02/2023		
Owner BAPTIST HEALTH FLOYD							Purpose X Routine	Follow Up	Released 11/02/2023	
Owner's Address 1850 STATE ST NEW ALBANY, IN 47150							Follow-up Complaint			
Person in Charge RACHEL SULLIVAN							Pre-Operational			
Responsible Person's Email							Temporary HACCP	Menu Type 1 2 3 4 _ <u>X</u> 5		
Certified Food Handler SAMANTHA DECARLO							Other (list)			
				AND NARRATIVE COLUMN NS ARE DENOTED IN THE		ND IN THE N	ARRAIVE COLUMN MARKED AS "R"			
Section #	C	NC	R	Narrative		To Be Corrected				
218 334 431	Х	X		Observed a closed valve added to the bleeder valve line at the chemical dispenser faucet in utility closet. The valve was closed and faucets were left on. This can cause the AVB valve to be stuck in the open position. The extra valve on bleeder valve should be removed. A hose may be added to prevent splashing. Water should run out when the water faucet is turned on and be diverted to chemical dispenser when button is pushed on dispenser.				today ne n	s reused	
				-			e cleaned frequently.  at prep and vegetable prep	sinks. Locate airgap c	or	
Summary of Vi	olations	(	C _	NC	2 R 0			3		
Received by (name and title printed):  RACHEL SULLIVAN							Inspected by (name and title printed): Thomas Snider CFS			
Received by (signature):							Inspected by (signature):			
cc:					cc:		<del>-</del>	ce:		