

# Retail Food Inspection Report

Floyd County Health Department  
Telephone (812) 948-4726


<b>Establishment Name</b> SAV-A-STEP FOOD MART NO. 54 (GRANTLINE RD)		<b>Telephone Number</b> Est 812/949-1790 Own 812-945-3096 X229		<b>Date of Inspection</b> 03/01/2023		<b>ID#</b>	
<b>Address</b> 4016 GRANT LINE ROAD, NEW ALBANY IN 47150		<b>Purpose</b> <input checked="" type="checkbox"/> Routine <input type="checkbox"/> Follow-up <input type="checkbox"/> Complaint <input type="checkbox"/> Pre-Operational <input type="checkbox"/> Temporary <input type="checkbox"/> HACCP <input type="checkbox"/> Other (list)		<b>Follow Up</b>		<b>Released</b> 03/11/2023	
<b>Owner</b> SAV-A-STEP FOOD MARTS, INC				<b>Menu Type</b> 1 __ 2 __ 3 <u>X</u> 4 __ 5 __			
<b>Owner's Address</b> 610 PROVIDENCE WAY CLARKSVILLE, IN 47129-							
<b>Person in Charge</b> MIKE NEIL							
<b>Responsible Person's Email</b> FOODSERVICE@SAVASTEP.COM							
<b>Certified Food Handler</b> JAMES NEILL							

CRITICAL ITEMS ARE IDENTIFIED IN THE CHECKLIST AND NARRATIVE COLUMNS MARKED "C"  
VIOLATION(S) REPEATED FROM PREVIOUS INSPECTIONS ARE DENOTED IN THE "SUMMARY OF VIOLATIONS" AND IN THE NARRATIVE COLUMN MARKED AS "R"

Section #	C	NC	R	Narrative	To Be Corrected
295		X	X	Observed the blade of the can opener and the floor under the milk/tea shelf in the walk-in in need of cleaning.	Today
310		X		Observed a buildup of dust on the exhaust vents in the restrooms.	5 days
342		X		Observed no hot water in the both restrooms.	10 days
392		X	X	Observed the dumpster lid left open.	Corrected
413		X		Observed a vertical door gap on all of the entry doors.	2 weeks
431		X		Observed a buildup of dust on the ceiling above the pizza oven.	1 week

INAPPROPRIATE BACKFLOW PREVENTION WAS OBSERVED BETWEEN THE CHEMICAL UNITS AND THE MOP SINK. A CONTINUOUS PRESSURE VALVE OR A PRESSURE BLEED VALVE IS REQUIRED FOR THESE CONNECTIONS TO PREVENT BACKFLOW CONTAMINATION. ATTACHED ARE TWO DOCUMENTS SHOWING THE APPROPRIATE DEVICES. CHEMICAL DISPENSERS AND Y-VALVE INSTALLATIONS PAGE 2 AND ASSE 1055 CHEMICAL DISPENSERS PAGE 5. FCHD IS NOT WRITING THIS AS A VIOLATION AT THIS TIME HOWEVER IF THE ISSUE IS NOT RESOLVED IN A TIMELY MANNER A VIOLATION WILL BE WRITTEN ON THE NEXT INSPECTION.

<b>Summary of Violations</b>	C <u>0</u>	NC <u>6</u>	R <u>2</u>	<b>6</b>
------------------------------	------------	-------------	------------	----------

Received by (name and title printed):		Inspected by (name and title printed): Anthony Lieber ASST. ENVIRONMENTAL SUPERVISOR	
Received by (signature):		Inspected by (signature): 	
cc:	cc:	cc:	