Retail Food Inspection Report

Floyd County Health Department Telephone (812) 948-4726

Establishment Name							Telephone Number	Date of	ID#	
FIVE GUYS #384						Est 812-944-9958		Inspection	ID#	
Address 2221 STATE ST #A, NEW ALBANY IN 47150						Own	(812) 378-7150	07/18/2024		
Owner						Purpose		Follow Up	Released	
GEORGE & STELLA ESTEP							X Routine	08/08/2024	07/18/2024	
Owner's Address 3685 N NATIONAL RD COLUMBUS, IN 47201-							——Follow-up Complaint			
Person in Charge MAKAYLA MCKANNAN							Pre-Operational			
Responsible Person's Email							Temporary	Menu Type		
FG384@ESTEP-CO.COM						1	HACCP	$1 - 2 - 3 \times 10^{-3}$	4 _ 5 _	
Certified Food Handler ELESHA BOONE							Other (list)			
CRITICAL ITEMS ARE IDENTIFIED IN THE CHECKLIST AND NARRATIVE COLUMNS MARKED "C" VIOLATION(S) REPEATED FROM PREVIOUS INSPECTIONS ARE DENOTED IN THE "SUMMARY OF VIOLATIONS" AND IN THE NARRAIVE COLUMN MARKED AS "R"										
Section #	C	NC	R	Narrative		To Be Corrected				
324										
392		Χ		compartment. Correction: Repair plumbing. Observed dumpster lid left open. Corrected. Corrected						
322	22 X Observed elevated lines and valve					strean			3 weeks	
			vacuum breaker on the mop sink faucet. Correction: FCHD recommends installing a bleeder valve to the faucet or connecting the dispenser to an independent water line or to a hand pump. The hoses may be disconnected between uses in the meantime.							
393	X X Observed a dumpster without a drain plug. Correction: Dumpsters widrains should have a drain plug in place.							n 2 weeks		
Summary of Vi	iolations	•	C _	1 NC	<u>3</u> R <u>2</u>			4		
Received by (name and title printed):							Inspected by (name and title printed): Carrie Fischer EHS			
Received by (signature):							Inspected by (signature):			
cc:					cc:			cc:		