

Retail Food Inspection Report

Floyd County Health Department
Telephone (812) 948-4726

Establishment Name MCDONALD'S RESTAURANT #7438 (GEORGETOWN)	Telephone Number Est 812-923-2814 Own (614) 682-1524	Date of Inspection 07/09/2024	ID#
Address 1051 LUTHER ROAD, GEORGETOWN IN 47122			
Owner MCDONALD'S RESTAURANTS OF INDIANA INC.	Purpose <input type="checkbox"/> Routine <input checked="checked" type="checkbox"/> Follow-up <input type="checkbox"/> Complaint <input type="checkbox"/> Pre-Operational <input type="checkbox"/> Temporary <input type="checkbox"/> HACCP <input type="checkbox"/> Other (list)	Follow Up 07/24/2024	Released 07/09/2024
Owner's Address PO BOX 183090 COLUMBUS, OH 43218	Menu Type 1 ___ 2 ___ 3 <u>X</u> 4 ___ 5 ___		
Person in Charge JACKIE ROWLEY			
Responsible Person's Email IND.12895@US.STORES.MCD.COM			
Certified Food Handler KATIE LEIDOLF			

CRITICAL ITEMS ARE IDENTIFIED IN THE CHECKLIST AND NARRATIVE COLUMNS MARKED "C"
VIOLATION(S) REPEATED FROM PREVIOUS INSPECTIONS ARE DENOTED IN THE "SUMMARY OF VIOLATIONS" AND IN THE NARRATIVE COLUMN MARKED AS "R"

Section #	C	NC	R	Narrative	To Be Corrected
322	X		X	Observed the mop sink faucet had a y-valve with a line to a chemical dispenser and was left on down stream of an atmospheric vacuum breaker. The atmospheric breaker on the faucet is not designed to be under constant pressure. FCHD recommends installing a bleeder valve to the faucet or connecting the dispenser to an independent water line or a hand pump. The hoses may be disconnected between uses in the meantime.	2 weeks

Summary of Violations	C <u>1</u>	NC <u>0</u>	R <u>1</u>		1
------------------------------	------------	-------------	------------	--	----------

Received by (name and title printed):	Inspected by (name and title printed): Carrie Fischer EHS	
Received by (signature):	Inspected by (signature): 	
cc:	cc:	cc: