Floyd County Health Department Telephone (812) 948-4726

Establishment Name Telephone Number ID# Date of THE ELDERBERRY CO. Inspection Est 309-830-4685 Address 06/07/2024 Own 800-825-0445 302 PEARL STREET STE. B, NEW ALBANY IN 47150 Owner Follow Up Released Purpose X Routine 06/07/2024 JENNY WATSON **Owner's Address** Follow-up 302 PEARL STREET STE B SELLERSBURG, IN 47172 Complaint Person in Charge **Pre-Operational** KAM WESTPHAL Temporary Menu Type **Responsible Person's Email** HACCP 1 <u>X</u> 2 <u>3</u> 4 <u>5</u> ACCOUNTING@THEELDERBERRYCO.COM **Certified Food Handler** Other (list) CRITICAL ITEMS ARE IDENTIFIED IN THE CHECKLIST AND NARRATIVE COLUMNS MARKED "C" VIOLATION(S) REPEATED FROM PREVIOUS INSPECTIONS ARE DENOTED IN THE "SUMMARY OF VIOLATIONS" AND IN THE NARRAIVE COLUMN MARKED AS "R" Section # С NC **R** Narrative **To Be Corrected** 441 Х Observed the mop sink faucet had a y-valve with a line to a chemical 2 weeks dispenser. The atmospheric breaker on the faucet is not designed to be under constant pressure. FCHD recommends installing a bleeder valve to the faucet or connecting the dispenser to an independent water line or to a hand pump. The hoses may be disconnected between uses in the meantime. 1 **Summary of Violations** C 1 NC 0 R 0 Received by (name and title printed): Inspected by (name and title printed): JENNY WATSON Carrie Fischer EHS Received by (signature): Inspected by (signature): Covolga Sizetre cc: cc: cc: