Retail Food Inspection Report

Floyd County Health Department
Telephone (812) 948-4726

Establishment Name	Telephone Number	Date of Inspection	ID#
GREEN VALLEY ELEMENTARY	Est 812-542-6110	03/06/2024	
Address 2230 GREEN VALLEY RD, NEW ALBANY IN 47150	Own 812-542-4703		

Owner	Purpose	Follow Up	Released
NAFCS FOOD & NUTRITION SERVICES	X Routine		03/06/2024
Owner's Address 2801 GRANTLINE RD NEW ALBANY, IN 47150-	___ Follow-up		
Person in Charge ROLANDA COLLINS	___ Complaint		
Responsible Person's Email RCOLLINS@NAFCS.ORG	___ Pre-Operational		
Certified Food Handler ROLANDA COLLINS	___ Temporary	**Menu Type**	
	___ HACCP	1 __ 2 __ 3 __ 4 X 5 __	
	___ Other (list)		

CRITICAL ITEMS ARE IDENTIFIED IN THE CHECKLIST AND NARRATIVE COLUMNS MARKED "C"
VIOLATION(S) REPEATED FROM PREVIOUS INSPECTIONS ARE DENOTED IN THE "SUMMARY OF VIOLATIONS" AND IN THE NARRAIVE COLUMN MARKED AS "R"

Section #	C	NC	R	Narrative	To Be Corrected
322	X		X	Observed a y-valve and elevated lines downstream from an atmospheric vacuum breaker (AVB) on the mop sink. The AVB is not designed to operate under constant pressure.	10 DAYS
218		X		Observed ice buildup in the walk-in cooler	2 WEEKS

Summary of Violations C 1 NC 1 R 1 2

Received by (name and title printed):	Inspected by (name and title printed):
ROLANDA COLLINS	John Klem EHS
Received by (signature):	Inspected by (signature): John Klem

cc:	cc:	cc: