

◆ ◆ ◆ **REQUIRED INSPECTIONS** ◆ ◆ ◆

**Electrical Service and Upgrades**

1. PERMANENT ELECTRICAL SERVICE INSPECTION: Prior to Electric Company Hook-up. After meter base is installed and wired into main disconnect or breaker panel. Note: Two ground rods required minimum of 6 feet apart unless Ufer rod is utilized. Ground wire must be continuous from both ground rods or Ufer rod to the first disconnect panel. Ground wire from disconnect and/or breaker panel to ground rods or ufer rod MUST NOT BE ROUTED through meter base.

◆ ◆ ◆ **A TWENTY-FOUR (24) HOUR NOTICE IS REQUIRED ON ALL INSPECTIONS.** ◆ ◆ ◆