



APPLICATION FOR VARIANCE

State Form 44400 (R7 / 10-13)
Approved by State Board of Accounts, 2013

INDIANA DEPARTMENT OF HOMELAND SECURITY
CODE SERVICES SECTION
302 West Washington Street, Room W246
Indianapolis, IN 46204-2739
http://www.in.gov/dhs/fire/ip_bs_code_center



INSTRUCTIONS: Please refer to the attached four (4) page instructions.
Attach additional pages as needed to complete this application.

Variance number (Assigned by department)

16-06-07(a)

1. APPLICANT INFORMATION (Person who would be in violation if variance is not granted; usually this is the owner)

Name of applicant	ELIGIENE PEREY & HALENIA MYNATT	Title	OWNERS
Name of organization	N.A.	Telephone number	(317) 446 1257
Address (number and street, city, state, and ZIP code)			
11141 ROCKFELL RD MOORESVILLE IN 46158			

2. PERSON SUBMITTING APPLICATION ON BEHALF OF THE APPLICANT (If not submitted by the applicant)

Name of applicant	STEPHEN C. HOFFMAN	Title	ENGINEER OF RECORD
Name of organization	HOFFMAN ENGINEERS, P.C.	Telephone number	(317) 443-1901 (c)
Address (number and street, city, state, and ZIP code)			
8261 W. BASE LINE RD., PARAGON, IN 46166			

3. DESIGN PROFESSIONAL OF RECORD (If applicable)

Name of design professional	STEPHEN C. HOFFMAN	License number	PE 00016188
Name of organization	HOFFMAN ENGINEERS, P.C.	Telephone number	317-443-1901 (c)
Address (number and street, city, state, and ZIP code)			
8261 W. BASE LINE RD., PARAGON IN 46166			

4. PROJECT IDENTIFICATION

Name of project	WEDDING CHAPEL/WORSHIP HALL	State project number	379256	County	MORGAN
Address of site (number and street, city, state, and ZIP code)					
3663 MILKHOUSE LANE MOORESVILLE IN					
Type of project					
<input type="checkbox"/> New <input type="checkbox"/> Addition <input type="checkbox"/> Alteration <input type="checkbox"/> Change of occupancy <input checked="" type="checkbox"/> Existing					

5. REQUIRED ADDITIONAL INFORMATION

The following required information has been included with this application (check as applicable):

- A check made payable to the Indiana Department of Homeland Security for the appropriate amount. (See instructions)
- One (1) set of plans or drawings and supporting data that describe the area affected by the requested variance and any proposed alternatives. ✓
- Written documentation showing that the local fire official has received a copy of the variance application. **TO FOLLOW**
- Written documentation showing that the local building official has received a copy of the variance application. **TO FOLLOW**

6. VIOLATION INFORMATION

Has the Plan Review Section of the Division of Fire and Building Safety issued a Correction Order?

Yes (If yes, attach a copy of the Correction Order.) No

Has a violation been issued?

Yes (If yes, attach a copy of the Violation and answer the following.) No

Violation issued by:

Local Building Department
 State Fire and Building Code Enforcement Section
 Local Fire Department

7. DESCRIPTION OF REQUESTED VARIANCE

Name of code or standard and edition involved IBC 2014	Specific code section CHAPTER 29 & TABLE 2902.1
Nature of non-compliance (include a description of spaces, equipment, etc. involved as necessary.) NO PERMANENT TOILET FACILITIES	

8. DEMONSTRATION THAT PUBLIC HEALTH, SAFETY, AND WELFARE WILL BE PROTECTED

Select one of the following statements:

Non-compliance with the rule will not be adverse to the public health, safety or welfare; or

Applicant will undertake alternative actions in lieu of compliance with the rule to ensure that granting of the variance will not be adverse to public health, safety, or welfare. Explain why alternative actions would be adequate (be specific).

Facts demonstrating that the above selected statement is true:
PORTABLE TOILETS WILL BE PROVIDED PER SHEET 8 OF 11

9. DEMONSTRATION OF UNDUH HARDSHIP OR HISTORICALLY SIGNIFICANT STRUCTURE

Select at least one of the following statements:

Imposition of the rule would result in an undue hardship (unusual difficulty) because of physical limitations of the construction site or its utility services.

Imposition of the rule would result in an undue hardship (unusual difficulty) because of major operational problems in the use of the building or structure.

Imposition of the rule would result in an undue hardship (unusual difficulty) because of excessive costs of additional or altered construction elements.

Imposition of the rule would prevent the preservation of an architecturally or a historically significant part of the building or structure.

Facts demonstrating that the above selected statement is true:
NO EXISTING SEPTIC &/OR SEWER FACILITIES ON SITE OR CLOSE TO SITE ... RURAL AREA.

10. STATEMENT OF ACCURACY

I hereby certify under penalty of perjury that the information contained in this application is accurate.

Signature of applicant or person submitting application 	Please print name STEPHEN C. HOFFMAN	Date of signature (month, day, year) MAR 6 2016
Signature of design professional or approver 	Please print name STEPHEN C. HOFFMAN	Date of signature (month, day, year) MAR 6 2016

11. STATEMENT OF AWARENESS (If the application is submitted on the applicant's behalf, the applicant must sign the following statement.)

I hereby certify under penalty of perjury that I am aware of this request for variance and that this application is being submitted on my behalf.


Signature of applicant 	Please print name HALIENA MYRDATT	Date of signature (month, day, year) 3/9/16
----------------------------	---	---



APPLICATION FOR VARIANCE

State Form 44400 (R7 / 10-13)
Approved by State Board of Accounts, 2013

INDIANA DEPARTMENT OF HOMELAND SECURITY
CODE SERVICES SECTION
302 West Washington Street, Room W248
Indianapolis, IN 46204-2739
http://www.in.gov/dhs/fire/cp_bs_comm_code/



INSTRUCTIONS: Please refer to the attached four (4) page instructions.
Attach additional pages as needed to complete this application.

Variance number (Assigned by department)
16-06-07 (b)

1. APPLICANT INFORMATION (Person who would be in violation if variance is not granted; usually this is the owner)		
Name of applicant	ELIZABETH PERCY & HELENIA MYNATT	Title OWNERS
Name of organization	N.A.	Telephone number (317) 446 1257
Address (number and street, city, state, and ZIP code) 1141 ROCKFELL RD MOORESVILLE IN 46158		
2. PERSON SUBMITTING APPLICATION ON BEHALF OF THE APPLICANT (if not submitted by the applicant)		
Name of applicant	STEPHEN C. HOFFMAN	Title ENGINEER OF RECORD
Name of organization	HOFFMAN ENGINEERS, P.C.	Telephone number (317) 443-1901 (c)
Address (number and street, city, state, and ZIP code) 9261 W. BASE LINE RD., PARAGON, IN 46166		
3. DESIGN PROFESSIONAL OF RECORD (if applicable)		
Name of design professional	STEPHEN C. HOFFMAN	License number PE 60016188
Name of organization	HOFFMAN ENGINEERS, P.C.	Telephone number 317-443-1901 (c)
Address (number and street, city, state, and ZIP code) 9261 W. BASE LINE RD., PARAGON IN 46166		
4. PROJECT IDENTIFICATION		
Name of project	WOODING CHAPEL/WORSHIP HOUSE	State project number 379256
Address of site (number and street, city, state, and ZIP code)		County MORGAN
3663 MILKHOUSE LANE MOORESVILLE IN		
Type of project <input type="checkbox"/> New <input type="checkbox"/> Addition <input type="checkbox"/> Alteration <input type="checkbox"/> Change of occupancy <input checked="" type="checkbox"/> Existing		
5. REQUIRED ADDITIONAL INFORMATION		
The following required information has been included with this application (check as applicable):		
<input type="checkbox"/> A check made payable to the Indiana Department of Homeland Security for the appropriate amount. (see instructions)		
<input type="checkbox"/> One (1) set of plans or drawings and supporting data that describe the area affected by the requested variance and any proposed alternatives. ✓		
<input type="checkbox"/> Written documentation showing that the local fire official has received a copy of the variance application. TO FOLLOW		
<input type="checkbox"/> Written documentation showing that the local building official has received a copy of the variance application. TO FOLLOW		
6. VIOLATION INFORMATION		
Has the Plan Review Section of the Division of Fire and Building Safety issued a Correction Order?		
<input type="checkbox"/> Yes (if yes, attach a copy of the Correction Order.) <input checked="" type="checkbox"/> No		
Has a violation been issued?		
<input type="checkbox"/> Yes (if yes, attach a copy of the Violation and answer the following.) <input checked="" type="checkbox"/> No		
Violation issued by:		
<input type="checkbox"/> Local Building Department <input type="checkbox"/> State Fire and Building Code Enforcement Section <input type="checkbox"/> Local Fire Department		

7. DESCRIPTION OF REQUESTED VARIANCE

Name of code or standard and edition involved IMC 2012	Specific code section SECTION 309
Nature of non-compliance (Include a description of spaces, equipment, etc. involved as necessary.) HVAC EQUIPMENT NOT <u>PERMANENTLY</u> INSTALLED	

8. DEMONSTRATION THAT PUBLIC HEALTH, SAFETY, AND WELFARE WILL BE PROTECTED

Select one of the following statements:

Non-compliance with the rule will not be adverse to the public health, safety or welfare; or

Applicant will undertake alternative actions in lieu of compliance with the rule to ensure that granting of the variance will not be adverse to public health, safety, or welfare. Explain why alternative actions would be adequate (be specific).

Facts demonstrating that the above selected statement is true:

PORTABLE HEATING & COOLING EQUIPMENT WILL BE USED ON AN "AS NEEDED" BASIS (SIMILAR TO TENT HEATERS & COOLERS FOR EVENT USE)

9. DEMONSTRATION OF UNDUE HARDSHIP OR HISTORICALLY SIGNIFICANT STRUCTURE

Select at least one of the following statements:

Imposition of the rule would result in an undue hardship (unusual difficulty) because of physical limitations of the construction site or its utility services.

Imposition of the rule would result in an undue hardship (unusual difficulty) because of major operational problems in the use of the building or structure.

Imposition of the rule would result in an undue hardship (unusual difficulty) because of excessive costs of additional or altered construction elements.

Imposition of the rule would prevent the preservation of an architecturally or a historically significant part of the building or structure.

Facts demonstrating that the above selected statement is true:

THIS FACILITY IS SIMILAR TO A TENT OR A FAIRGROUNDS BLOG THAT WILL BE USED "AS-IS" OR WITH TEMPERED AIR AS NEEDED...

10. STATEMENT OF ACCURACY

I hereby certify under penalty of perjury that the information contained in this application is accurate.

Signature of applicant or person submitting application 	Please print name STEPHEN C. HOFFMAN	Date of signature (month, day, year) MAR 6 2016
Signature of design professional (if applicable) 	Please print name STEPHEN C. HOFFMAN	Date of signature (month, day, year) MAR 6 2016

11. STATEMENT OF AWARENESS (If the application is submitted on the applicant's behalf, the applicant must sign the following statement.)

I hereby certify under penalty of perjury that I am aware of this request for variance and that this application is being submitted on my behalf.

Signature of applicant Halimera Myndatt	Please print name Halimera Myndatt	Date of signature (month, day, year) 3/9/16
---	--	---



APPLICATION FOR VARIANCE
 State Form 44400 (R7 / 10-13)
 Approved by State Board of Accounts, 2013

INDIANA DEPARTMENT OF HOMELAND SECURITY
 CODE SERVICES SECTION
 302 West Washington Street, Room W248
 Indianapolis, IN 46204-2739
http://www.in.gov/dhs/fire/bs_comm_code/



INSTRUCTIONS: Please refer to the attached four (4) page instructions.
 Attach additional pages as needed to complete this application.

Variance number (Assigned by department)
 16-06-07(c)

1. APPLICANT INFORMATION (Person who would be in violation if variance is not granted; usually this is the owner)		
Name of applicant ELIGIANE PERCY & HELENIA MYNATT	Title OWNERS	
Name of organization N.A.	Telephone number (317) 446 1257	
Address (number and street, city, state, and ZIP code) 11141 RODGER RD MOORESVILLE IN 46158		
2. PERSON SUBMITTING APPLICATION ON BEHALF OF THE APPLICANT (If not submitted by the applicant)		
Name of applicant STEPHEN C. HOFFMAN	Title ENGINEER OF RECORD	
Name of organization HOFFMAN ENGINEERS, P.C.	Telephone number (317) 443-1901 (c)	
Address (number and street, city, state, and ZIP code) 8261 W. BASE LINE RD., PARAGON, IN 46166		
3. DESIGN PROFESSIONAL OF RECORD (If applicable)		
Name of design professional STEPHEN C. HOFFMAN	License number PE 60016188	
Name of organization HOFFMAN ENGINEERS, P.C.	Telephone number 317-443-1901 (c)	
Address (number and street, city, state, and ZIP code) 8261 W. BASE LINE RD., PARAGON IN 46166		
4. PROJECT IDENTIFICATION		
Name of project WOODING CHAPEL WORSHIP HOUSE	State project number 379256	County MORGAN
Address of site (number and street, city, state, and ZIP code) 3063 MILKHOUSE LANE MOORESVILLE IN		
Type of project <input type="checkbox"/> New <input type="checkbox"/> Addition <input type="checkbox"/> Alteration <input type="checkbox"/> Change of occupancy <input checked="" type="checkbox"/> Existing		
5. REQUIRED ADDITIONAL INFORMATION		
The following required information has been included with this application (check as applicable):		
<input type="checkbox"/> A check made payable to the Indiana Department of Homeland Security for the appropriate amount. (see instructions)		
<input type="checkbox"/> One (1) set of plans or drawings and supporting data that describe the area affected by the requested variance and any proposed alternatives. ✓		
<input type="checkbox"/> Written documentation showing that the local fire official has received a copy of the variance application. TO FOLLOW		
<input type="checkbox"/> Written documentation showing that the local building official has received a copy of the variance application. TO FOLLOW		
6. VIOLATION INFORMATION		
Has the Plan Review Section of the Division of Fire and Building Safety issued a Correction Order? <input type="checkbox"/> Yes (If yes, attach a copy of the Correction Order.) <input checked="" type="checkbox"/> No		
Has a violation been issued? <input type="checkbox"/> Yes (If yes, attach a copy of the Violation and answer the following.) <input checked="" type="checkbox"/> No		
Violation issued by: <input type="checkbox"/> Local Building Department <input type="checkbox"/> State Fire and Building Code Enforcement Section <input type="checkbox"/> Local Fire Department		

7. DESCRIPTION OF REQUESTED VARIANCE

Name of code or standard and edition involved 2010 INDIANA ENERGY CODE	Specific code section 675 IAC 19-4 A SHRAE 90.1 4.2
--	---

Nature of non-compliance (include a description of spaces, equipment, etc. involved as necessary.)
**SPACE IS A BARN & IS NOT INSULATED
 HVAC EQUIPMENT IS NOT CERTIFIED AS "ENERGY EFFICIENT"**

8. DEMONSTRATION THAT PUBLIC HEALTH, SAFETY, AND WELFARE WILL BE PROTECTED

Select one of the following statements:
 Non-compliance with the rule will not be adverse to the public health, safety or welfare; or
 Applicant will undertake alternative actions in lieu of compliance with the rule to ensure that granting of the variance will not be adverse to public health, safety, or welfare. Explain why alternative actions would be adequate (be specific).

Facts demonstrating that the above selected statement is true:
**HVAC EQUIPMENT WILL ONLY BE USED DURING THE WINTER
 & WILL BE LIMITED TO ONLY WHEN THE BUILDING
 IS OCCUPIED**

9. DEMONSTRATION OF UNDUE HARDSHIP OR HISTORICALLY SIGNIFICANT STRUCTURE

Select at least one of the following statements:
 Imposition of the rule would result in an undue hardship (unusual difficulty) because of physical limitations of the construction site or its utility services.
 Imposition of the rule would result in an undue hardship (unusual difficulty) because of major operational problems in the use of the building or structure.
 Imposition of the rule would result in an undue hardship (unusual difficulty) because of excessive costs of additional or altered construction elements.
 Imposition of the rule would prevent the preservation of an architecturally or a historically significant part of the building or structure.

Facts demonstrating that the above selected statement is true:
**LIMITED USE OF THE BUILDING WOULD MAKE
 INSULATION & PERMANENT HVAC EQUIPMENT
 WOULD PRECLUDE ANY USE OF THE BUILDING
 EXCEPT IN 60°-75° WEATHER (ASSUMING OTHER
 VARIANCES WERE APPROVED)**

10. STATEMENT OF ACCURACY

I hereby certify under penalty of perjury that the information contained in this application is accurate.

Signature of applicant or person submitting application 	Please print name STEPHEN C. HOFFMAN	Date of signature (month, day, year) MAR 6 2016
Signature of design professional (if applicable) 	Please print name STEPHEN C. HOFFMAN	Date of signature (month, day, year) MAR 6 2016

11. STATEMENT OF AWARENESS (If the application is submitted on the applicant's behalf, the applicant must sign the following statement.)

I hereby certify under penalty of perjury that I am aware of this request for variance and that this application is being submitted on my behalf.

Signature of applicant 	Please print name Haliena Mynatt	Date of signature (month, day, year) 3/9/16
----------------------------	--	---



APPLICATION FOR VARIANCE
 State Form 44400 (R7 / 10-13)
 Approved by State Board of Accounts, 2013

INDIANA DEPARTMENT OF HOMELAND SECURITY
 CODE SERVICES SECTION
 302 West Washington Street, Room W246
 Indianapolis, IN 46204-2739
http://www.in.gov/dhs/fire/in_bs_code/



INSTRUCTIONS: Please refer to the attached four (4) page instructions.
 Attach additional pages as needed to complete this application.

Variance number (Assigned by department)
 16-06-07(d)

1. APPLICANT INFORMATION (Person who would be in violation if variance is not granted, usually this is the owner)

Name of applicant	ELIGIJE PERCY & HELENIA MYNATT	Title	OWNERS
Name of organization	N.A.	Telephone number	(317) 446 1257
Address (number and street, city, state, and ZIP code)			
1141 ROCKFEL RD MOORESVILLE IN 46158			

2. PERSON SUBMITTING APPLICATION ON BEHALF OF THE APPLICANT (If not submitted by the applicant)

Name of applicant	STEPHEN C. HOFFMAN	Title	ENGINEER OF RECORD
Name of organization	HOFFMAN ENGINEERS, P.C.	Telephone number	(317) 443-1901 (c)
Address (number and street, city, state, and ZIP code)			
8261 W. BASE LINE RD., PARAGON, IN 46166			

3. DESIGN PROFESSIONAL OF RECORD (If applicable)

Name of design professional	STEPHEN C. HOFFMAN	License number	PE 60016188
Name of organization	HOFFMAN ENGINEERS, P.C.	Telephone number	317-443-1901 (c)
Address (number and street, city, state, and ZIP code)			
8261 W. BASE LINE RD., PARAGON IN 46166			

4. PROJECT IDENTIFICATION

Name of project	WEDDING CHAPEL / WORSHIP HALL	State project number	379256	County	MORGAN
Address of site (number and street, city, state, and ZIP code)					
3063 MILKHOUSE LANE MOORESVILLE IN					
Type of project					
<input type="checkbox"/> New <input type="checkbox"/> Addition <input type="checkbox"/> Alteration <input type="checkbox"/> Change of occupancy <input checked="" type="checkbox"/> Existing					

5. REQUIRED ADDITIONAL INFORMATION

The following required information has been included with this application (check as applicable):

- A check made payable to the Indiana Department of Homeland Security for the appropriate amount. (see Instructions)
- One (1) set of plans or drawings and supporting data that describe the area affected by the requested variance and any proposed alternatives. ✓
- Written documentation showing that the local fire official has received a copy of the variance application. **TO FOLLOW**
- Written documentation showing that the local building official has received a copy of the variance application. **TO FOLLOW**

6. VIOLATION INFORMATION

Has the Plan Review Section of the Division of Fire and Building Safety Issued a Correction Order?

Yes (If yes, attach a copy of the Correction Order.) No

Has a violation been issued?

Yes (If yes, attach a copy of the Violation and answer the following.) No

Violation issued by:

Local Building Department
 State Fire and Building Code Enforcement Section
 Local Fire Department

7. DESCRIPTION OF REQUESTED VARIANCE

Name of code or standard and edition involved IECC	Specific code section SECTION 5.7.1
Nature of non-compliance (Include a description of spaces, equipment, etc. involved as necessary.) ENERGY COMPLIANCE REPORT SIGNED & SEALED BY THE DESIGN PROF. OF RECORD	

8. DEMONSTRATION THAT PUBLIC HEALTH, SAFETY, AND WELFARE WILL BE PROTECTED

Select one of the following statements:

Non-compliance with the rule will not be adverse to the public health, safety or welfare; or

Applicant will undertake alternative actions in lieu of compliance with the rule to ensure that granting of the variance will not be adverse to public health, safety, or welfare. Explain why alternative actions would be adequate (be specific).

Facts demonstrating that the above selected statement is true:
IF VARIANCE C IS APPROVED THIS BECOMES MEET.

9. DEMONSTRATION OF UNDUHARDSHIP OR HISTORICALLY SIGNIFICANT STRUCTURE

Select at least one of the following statements:

Imposition of the rule would result in an undue hardship (unusual difficulty) because of physical limitations of the construction site or its utility services.

Imposition of the rule would result in an undue hardship (unusual difficulty) because of major operational problems in the use of the building or structure.

Imposition of the rule would result in an undue hardship (unusual difficulty) because of excessive costs of additional or altered construction elements.

Imposition of the rule would prevent the preservation of an architecturally or a historically significant part of the building or structure.

Facts demonstrating that the above selected statement is true:
SEE VARIANCE C

10. STATEMENT OF ACCURACY

I hereby certify under penalty of perjury that the information contained in this application is accurate.

Signature of applicant or person submitting application 	Please print name Stephen C. Hoffman	Date of signature (month, day, year) MAR 6 2016
Signature of design professional (if applicable) 	Please print name Stephen C. Hoffman	Date of signature (month, day, year) MAR 6 2016

11. STATEMENT OF AWARENESS (If the application is submitted on the applicant's behalf, the applicant must sign the following statement.)

I hereby certify under penalty of perjury that I am aware of this request for variance and that this application is being submitted on my behalf.

Signature of applicant 	Please print name Halilena Myndatt	Date of signature (month, day, year) 3/9/16
----------------------------	--	---



APPLICATION FOR VARIANCE

State Form 44400 (R7 / 10-13)
Approved by State Board of Accounts, 2013

INDIANA DEPARTMENT OF HOMELAND SECURITY
CODE SERVICES SECTION
302 West Washington Street, Room W246
Indianapolis, IN 46204-2739
http://www.in.gov/dhs/fire/cb_scomm_code/



INSTRUCTIONS: Please refer to the attached four (4) page instructions.
Attach additional pages as needed to complete this application.

Variance number (Assigned by department)
16-06-07 (e)

1. APPLICANT INFORMATION (Person who would be in violation if variance is not granted; usually this is the owner)	
Name of applicant ELIZABETH PERCY & HELENIA MYNATT	Title OWNERS
Name of organization N.A.	Telephone number (317) 446 1257
Address (number and street, city, state, and ZIP code) 11141 ROCKFORD RD MOORESVILLE IN 46158	

2. PERSON SUBMITTING APPLICATION ON BEHALF OF THE APPLICANT (If not submitted by the applicant)	
Name of applicant STEPHEN C. HOFFMAN	Title ENGINEER OF RECORD
Name of organization HOFFMAN ENGINEERS, P.C.	Telephone number (317) 443-1901 (c)
Address (number and street, city, state, and ZIP code) 8261 W. BASE LINE RD., PARAGON, IN 46166	

3. DESIGN PROFESSIONAL OF RECORD (If applicable)	
Name of design professional STEPHEN C. HOFFMAN	License number PE160016188
Name of organization HOFFMAN ENGINEERS, P.C.	Telephone number 317-443-1901 (c)
Address (number and street, city, state, and ZIP code) 8261 W. BASE LINE RD., PARAGON IN 46166	

4. PROJECT IDENTIFICATION		
Name of project WEDDING CHAPEL / WORSHIP HOUSE	State project number 379256	County MORGAN
Address of site (number and street, city, state, and ZIP code) 3663 MILKHOUSE LANE MOORESVILLE IN		
Type of project <input type="checkbox"/> New <input type="checkbox"/> Addition <input type="checkbox"/> Alteration <input type="checkbox"/> Change of occupancy <input checked="" type="checkbox"/> Existing		

5. REQUIRED ADDITIONAL INFORMATION
The following required information has been included with this application (check as applicable):
<input type="checkbox"/> A check made payable to the Indiana Department of Homeland Security for the appropriate amount. (see instructions)
<input type="checkbox"/> One (1) set of plans or drawings and supporting data that describe the area affected by the requested variance and any proposed alternatives. ✓
<input type="checkbox"/> Written documentation showing that the local fire official has <u>received</u> a copy of the variance application. TO FOLLOW
<input type="checkbox"/> Written documentation showing that the local building official has <u>received</u> a copy of the variance application. TO FOLLOW

6. VIOLATION INFORMATION
Has the Plan Review Section of the Division of Fire and Building Safety issued a Correction Order? <input type="checkbox"/> Yes (If yes, attach a copy of the Correction Order.) <input checked="" type="checkbox"/> No
Has a violation been issued? <input type="checkbox"/> Yes (If yes, attach a copy of the Violation and answer the following.) <input checked="" type="checkbox"/> No
Violation issued by: <input type="checkbox"/> Local Building Department <input type="checkbox"/> State Fire and Building Code Enforcement Section <input type="checkbox"/> Local Fire Department

7. DESCRIPTION OF REQUESTED VARIANCE

Name of code or standard and edition involved IECC	Specific code section 5.4.3.4
--	---

Nature of non-compliance (include a description of spaces, equipment, etc. involved as necessary.)
BUILDING DOES NOT HAVE AN ENCLOSED VESTIBULE AT THE MAIN ENTRANCE.

8. DEMONSTRATION THAT PUBLIC HEALTH, SAFETY, AND WELFARE WILL BE PROTECTED

Select one of the following statements:
 Non-compliance with the rule will not be adverse to the public health, safety or welfare; or
 Applicant will undertake alternative actions in lieu of compliance with the rule to ensure that granting of the variance will not be adverse to public health, safety, or welfare. Explain why alternative actions would be adequate (be specific).

Facts demonstrating that the above selected statement is true:
THE USE OF THE BUILDING IS LIMITED & SPORADIC AND ONLY FOR A FEW HOURS AT A TIME. ADDITION OF A VESTIBULE WOULD USE MORE ENERGY TO PRODUCE THE BUILDING MATERIALS THAN WOULD BE SAVED BY THE VESTIBULE AIR LOCK.

9. DEMONSTRATION OF UNDUE HARDSHIP OR HISTORICALLY SIGNIFICANT STRUCTURE

Select at least one of the following statements:
 Imposition of the rule would result in an undue hardship (unusual difficulty) because of physical limitations of the construction site or its utility services.
 Imposition of the rule would result in an undue hardship (unusual difficulty) because of major operational problems in the use of the building or structure.
 Imposition of the rule would result in an undue hardship (unusual difficulty) because of excessive costs of additional or altered construction elements.
 Imposition of the rule would prevent the preservation of an architecturally or a historically significant part of the building or structure.

Facts demonstrating that the above selected statement is true:
ADDITION OF VESTIBULE WOULD NOT BE OF VALUE AS THE USAGE IS SMALL

10. STATEMENT OF ACCURACY


I hereby certify under penalty of perjury that the information contained in this application is accurate.

Signature of applicant or person submitting application <i>[Signature]</i>	Please print name STEPHEN C. HOFFMAN	Date of signature (month, day, year) MAR 6 2016
Signature of design professional (if applicable) <i>[Signature]</i>	Please print name STEPHEN C. HOFFMAN	Date of signature (month, day, year) MAR 6 2016

11. STATEMENT OF AWARENESS (If the application is submitted on the applicant's behalf, the applicant must sign the following statement.)

I hereby certify under penalty of perjury that I am aware of this request for variance and that this application is being submitted on my behalf.

Signature of applicant <i>[Signature]</i>	Please print name Halienea Mynatt	Date of signature (month, day, year) 3/9/16
--	---	---



HOFFMAN ENGINEERS, P.C.

8261 W. BASE LINE ROAD
PARAGON, INDIANA 46166
765-537-2991 FAX: 765-537-2992
steve@hoffmanengineers.com
www.hoffmanengineers.com

"GLOBAL COMMITMENT WITH A MAIN STREET ATTITUDE"

March 6, 2016


Indiana Department of Homeland Security
Fire & Building Safety Plan Review

Re: Variance Requests for Wedding Chapel
Project # 379256

Please see the attached Variance Requests. Please send hearing date to
steve@hoffmanengineers.com

Your consideration is appreciated.

Thank you,



Stephen C. Hoffman PE

WEDDING CHAPEL

Would you like to reduce your turnaround time?

ELECTRONICALLY FILE YOUR PROJECT WITH STATE OF INDIANA at <http://www.in.gov/dhs/2650.htm>.

This on-line filing is through a secure site, you can use it to submit your project information, pay the fees and upload your project plans. Use Internet Browser to View this report, other browsers are not compatible to view this report



REQUEST FOR ADDITIONAL INFORMATION

DEPARTMENT OF HOMELAND SECURITY
PLAN REVIEW DIVISION
402 West Washington Street
Room E245
Indianapolis, IN 46204

Project Number 379256	Receipt No. 0	RFI Date 08/03/2015
Construction type		Occupancy classification
Scope of release requested		
Type of release requested		
Project Name Wedding Chapel Worship House		
Street address 3683 E Milkhouse Lane		
City Mooresville	County MORGAN	

REPORT PRINTED ON: 08/03/2015

To: Owner / Architect / Engineer FAX: 7665372992 951395

Hoffman Engineers PC
Stephen Clement Hoffman PE60016188
8201 Baseline Road
Paragon IN 46166

steve@hoffmanengineers.com

We are holding the above referenced project from further review and release for the reasons indicated below:

- : NOTE: A late filing fee of \$300.00 is due on this project. **CHECK ATTACHED**
- 14B0903212 : An automatic sprinkler system shall be provided for Group A-2 occupancies in accordance with Section 903.2.1.2, IBC (675 IAC 13-2.6).NOTE: This project is classified as a Group A, Division 2 occupancy per Section 303.3, IBC. **NOT REQ'D SEE ATTACHED**
- 14B2902 : Plumbing facilities shall be provided in accordance with Chapter 29 and Table 2902.1, IBC (675 IAC 13-2.6) NOTE: The use of portable facilities requires a variance or permanent facilities shall be provided. **VARIANCE A**
- : NOTE: Interior spaces intended for human occupancy shall be provided with active or passive space-heating systems capable of maintaining a minimum indoor temperature of 68 degrees F at a point 3 feet above the floor in accordance with Section 309, IMC. **VARIANCE B**
- 10C : The current Energy Code for this project is the 2010 Indiana Energy Conservation Code (675 IAC 15-4) consisting of ASHRAE Standard 90.1, 2007 edition, as amended by the State of Indiana.NOTE: Required for building envelope and mechanical. **VARIANCE C**
- 10C571 : For construction projects filed for which a design professional is required and where energy conservation details are required an Energy Compliance Report SIGNED AND SEALED by the design professional of record shall be submitted in accordance with Section 5.7.4, IECC (675 IAC 15-4). **VARIANCE D**
- 10C5434 : Building main entrance(s) that separate conditioned spaces from the exterior shall be protected with an enclosed vestibule in accordance with Section 5.4.3.4, IECC (675 IAC 15-4). **VARIANCE E**

RETURN THIS SHEET along with a minimum of 1 set of the corrected plans as soon as possible to the Code Review Official in order for us to continue processing your plans. If corrected plans and specifications are not received within 30 days of this request the application will be subject to denial by the Branch Director, Code Enforcement and Plan Review in accordance with Section 12, GAR 675 IAC 12-6-12 (b). IMMEDIATE ATTENTION AND RESPONSE IS REQUIRED.

Any questions concerning this matter should be addressed to the Code Review Official.

WEDDING CHAPEL 379256

Indiana Register

(3) Renumber exception 5 to read exception 2 and delete, "and combination fire/smoke dampers".

(q) Amend Section 717.5.4, Fire partitions, Exception 4, by adding in the last sentence after "terminals" ", except that flexible air connectors not exceeding five foot in length are permitted, provided no outlet or inlet terminals are provided for a distance on each side of the wall(s) equal to at least four duct-equivalent diameters".

(r) Amend Section 717.5.5, Smoke barriers, by deleting the text of the exception and inserting to read as follows: Smoke dampers shall not be required in duct penetrations of smoke barriers in fully ducted heating, ventilating, and air conditioning systems in smoke compartments protected throughout with quick response sprinklers.

(s) Amend Section 718.2.4, Stairways, by deleting the text and inserting to read as follows: Fire blocking shall be provided in concealed spaces between stair stringers at the top and bottom of the run and between studs along and in line with the run of stairs, if the walls under the stairs are unfinished, and shall comply with the requirements of Section 1009.9.3.

(t) Amend Section 722.3.4, Concrete masonry lintels, by deleting "by approved alternate methods" and inserting "as approved by the building official".

(u) Amend Section 722.3.5, Concrete masonry columns, by deleting "by approved alternate methods" and inserting "as approved by the building official".

(Fire Prevention and Building Safety Commission; 675 IAC 13-2.6-8; filed Aug 1, 2014, 11:12 a.m.: 20140827-IR-675130339FRA, eff Dec 1, 2014)

675 IAC 13-2.6-9 Chapter 8; interior finishes

Authority: IC 22-13-2-2; IC 22-13-2-13


Affected: IC 22-12; IC 22-13; IC 22-14; IC 22-15; IC 36-7

Sec. 9. Chapter 8 is amended as follows: (a) Delete Section 801.5, Applicability, without substitution.

(b) Amend footnote "b" under Table 803.9, Interior wall and ceiling finish requirements by occupancy, by deleting "I-2" and inserting "I-3".

(c) Amend Section 806, Decorative materials and trim, by deleting the text in its entirety, and inserting "See the Indiana Fire Code (675 IAC 22)".

(Fire Prevention and Building Safety Commission; 675 IAC 13-2.6-9; filed Aug 1, 2014, 11:12 a.m.: 20140827-IR-675130339FRA, eff Dec 1, 2014)

 675 IAC 13-2.6-10 Chapter 9; fire protection systems

Authority: IC 22-13-2-2; IC 22-13-2-13

Affected: IC 22-11-18; IC 22-12; IC 22-13; IC 22-14; IC 22-15; IC 36-7

Sec. 10. Chapter 9 is amended as follows: (a) Amend Section 901.3, Modifications, by deleting the text and inserting to read as follows: No person shall remove or modify any fire protection system installed or maintained in accordance with the rules of the commission without notifying the servicing fire department prior to receiving approval from the building official.

(b) Amend Section 901.5, Acceptance tests, by deleting the text and inserting to read as follows: 901.5 Acceptance tests. Fire protection systems shall be tested in accordance with the rules of the commission at the expense of the owner or owner's representative. When requested by the building official, such tests shall be conducted in the building official's presence. Prior to conducting such tests, the local building official shall be given at least 48-hours notice. It shall be unlawful to occupy portions of a structure until

WEDDING CHAPEL 379256

the required fire protection systems within that portion of the structure have been completed, successfully tested, and fully operational with appropriate contractor's material and test certificates filled out in full and provided to the building official.

(c) Amend Section 903.2.1.3, Group A-3, as follows:

(1) Add Exception 1 to read as follows: Fire areas not exceeding 7,000 square feet (650.3 m²) used primarily for worship with or without fixed seating and not used for exhibition or display, and the fire area is not located on a floor level other than that of exit discharge.

(2) Add Exception 2 to read as follows: The fire area is located on a floor other than the level of exit discharge. For purposes of determining the level of exit discharge, mezzanines of 2,000 s.f. or less in area in compliance with Section 505 shall be considered a portion of the story below if the total floor area and occupant load, including the mezzanine, are compliant with both conditions (1) and (2).

(d) Delete Section 903.2.2, Ambulatory care facilities, without substitution.

(e) Amend Section 903.2.6, Group I, by adding Exception 5 to read as follows: 5. In jails, prisons, and reformatories, the piping system may be dry, provided a manually operated valve is installed at a continuously monitored location such that opening the valve will cause the system to be charged. The valve may be located in a locked cabinet or enclosure provided the activation of a sprinkler unlocks the cabinet or enclosure.

(f) Amend Section 903.2.7, Group M, item number 4, by deleting the text and inserting to read as follows: A Group M fire area that contains more than 5,000 square feet (464 m²) of floor area used predominately for the display and sale of upholstered furniture or mattresses.

(g) Amend Section 903.2.10, Group S-2 enclosed parking garages, by deleting "406.4" and inserting "406.6".

(h) Amend Section 903.2.8 to add an exception as follows: Exception: Where a 13D sprinkler system is provided for an R-3 occupancy under Section 903.2.8.1, and an automatic sprinkler system is not otherwise required in other portions of the building, only the R3 occupancy is required to be provided with an automatic sprinkler system.

(i) Amend Section 903.2.11.1.3, Basements, by deleting the text and inserting to read as follows: Where any portion of a basement is located more than 75 feet (22,800 mm) from openings required by Section 903.2.11.1, the basement shall be equipped throughout with an approved automatic sprinkler system.

(j) Amend Section 903.3.1.1, NFPA 13 sprinkler systems, by deleting the text and inserting to read as follows: Where the provisions of this code require that a building or portion thereof be equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1, sprinklers shall be installed throughout in accordance with NFPA 13 (675 IAC 28-1-5) except as provided in Section 903.3.1.1.1.

(k) Amend Section 903.3.1.1.1, Exempt locations as follows:

(1) In item 2, delete ", when approved by the fire code official" without substitution.

(2) In item 4, delete the text and insert to read as follows: Elevator equipment rooms and hoistways used exclusively for the operation of elevators and that are separated from the remainder of the building by two (2) hour fire-resistive construction. Penetrations between machine rooms and hoistways necessary for the safe operation of an elevator, and vents required by Section 3004 of this code need not be fire-rated.

(l) Amend Section 903.3.1.2, NFPA 13R sprinkler systems, by deleting "o" after "Group".

(m) Amend Section 903.3.5.1.1, Limited area sprinkler systems, in the exception, by deleting "An approved" and inserting "A listed".



APPLICATION FOR VARIANCE

State Form 44400 (R7 / 10-13)
Approved by State Board of Accounts, 2013

INDIANA DEPARTMENT OF HOMELAND SECURITY
CODE SERVICES SECTION
302 West Washington Street, Room W245
Indianapolis, IN 46204-2739
http://www.in.gov/dhs/fire/fs_bs_connm_code/



INSTRUCTIONS: Please refer to the attached four (4) page instructions.
Attach additional pages as needed to complete this application.

Variance number (Assigned by department)

16-06-07 (F)

1. APPLICANT INFORMATION (Person who would be in violation if variance is not granted; usually this is the owner)

Name of applicant	ELIENE PERCY & HALENIA MYNATT	Title	
Name of organization	N.A.	Telephone number	(317)-446-1257
Address (number and street, city, state, and ZIP code)			
11141 ROCKER RD MOORESVILLE IN 46158			

2. PERSON SUBMITTING APPLICATION ON BEHALF OF THE APPLICANT (if not submitted by the applicant)

Name of applicant	STEPHEN C. HOFFMAN	Title	ENGINEER OF RECORD
Name of organization	HOFFMAN ENGINEERS, P.C.	Telephone number	317-443-1901 (C)
Address (number and street, city, state, and ZIP code)			
8761 W. BASELINE RD DAVENPORT, IN 46166			

3. DESIGN PROFESSIONAL OF RECORD (if applicable)

Name of design professional	STEPHEN C. HOFFMAN	License number	PE 60016123
Name of organization	HOFFMAN ENGINEERS, P.C.	Telephone number	317-443-1901
Address (number and street, city, state, and ZIP code)			
8761 W. BASELINE RD DAVENPORT, IN 46166			

4. PROJECT IDENTIFICATION

Name of project	WOODING CHAPEL WORSHIP HOUSE	State project number	319250	County	MORGAN
Address of site (number and street, city, state, and ZIP code)					
3603 MILKHOKE LANE MOORESVILLE IN					
Type of project					
<input type="checkbox"/> New <input type="checkbox"/> Addition <input type="checkbox"/> Alteration <input type="checkbox"/> Change of occupancy <input checked="" type="checkbox"/> Existing					

5. REQUIRED ADDITIONAL INFORMATION

The following required information has been included with this application (check as applicable):

- A check made payable to the Indiana Department of Homeland Security for the appropriate amount. (see instructions)
- One (1) set of plans or drawings and supporting data that describe the area affected by the requested variance and any proposed alternatives.
- Written documentation showing that the local fire official has received a copy of the variance application.
- Written documentation showing that the local building official has received a copy of the variance application.

6. VIOLATION INFORMATION

Has the Plan Review Section of the Division of Fire and Building Safety issued a Correction Order?

Yes (If yes, attach a copy of the Correction Order.) No

Has a violation been issued?

Yes (If yes, attach a copy of the Violation and answer the following.) No

Violation issued by:

Local Building Department
 State Fire and Building Code Enforcement Section
 Local Fire Department

7. DESCRIPTION OF REQUESTED VARIANCE

Name of code or standard and edition involved: **IBC 2014** Specific code section: **903.2.1.2 & 303.3**

Nature of non-compliance (include a description of spaces, equipment, etc. involved as necessary):
A-2 OCCUPANCY

8. DEMONSTRATION THAT PUBLIC HEALTH, SAFETY, AND WELFARE WILL BE PROTECTED

Select one of the following statements:
 Non-compliance with the rule will not be adverse to the public health, safety or welfare; or
 Applicant will undertake alternative actions in lieu of compliance with the rule to ensure that granting of the variance will not be adverse to public health, safety, or welfare. Explain why alternative actions would be adequate (be specific).

Facts demonstrating that the above selected statement is true:
**BUILDING IS SMALL, EVENTS ARE SMALL & THERE ARE
 4 EXITS FROM BUILDING.
 THERE ARE NO COOKING FACILITIES
 THERE ARE NO RESTROOMS OR OTHER ROOMS WHERE
 A FIRE COULD START HIDDEN**

9. DEMONSTRATION OF UNDUE HARDSHIP OR HISTORICALLY SIGNIFICANT STRUCTURE

Select at least one of the following statements:
 Imposition of the rule would result in an undue hardship (unusual difficulty) because of physical limitations of the construction site or its utility services.
 Imposition of the rule would result in an undue hardship (unusual difficulty) because of major operational problems in the use of the building or structure.
 Imposition of the rule would result in an undue hardship (unusual difficulty) because of excessive costs of additional or altered construction elements.
 Imposition of the rule would prevent the preservation of an architecturally or a historically significant part of the building or structure.

Facts demonstrating that the above selected statement is true:
**ADEQUATE SUPPLY OF WATER IS NOT AVAILABLE AT
 A REASONABLE DISTANCE (OVER 600 FT) FROM
 BUILDING**

10. STATEMENT OF ACCURACY

I hereby certify under penalty of perjury that the information contained in this application is accurate.

Signature of applicant or person submitting application	Please print name	Date of signature (month, day, year)
	STEPHEN C. HOFFMAN	20 MAY 16
Signature of design professional (if applicable)	Please print name	Date of signature (month, day, year)
	STEPHEN C. HOFFMAN	20 MAY 16

11. STATEMENT OF AWARENESS (If the application is submitted on the applicant's behalf, the applicant must sign the following statement)

I hereby certify under penalty of perjury that I am aware of this request for variance and that this application is being submitted on my behalf.

Signature of applicant	Please print name	Date of signature (month, day, year)
	HALIENA MYNATT	5.26.16

WEDDING CHAPEL

Would you like to reduce your turnaround time?

ELECTRONICALLY FILE YOUR PROJECT WITH STATE OF INDIANA at <http://www.in.gov/dhs/2650.htm>.
 This on-line filing is through a secure site, you can use it to submit your project information, pay the fees and upload your project plans.
 Use Internet Browser to view this report, other browsers are not compatible to view this report



REQUEST FOR ADDITIONAL INFORMATION

DEPARTMENT OF HOMELAND SECURITY
 PLAN REVIEW DIVISION
 402 West Washington Street
 Room E246
 Indianapolis, IN 46204

Project Number 379266	Receipt No. 0	RFI Date 08/03/2015
Construction type	Occupancy classification	
Scope of release requested		
Type of release requested		
Project Name Wedding Chapel Worship House		
Street address 3663 E Milkhouse Lane		
City Mooresville	County MORGAN	

REPORT PRINTED ON: 08/03/2015

951998

FAX: 7665972592

To: Owner / Architect / Engineer

Hoffman Engineers PC
 Stephen Clarent Hoffman PE60016108
 8201 Baseline Road
 Paragon IN 46166
 shve@hoffmanengineers.com

We are holding the above referenced project from further review and release for the reasons indicated below:

- 1 : NOTE: A late filing fee of \$300.00 is due on this project. **CHECK ATTACHED VARIANCE F**
- 2 1480903212 : An automatic sprinkler system shall be provided for Group A-2 occupancies in accordance with Section 903.2.1.2, IBC (675 IAC 13-2.8).NOTE: This project is classified as a Group A, Division 2 occupancy per Section 203.3, IBC. **NOT REQ'D SEE ATTAC**
- 3 1482902 : Plumbing facilities shall be provided in accordance with Chapter 29 and Table 2002.1, IBC (675 IAC 13-2.6).NOTE: This use of portable facilities requires a variance or permanent facilities shall be provided. **VARIANCE A**
- 4 : NOTE: Interior spaces intended for human occupancy shall be provided with active or passive space-heating systems capable of maintaining a minimum indoor temperature of 68 degrees F at a point 3 feet above the floor in accordance with Section 309, IMC. **VARIANCE B**
- 5 10C : This current Energy Code for this project is the 2010 Indiana Energy Conservation Code (675 IAC 19-4) consisting of ASHRAE Standard 90.1, 2007 edition, as amended by the State of Indiana.NOTE: Required for building envelope and mechanical. **VARIANCE C**
- 6 10C571 : For construction projects filed for which a design professional is required and where energy conservation details are required an Energy Compliance Report SIGNED AND SEALED by the design professional of record shall be submitted in accordance with Section 5.7.1, IECC (675 IAC 19-4). **VARIANCE D**
- 7 10C5434 : Building main entrance(s) that separate conditioned spaces from the exterior shall be protected with an enclosed vestibule in accordance with Section 5.4.3.4, IECC (675 IAC 19-4). **VARIANCE E**

RETURN THIS SHEET along with a minimum of 1 set of the corrected plans as soon as possible to the Code Review Official in order for us to continue processing your plans. If corrected plans and specifications are not received within 30 days of this request the application will be subject to denial by the Branch Director, Code Enforcement and Plan Review in accordance with Section 12, GAR 675 IAC 12-6-12 (b). IMMEDIATE ATTENTION AND RESPONSE IS REQUIRED.

Any questions concerning this matter should be addressed to the Code Review Official.