



APPLICATION FOR VARIANCE

State Form 44400 (R7 / 10-13)
Approved by State Board of Accounts, 2013

INDIANA DEPARTMENT OF HOMELAND SECURITY
CODE SERVICES SECTION
302 West Washington Street, Room W246
Indianapolis, IN 46204-2739
http://www.in.gov/dhs/fire/fp_bs_comm_code/



INSTRUCTIONS: Please refer to the attached four (4) page instructions.
Attach additional pages as needed to complete this application.

Variance number (Assigned by department)
17-03-06

1. APPLICANT INFORMATION (Person who would be in violation if variance is not granted; usually this is the owner)

Name of applicant Rob Staley	Title Executive Director
Name of organization The Crossing National, Inc.	Telephone number (574) 226-0671
Address (number and street, city, state, and ZIP code) 2930 S. Napanee St., Elkhart, In. 46517	

2. PERSON SUBMITTING APPLICATION ON BEHALF OF THE APPLICANT (If not submitted by the applicant)

Name of applicant Jennifer Hasbrook	Title Administrator
Name of organization The Crossing National, Inc.	Telephone number (574) 226-0671
Address (number and street, city, state, and ZIP code) 2930 S. Nappanee St., Elkhart, In. 46517	

3. DESIGN PROFESSIONAL OF RECORD (If applicable)

Name of design professional n/a	License number
Name of organization	Telephone number ()
Address (number and street, city, state, and ZIP code)	

4. PROJECT IDENTIFICATION

Name of project Syracuse Crossing	State project number S	County
Address of site (number and street, city, state, and ZIP code) 304 W. Main Street, Syracuse, In. 46567		
Type of project <input type="checkbox"/> New <input type="checkbox"/> Addition <input type="checkbox"/> Alteration <input type="checkbox"/> Change of occupancy <input checked="" type="checkbox"/> Existing		

5. REQUIRED ADDITIONAL INFORMATION

The following required information has been included with this application (check as applicable):

- A check made payable to the Indiana Department of Homeland Security for the appropriate amount. (see instructions)
- One (1) set of plans or drawings and supporting data that describe the area affected by the requested variance and any proposed alternatives.
- Written documentation showing that the local fire official has received a copy of the variance application.
- Written documentation showing that the local building official has received a copy of the variance application.

6. VIOLATION INFORMATION

Has the Plan Review Section of the Division of Fire and Building Safety issued a Correction Order?
 Yes (If yes, attach a copy of the Correction Order.) No

Has a violation been issued?
 Yes (If yes, attach a copy of the Violation and answer the following.) No

Violation issued by:
 Local Building Department State Fire and Building Code Enforcement Section Local Fire Department

7. DESCRIPTION OF REQUESTED VARIANCE

Name of code or standard and edition involved

2014 Edition IBC

Specific code section

675 IAC 13-2.6

Nature of non-compliance (include a description of spaces, equipment, etc. involved as necessary.)

[F] 907.2.3 Group E. A manual fire alarm system shall be installed in Group E occupancies. When automatic sprinkler systems or smoke detectors are installed, such systems or detectors shall be connected to the building fire alarm system.

Exceptions:

1. Group E occupancies with an occupant load of less than 50.
2. Manual fire alarm boxes are not required in Group E occupancies where the following apply:
 - 2.1 Interior corridors are protected by smoke detectors with alarm verification.
 - 2.2 Auditoriums, cafeterias, gymnasiums and the like are protected by heat detectors or other approved detection devices.
 - 2.3 Shops and laboratories involving dusts or vapors are protected by heat detectors or other listed detection.
 - 2.4 Off premise monitoring is provided.
 - 2.5 The capability to activate the evacuation signal from a central point is provided.
 - 2.6 In buildings where normally occupied spaces are provided with a two-way communication system between such spaces and a constantly attended receiving station from where a general evacuation alarm can be sounded.
3. Manual fire alarm boxes shall not be required in Group E occupancies where the building is equipped throughout with an approved automatic sprinkler system, the notification appliances will activate on sprinkler water flow and manual activation provided from a normally occupied location.

The calculated occupant load of school is 102 persons. A fire alarm system or sprinkler system is required per the above code reference.

8. DEMONSTRATION THAT PUBLIC HEALTH, SAFETY, AND WELFARE WILL BE PROTECTED

Select one of the following statements:

- Non-compliance with the rule will not be adverse to the public health, safety or welfare; or
- Applicant will undertake alternative actions in lieu of compliance with the rule to ensure that granting of the variance will not be adverse to public health, safety, or welfare. Explain why alternative actions would be adequate (be specific).

Facts demonstrating that the above selected statement is true:

Variance to be classified to Group E. The Crossing is temporarily planning to stay in the building until the end of the school year. We are asking for an option to stay and have the variance granted for up to 2 years, or until June 30, 2019. The extra time will allow for The Crossing to locate another building.

9. DEMONSTRATION OF UNDUE HARDSHIP OR HISTORICALLY SIGNIFICANT STRUCTURE

Select at least one of the following statements:

- Imposition of the rule would result in an undue hardship (unusual difficulty) because of physical limitations of the construction site or its utility services.
- Imposition of the rule would result in an undue hardship (unusual difficulty) because of major operational problems in the use of the building or structure.
- Imposition of the rule would result in an undue hardship (unusual difficulty) because of excessive costs of additional or altered construction elements.
- Imposition of the rule would prevent the preservation of an architecturally or a historically significant part of the building or structure.

Facts demonstrating that the above selected statement is true:

A Sprinkler system installed in this facility will cause a financial hardship for The Crossing.

10. STATEMENT OF ACCURACY

I hereby certify under penalty of perjury that the information contained in this application is accurate.

Signature of applicant or person submitting application



Please print name

Jennifer Hasbrook

Date of signature (month, day, year)

2/13/17


Signature of design professional (if applicable)

Please print name

Date of signature (month, day, year)

11. STATEMENT OF AWARENESS (if the application is submitted on the applicant's behalf, the applicant must sign the following statement.)

I hereby certify under penalty of perjury that I am aware of this request for variance and that this application is being submitted on my behalf.

Signature of applicant 	Please print name Rob Staley	Date of signature (month, day, year) 2/14/2012
---	---------------------------------	---



FIRE AND BUILDING CODE ENFORCEMENT INSPECTION REPORT ORDER

DIVISION OF FIRE AND BUILDING SAFETY
 INDIANA DEPARTMENT OF HOMELAND SECURITY
 302 WEST WASHINGTON STREET, RM E241
 INDIANAPOLIS, IN 46204
 TELEPHONE: 317-232-2222
 WEB ADDRESS: WWW.IN.GOV/DHS

Identification Number BU26784	Name of the facility THE CROSSING SCHOOL	County KOSCIUSKO
Address of Property 304 W MAIN ST SYRACUSE 46567	Name of the Contact BARBARA RICE	Telephone Number (574) 400-8472
Email doreenshelt@gmail.com	Inspection Date 01/18/2017	
Inspection Category BUSINESS/MANUFACTURING	Inspection Type REINSPECTION	Inspection Status: VIOLATION
Name of the inspector ED SORENSEN	Phone: 3175174524	
Email: esoransen@dhs.in.gov		

Violations

VIO- LATION NUMBER	RULE OR INDIANA CODE SECTION VIOLATED	DESCRIPTION OF VIOLATION	DATE BY WHICH VIOLATION MUST BE CORRECTED
1	Sec. 405.5 2014 Edition IFC 675 IAC 22-2.5	<p>Records shall be maintained of required emergency evacuation drills and include the following information:</p> <ol style="list-style-type: none"> 1. Identity of the person conducting the drill. 2. Date and time of the drill. 3. Notification method used. 4. Staff members on duty and participating. 5. Number of occupants evacuated. 6. Special conditions simulated. 7. Problems encountered. 8. Weather conditions when occupants were evacuated. 9. Time required to accomplish complete evacuation. <p><u>Provide current copy of monthly fire drills.</u></p>	02/18/2017
2	Sec. 404.3.2 2014 Edition IFC 675 IAC 22-2.5	<p>Fire safety plans shall include the following:</p> <ol style="list-style-type: none"> 1. The procedure for reporting a fire or other emergency. 2. The life safety strategy and procedures for notifying, relocating or evacuating occupants, including occupants who need assistance. 3. Site plans indicating the following: <ol style="list-style-type: none"> 3.1. The occupancy assembly point. 3.2. The locations of fire hydrants. 3.3. The normal routes of fire department vehicle access. 4. Floor plans identifying the locations of the following: <ol style="list-style-type: none"> 4.1. Exits. 4.2. Primary evacuation routes. 4.3. Secondary evacuation routes. 4.4. Accessible egress routes. 4.5. Areas of refuge. 4.6. Exterior areas for assisted rescue. 4.7. Manual fire alarm boxes. 4.8. Portable fire extinguishers. 4.9. Occupant-use hose stations. 4.10. Fire alarm annunciators and controls. 5. A list of major fire hazards associated with the normal use and occupancy of the premises, including maintenance and housekeeping procedures. 	02/18/2017

		<p>6. Identification and assignment of personnel responsible for maintenance of systems and equipment installed to prevent or control fires.</p> <p>7. Identification and assignment of personnel responsible for maintenance, housekeeping and controlling fuel hazard sources.</p> <p><u>Provide copy of fire safety and evacuation plans for review.</u></p>	
3	<p>Sec. 1006.3 2014 Edition IBC 675 IAC 13-2.6</p>	<p>The power supply for means of egress illumination shall normally be provided by the premises' electrical supply. In the event of power supply failure, an emergency electrical system shall automatically illuminate all of the following areas:</p> <ol style="list-style-type: none"> 1. Aisles and unenclosed egress stairways in rooms and spaces that require two or more means of egress. 2. Corridors, interior exit stairways and ramps and exit passageways in buildings required to have two or more exits. 3. Exterior egress components at other than their levels of exit discharge until exit discharge is accomplished for buildings required to have two or more exits. 4. Interior exit discharge elements, as permitted in Section 1027.1, in buildings required to have two or more exits. 5. Exterior landings as required by Section 1008.1.6 for exit discharge doorways in buildings required to have two or more exits. <p>The emergency power system shall provide power for a duration of not less than 90 minutes and shall consist of storage batteries, unit equipment or an on-site generator. The installation of the emergency power system shall be in accordance with Section 2702.</p> <p><u>Provide emergency lighting to enable the students to see the exits in the event of a power failure.</u></p>	02/18/2017
4	<p>2014 Edition IBC 675 IAC 13-2.6</p>	<p>SECTION 1015 EXIT AND EXIT ACCESS DOORWAYS</p> <p>1015.1 Exits or exit access doorways from spaces. Two vided where one of the following conditions exists:</p> <ol style="list-style-type: none"> 1. The occupant load of the space exceeds one of the values in Table 1015.1. <p>Exceptions:</p> <ol style="list-style-type: none"> 1. In Group R-2 and R-3 occupancies, one means of egress is permitted within and from individual dwelling units with a maximum occupant load of 20 where the dwelling unit is equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2. 2. Care suites in Group I-2 occupancies complying with Section 407.4.3. 2. The common path of egress travel exceeds one of the limitations of Section 1014.3 3. Where required by Section 1015.3, 1015.4, 1015.5, or 1015.6. <p>Where a building contains mixed occupancies, each individual occupancy shall comply with the applicable requirements for that occupancy. Where applicable, cumulative * occupant loads from adjacent occupancies shall be considered in accordance with the provisions of Section 1004.1.</p> <p><u>The calculated occupant load is over 49 people. There is only one exit for the school. Need one additional exit.</u></p>	02/18/2017
5	<p>Sec. 1011.1 2014 Edition IBC 675 IAC 13-2.6</p>	<p>Exits and exit access doors shall be marked by an approved exit sign readily visible from any direction of egress travel. The path of egress travel to exits and within exits shall be marked by readily visible exit</p>	02/18/2017

		<p>signs to clearly indicate the direction of egress travel in cases where the exit or the path of egress travel is not immediately visible to the occupants. Intervening means of egress doors within exits shall be marked by exit signs. Exit sign placement shall be such that no point in an exit access corridor or exit passageway is more than 100 feet (30,480 mm) or the listed viewing distance for the sign, whichever is less, from the nearest visible exit sign.</p> <p>Exceptions:</p> <ol style="list-style-type: none"> 1. Exit signs are not required in rooms or areas that require only one exit or exit access. 2. Main exterior exit doors or gates that are obviously and clearly identifiable as exits need not have exit signs where approved by the fire code official. 3. Exit signs are not required in occupancies in Group U and individual sleeping units or dwelling units in Group R-1, R-2 or R-3. 4. Exit signs are not required in dayrooms, sleeping rooms or dormitories in occupancies in Group I-3. 5. In occupancies in Groups A-4 and A-5, exit signs are not required on the seating side of vomitories or openings into seating areas where exit signs are provided in the concourse that are readily apparent from the vomitories. Egress lighting is provided to identify each vomitory or opening within the seating area in an emergency. <p><u>Provide exit signs at all required exits.</u></p>	
6	2014 Edition IBC 675 IAC 13-2.6	<p>[F] 907.2.3 Group E. A manual fire alarm system shall be installed in Group E occupancies. When automatic sprinkler systems or smoke detectors are installed, such systems or detectors shall be connected to the building fire alarm system.</p> <p>Exceptions:</p> <ol style="list-style-type: none"> 1. Group E occupancies with an occupant load of less than 50. 2. Manual fire alarm boxes are not required in Group E occupancies where all of the following apply: <ol style="list-style-type: none"> 2.1. Interior corridors are protected by smoke detectors with alarm verification. 2.2. Auditoriums, cafeterias, gymnasiums and the like are protected by heat detectors or other approved detection devices. 2.3. Shops and laboratories involving dusts or vapors are protected by heat detectors or other listed detection. 3. Manual fire alarm boxes shall not be required in Group E occupancies where the building is equipped throughout with an approved automatic sprinkler system, the notification appliances will activate on sprinkler water flow and manual activation is provided from a normally occupied location. <p><u>The calculated occupant load of school is 102 persons. A fire alarm system or sprinkler system is required per the above code reference.</u></p>	02/18/2017

Facility Id	Received By Name	Signature and Date
BU26784		



FIRE AND BUILDING CODE ENFORCEMENT INSPECTION REPORT ORDER

DIVISION OF FIRE AND BUILDING SAFETY
INDIANA DEPARTMENT OF HOMELAND SECURITY
302 WEST WASHINGTON STREET, RM E241
INDIANAPOLIS, IN 46204
TELEPHONE: 317-232-2222
WEB ADDRESS: WWW.IN.GOV/DHS

Identification Number BU26784	Name of the facility THE CROSSING SCHOOL	County KOSCIUSKO
Address of Property 304 W MAIN ST SYRACUSE 46567	Name of the Contact BARBARA RICE	Telephone Number (574) 400-8472
Email		Inspection Date 11/17/2016
Inspection Category BUSINESS/MANUFACTURING	Inspection Type INITIAL	Inspection Status: VIOLATION
Name of the Inspector EJ Sorenson	Phone: 3175174524	
Email: esorenson@dhs.in.gov		

Violations

VIO-LATION NUMBER	RULE OR INDIANA CODE SECTION VIOLATED	DESCRIPTION OF VIOLATION	DATE BY WHICH VIOLATION MUST BE CORRECTED
1	Sec. 405.5 2014 Edition IFC 675 IAC 22-2.5	Records shall be maintained of required emergency evacuation drills and include the following information: 1. Identity of the person conducting the drill. 2. Date and time of the drill. 3. Notification method used. 4. Staff members on duty and participating. 5. Number of occupants evacuated. 6. Special conditions simulated. 7. Problems encountered. 8. Weather conditions when occupants were evacuated. 9. Time required to accomplish complete evacuation. <u>Provide current copy of monthly fire drills.</u>	12/7/16
2	Sec. 605.5 2014 Edition IFC 675 IAC 22-2.5	Extension cords and flexible cords shall not be a substitute for permanent wiring. Extension cords and flexible cords shall not be affixed to structures, extended through walls, ceilings or floors, or under doors or floor coverings, nor shall such cords be subject to environmental damage or physical impact. Extension cords shall be used only with portable appliances. <u>Two extension cords were found downstairs snack area need to be removed and instead use a permanent outlet for those appliances(microwave oven,etc.).</u>	12/17/2016
3	675 IAC 12-4-11 Occupancy of existing buildings	675 IAC 12-4-11 Occupancy of existing buildings Authority: IC 22-13-2-13 Affected: IC 12-17-2; IC 22-12-6-6; IC 22-13-2-2; IC 22-13-2-8; IC 36-8-17-13 Sec. 11. (a) Any building or structure lawfully in existence at the time of the adoption of any rule of the commission for new construction may have its existing use or occupancy continued without having to be altered to comply with such a rule. (b) No change in the character or use of any building or structure shall be permitted that shall cause	12/17/2016

		<p>the building or structure to be classified within a different occupancy group or within a different division of the same occupancy group, unless the building or structure complies with, or is made to comply with the:</p> <p>(1) current rules of the commission for new construction for the proposed revised use of the building; or</p> <p>(2) provisions of:</p> <p>(A) Chapter 34 of the Indiana Building Code (675 IAC 13-2.6-34); or</p> <p>(B) 675 IAC 12-13.</p> <p><u>This building's occupancy has changed from being used as an assembly use as a church and now is being used as a school upstairs and a residence downstairs. Please file plans for a change of occupancy with the state.</u></p>	12/7/2016
4	<p>Sec. 901.6 2014 Edition IFC 675 IAC 22-2.5</p>	<p>Fire detection, alarm, and extinguishing systems, mechanical smoke exhaust systems, and smoke and heat vents shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Nonrequired fire protection systems and equipment shall be inspected, tested and maintained or removed.</p> <p><u>The downstairs smoke alarm doesn't work. Please restore it to proper operation.</u></p>	12/17/2016
5	<p>Sec. 404.3.2 2014 Edition IFC 675 IAC 22-2.5</p>	<p>Fire safety plans shall include the following:</p> <ol style="list-style-type: none"> 1. The procedure for reporting a fire or other emergency. 2. The life safety strategy and procedures for notifying, relocating or evacuating occupants, including occupants who need assistance. 3. Site plans indicating the following: <ol style="list-style-type: none"> 3.1. The occupancy assembly point. 3.2. The locations of fire hydrants. 3.3. The normal routes of fire department vehicle access. 4. Floor plans identifying the locations of the following: <ol style="list-style-type: none"> 4.1. Exits. 4.2. Primary evacuation routes. 4.3. Secondary evacuation routes. 4.4. Accessible egress routes. 4.5. Areas of refuge. 4.6. Exterior areas for assisted rescue. 4.7. Manual fire alarm boxes. 4.8. Portable fire extinguishers. 4.9. Occupant-use hose stations. 4.10. Fire alarm annunciators and controls. 5. A list of major fire hazards associated with the normal use and occupancy of the premises, including maintenance and housekeeping procedures. 6. Identification and assignment of personnel responsible for maintenance of systems and equipment installed to prevent or control fires. 7. Identification and assignment of personnel responsible for maintenance, housekeeping and controlling fuel hazard sources. <p><u>Provide copy of fire safety and evacuation plans for review.</u></p>	12/7/2016
6	<p>2014 Edition IBC 675 IAC 13-2.6</p>	<p>[F] 907.2.3 Group E. A manual fire alarm system shall be installed in Group E occupancies. When automatic sprinkler systems or smoke detectors are installed, such systems or detectors shall be connected to the building fire alarm system.</p> <p>Exceptions:</p> <ol style="list-style-type: none"> 1. Group E occupancies with an occupant load of 	12/17/2016

less than 50.
 2. Manual fire alarm boxes are not required in Group E occupancies where all of the following apply:
 2.1. Interior corridors are protected by smoke detectors with alarm verification.
 2.2. Auditoriums, cafeterias, gymnasiums and the like are protected by heat detectors or other approved detection devices.
 2.3. Shops and laboratories involving dusts or vapors are protected by heat detectors or other listed detection.
 3. Manual fire alarm boxes shall not be required in Group E occupancies where the building is equipped throughout with an approved automatic sprinkler system, the notification appliances will activate on sprinkler water flow and manual activation is provided from a normally occupied location.

The calculated occupant load of school is 102 persons. A fire alarm system or sprinkler system is required per the above code reference.

Sec. 1030.2
 2014 Edition IFC
 675 IAC 22-2.5

Required exit accesses, exits and exit discharges shall be continuously maintained free from obstructions or impediments to full instant use in the case of fire or other emergency when the building area served by the means of egress is occupied. An exit or exit passageway shall not be used for any purpose that interferes with a means of egress.

12/17/2016

One of the leafs of the front exit double doors has wooden blocks on the panic bar that prevents it from opening. The blocks need to be removed to allow instant use of this exit door.

2014 Edition IBC
 675 IAC 13-2.6

SECTION 1015
 EXIT AND EXIT ACCESS DOORWAYS
 1015.1 Exits or exit access doorways from spaces. Two provided where one of the following conditions exists:
 1. The occupant load of the space exceeds one of the values in Table 1015.1.
 Exceptions:
 1. In Group R-2 and R-3 occupancies, one means of egress is permitted within and from individual dwelling units with a maximum occupant load of 20 where the dwelling unit is equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2.
 2. Care suites in Group I-2 occupancies complying with Section 407.4.3.
 2. The common path of egress travel exceeds one of the limitations of Section 1014.3
 3. Where required by Section 1015.3, 1015.4, 1015.5, or 1015.6.
 Where a building contains mixed occupancies, each individual occupancy shall comply with the applicable requirements for that occupancy. Where applicable, cumulative * occupant loads from adjacent occupancies shall be considered in accordance with the provisions of Section 1004.1.

12/17/2016


The calculated occupant load is over 49 people. There is only one exit

	<p><u>for the school. Need one additional exit.</u></p>	
<p>Sec. 1011.1 2014 Edition IBC 675 IAC 13-2.6</p>	<p>Exits and exit access doors shall be marked by an approved exit sign readily visible from any direction of egress travel. The path of egress travel to exits and within exits shall be marked by readily visible exit signs to clearly indicate the direction of egress travel in cases where the exit or the path of egress travel is not immediately visible to the occupants. Intervening means of egress doors within exits shall be marked by exit signs. Exit sign placement shall be such that no point in an exit access corridor or exit passageway is more than 100 feet (30,480 mm) or the listed viewing distance for the sign, whichever is less, from the nearest visible exit sign.</p> <p>Exceptions:</p> <ol style="list-style-type: none"> 1. Exit signs are not required in rooms or areas that require only one exit or exit access. 2. Main exterior exit doors or gates that are obviously and clearly identifiable as exits need not have exit signs where approved by the fire code official. 3. Exit signs are not required in occupancies in Group U and individual sleeping units or dwelling units in Group R-1, R-2 or R-3. 4. Exit signs are not required in dayrooms, sleeping rooms or dormitories in occupancies in Group I-3. 5. In occupancies in Groups A-4 and A-5, exit signs are not required on the seating side of vomitories or openings into seating areas where exit signs are provided in the concourse that are readily apparent from the vomitories. Egress lighting is provided to identify each vomitory or opening within the seating area in an emergency. <p><u>Provide exit signs at all required exits.</u></p>	<p>12/17/2016</p>
<p>Sec. 1006.3 2014 Edition IBC 675 IAC 13-2.6</p>	<p>The power supply for means of egress illumination shall normally be provided by the premises' electrical supply. In the event of power supply failure, an emergency electrical system shall automatically illuminate all of the following areas:</p> <ol style="list-style-type: none"> 1. Aisles and unenclosed egress stairways in rooms and spaces that require two or more means of egress. 2. Corridors, interior exit stairways and ramps and exit passageways in buildings required to have two or more exits. 3. Exterior egress components at other than their levels of exit discharge until exit discharge is accomplished for buildings required to have two or more exits. 4. Interior exit discharge elements, as permitted in Section 1027.1, in buildings required to have two or more exits. 5. Exterior landings as required by Section 1008.1.6 for exit discharge doorways in buildings required to have two or more exits. <p>The emergency power system shall provide power for a duration of not less than 90 minutes and shall consist of storage batteries, unit equipment or an on-site generator. The installation of the emergency power system shall be in accordance with Section 2702.</p> <p><u>Provide emergency lighting to enable the students to see the exits in the event of a power failure.</u></p>	<p>12/17/2016</p>
<p>Sec. 7.3.1.1.1 2010 Edition NFPA 10 675 IAC 28-1-2</p>	<p>Fire extinguishers shall be subjected to maintenance at intervals of not more than 1 year, at the time of hydrostatic test, or when specifically indicated by an inspection or electronic notification.</p> <p><u>Classroom fire extinguisher is over due for it's annual inspection.</u></p>	<p>12/17/2016</p>

Utility Id
26784

Received By Name

Signature and Date



11/17/16