From:	noreply@formstack.com
То:	Fire Prevention and Building and Safety Commission
Subject:	Code Comments, Proposals and Advice
Date:	Wednesday, May 19, 2021 5:06:46 PM

## \*\*\*\* This is an EXTERNAL email. Exercise caution. DO NOT open attachments or click links from unknown senders or unexpected email. \*\*\*\*



## **Formstack Submission For: 4202** Submitted at 05/19/21 5:06 PM

Name:	Daniel Schenkel
Email:	dan@eri.consulting
Phone:	(260) 490-1025
Address:	4175 New Vision Drive Fort Wayne, IN 46845
Indiana Code You Are Commenting On:	2012 International Building Code and ASCE7-10 (incorporated by reference into IBC2012)
Comment or Proposal:	For hospitals and other occupancy category IV buildings in northern Indiana with soil Site Class C, Table 11.6-2 of ASCE7-10 (per IBC2012) requires that the structure be designed as Seismic Design Category C whereas the same table in ASCE7-16 (per IBC2018) only requires that the structure be designed for Seismic Design Category A. This difference results in a significant fiscal impact to the design of these types of structures in northern Indiana. Seismic Design Category C results in design for a significantly higher lateral force resulting in increased member sizing for the lateral load resisting system. In addition, Seismic Design Category C triggers structural seismic detailing

requirements as well as seismic bracing of non structural components (mechanical and electrical components hanging from the structure, etc). The fiscal impact of this difference between the current code and the adopted IBC 2012 code can be several hundred thousand dollars on a large hospital construction project.

File:

Copyright © 2021 Formstack, LLC. All rights reserved. This is a customer service email.

Formstack, 11671 Lantern Road, Suite 300, Fishers, IN 46038