



Proposed Code Change
State Form 41186R

RETURN TO:
INDIANA DEPARTMENT OF HOMELAND SECURITY
CODE SERVICES SECTION
302 W. Washington Street Room W246
Indianapolis, IN 46204

FOR OFFICE USE ONLY	
Received	3/15/10
Code	52.1.8-09

INSTRUCTIONS:

Only TYPED copy accepted.
(KEY- ~~Dashed line through material to be deleted~~, underline material to be added)
Use second sheet for any material requiring more space.

Code Title Indiana Residential Code		Edition 2009
Section number and title R1003.4 Seismic anchorage		Page 449
Proponent SW Indiana Builders and Building Officials	Title	
Address 2175 N Cullen Ave; Evansville, IN 47715 Center Complex; Room 310; Evansville, IN 47708		Phone 812-479-6026 812-436-7868
<input checked="" type="checkbox"/> Change to read as follows <input type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution PROPOSED CODE CHANGE (Check One)		
<p>Change Section R1003.4 to read as follows: Masonry and concrete chimneys and foundations in Seismic Design Category D0, D1 and D2 <u>C1</u> shall be anchored at each floor, ceiling or roof line more than 6 feet (1829 mm) above grade, except where constructed completely within the exterior walls. Anchorage shall conform to the requirements in Section R1003.4.1.</p>		
REASON		
<p>This is part of the Seismic Package for C1 in the 2005 InRC, and need to be continued.</p>		
REVIEW RECOMMENDATION		
Approve 18-0-0 3/16/10		
Disapprove		
Approve as amended		
Further Study		