



Proposed Code Change
State Form 41186R

RETURN TO:
INDIANA DEPARTMENT OF HOMELAND SECURITY
CODE SERVICES SECTION
302 W. Washington Street Room W246
Indianapolis, IN 46204

| FOR OFFICE USE ONLY | |
|---------------------|-----------|
| Received | 11/12/09 |
| Code | 52.326-09 |

INSTRUCTIONS:

Only TYPED copy accepted.
(KEY- Dashed line through material to be deleted, underline material to be added)
Use second sheet for any material requiring more space.

| | | |
|--|--------------------------------|-----------------------|
| Code Title Indiana Residential Code | | Edition 2009 |
| Table N1102.1.2 | | Page |
| Proponent William Fox / IBA | Title Code Committee Member | |
| Address 6125 W 29th Place, Speedway, IN. 46224 | | Phone 317-291-7575 |
| PROPOSED CODE CHANGE (Check One) | | |
| <input checked="" type="checkbox"/> Change to read as follows <input type="checkbox"/> Add to read as follows <input checked="" type="checkbox"/> Delete and substitute as follows <input checked="" type="checkbox"/> Delete without substitution | | |
| <p>Delete all Climate Zones in Table N1102.1.2 except Climate Zones 4 and 5. Delete the word MARINE from the Climate Zone column. Change the U factor from 0.060 to 0.057 in the Frame wall U-Facture column. Change footnote b to read as follows: When more than half the insulation is on the interior, the mass wall U-factors shall be a maximum 3.0 in zone 4 and the same factor in zone 5. Delete footnote c.</p> | | |
| Reason | | |
| These changes delete references to Climate Zones that do no pertain to Indiana and make the Ccode more convenient for the Indiana user. "Marine" does not apply to Indiana. (Footnote d is not listed in this Table in Chapter 4, Third printing of the 2009 IECC). The U factor change is to bring this Code into compliance with the 2009 IECC. | | |
| REVIEW RECOMMENDATION | | |
| Approve | | |
| Disapprove | | |
| Approve as amended | | |
| Further Study | | |