



PROPOSAL FOR CODE CHANGE

State Form 41186 (R3 / 5-10)



INSTRUCTIONS:

1. Only a **TYPED** copy will be accepted.
2. **Dashed-line through material to-be-deleted; underline or bold face material to be added.**
3. Use a second sheet for any material requiring more space.
4. Return this completed form to: Indiana Department of Homeland Security, Code Services, 402 West Washington Street, Room W246, Indianapolis, Indiana 46204.

FOR OFFICE USE ONLY		
Received 02/08/25 6:15 PM	Code	Proposal number 525

Code title Building Codes	Edition
Section number and title 907.5.2.3.1	Page number
Proponent Darrel Cross	Representing (<i>if applicable</i>) Fire Inspectors Association of Indiana
Address (number and street, city, state, and ZIP code) 135 S 9th St	Telephone number (317)557-8453

PROPOSED CODE CHANGE (check one)

Change to read as follows Add to read as follows Delete and substitute as follows Delete without substitution

Public Areas and Common Areas,++Buildings with fire rated separations++: Visible Alarm Notification appliances shall be provided in public areas and common areas ++and buildings with rated separations. Exceptions: Horizontal Assemblies

REASON STATEMENT AND FISCAL IMPACT

Coordination with IFC amendment - no fiscal impact

REVIEW RECOMMENDATION

Approve
Reject
Approve as amended
Further study