



Indiana Department of Homeland Security Fire and Building Safety Division

NOTICE OF VIOLATIONS AND ORDER TO CORRECT

Facility Name		Address	City	Zip		
Inspector Name		Inspection Date		ID No.		
	Code Requirement	Met	Not Met	N/A		
1.	FIREWORKS TENTS AND TEMPORARY STANDS					
2.	IC 22-11-14-4.5 Sec. 4.5(a) The tent shall not be larger than one thousand five hundred (1,500) square feet.					
3.	IC 22-11-14-4.5 Sec 4.5(b) There shall be only one (1) tent for each permit granted by the State Fire Marshal.					
4.	IC 22-11-14-4.5(c) The tent shall not be closer than one hundred (100) feet to a permanent structure.					
5.	IC 22-11-14-4.5 Sec 4.5(d) A vehicle shall not be parked closer than twenty (20) feet from the edge of the tent.					
6.	IC 22-11-14-4.5 Sec 4.5(e) The tent must be flame retardant.					
7.	IC 22-11-14-4.5 Sec. 4.5(g) Sales of fireworks shall not be made from the tent for more than forty-five (45) days in a year.					
8.	IC 22-11-14-4.5 Sec 4.5(h) The weight of consumer fireworks in a tent shall not exceed three thousand (3,000) gross pounds of consumer fireworks.					
9.	IC 22-11-14-7 Sec7(a) A retailer selling items referenced in section 8(a) of this chapter at one (1) or more temporary stands must obtain a fireworks permit, referred to in this section as a "permit", from the state fire marshal.					
10.	IC 22-11-14-7 Sec 7(d) The permit shall be posted by the retailer at the retail sales stand so it is easily seen by the public.					
11.	IC 22-11-14-7 Sec 7(g) Fireworks may not be sold at retail from a motor vehicle.					
12.	IC22-11-14-8 Sec 8(a) A person shall not sell at retail, offer for sale at retail, or deliver Section 8(a) fireworks to a person less than eighteen (18) years of age					
13.	IC 22-11-14-8 Sec 8(b) A retailer or wholesaler may sell consumer fireworks to a person at least eighteen (18) years of age.					
14.	IC 22-11-14-8 Sec 8(c) An individual who sells consumer fireworks must be at least eighteen (18) years of age.					
15.	IC 22-11-14-8 Sec 8(d) An individual who sells an item set forth in subsection 8(a) must be at least sixteen (16) years of age.					
16.	Sec. 2404.12 I.F.C. 2008 Edn. – Fire extinguishers shall be installed in tents and shall comply with Sec. 906 of the 2008 Indiana Fire Code.					
17.	Sec. 1028.2 I.F.C. 2008 Edn. – Exit doors shall be maintained free from obstructions or impediments to full instant use in the case of fire or other emergency.					
18.	Sec. 1028.5 I.F.C. 2008 Edn. – Furnishings, decorations or other objects shall not be placed so as to obstruct exits, access to exits or visibility of exits.					
19.	Sec. 1006.1 I.F.C. 2008 Edn. – Exit signs shall be illuminated and operational at all times that the structure is occupied.					
20.	Sec. 310 I.F.C. 2008 Edn. – No smoking signs shall be posted in each tent and temporary stand in which fireworks are sold, offered for sale or stored.					
21.	Sec. 308 I.F.C. 2008 Edn. – No open flame devices shall used in any tent or temporary stand in which fireworks are sold, offered for sale or stored.					



Indiana Department of Homeland Security Fire and Building Safety Division

22.	<u>Sec. 315 I.F.C. 2008 Edn.</u> – Combustible storage shall be at least 24 inches from the ceiling.			
23.	<u>Sec. 2404.17.1 I.F.C. 2008 Edn.</u> – Flammable-liquid-fueled equipment shall not be used in tents.			
24.	<u>Section 2404.15 I.F.C. 2008 Edn.</u> – Heating and cooking equipment shall comply with Section 2404.15.7 of the Indiana Fire Code.			
25.	<u>Sec. 2403.12.8 I.F.C. 2008 Edn.</u> – The required width of exits, aisles and passageways shall be maintained at all time to a public way. Guy wires, guy ropes and other support members shall not cross a means of egress at a height of less than 8 feet. The surface of means of egress shall be maintained in an approved manner.			

NOTES:

Please be advised that if you desire administrative review of this Order, you must file a written petition for review with the Fire Prevention and Building Safety Commission at 402 West Washington Street, Rm. W246, Indianapolis, IN 46204, identifying the violations for which you seek review no later than 18 days from the date of this Order unless such date is a Saturday, Sunday, legal holiday under state statute, or day that the Department of Homeland Security’s offices are closed during regular business hours, in which case the deadline would be the first day thereafter that is not a Saturday, Sunday, legal holiday under state statute, or day that the Department of Homeland Security's offices are closed during regular business hours. If you do so, your petition for review will be granted and an administrative proceeding will be conducted by an administrative law judge appointed by the Fire Prevention and Building Safety Commission. If you do not file a petition for review, this Order will be **FINAL** and you **MUST** comply with its requirements.

Please be further advised that you may request an opportunity to informally discuss this Order prior to filing a petition for review. Such informal discussion or a request therefore, does not extend the deadline for filing a petition for review and, therefore, any request for an informal discussion should be made promptly, preferably by telephone, upon receipt of this Order.

Authorized Fire Official’s Signature

Date

Received by

Date