

ADDENDUM NO. 1
TO
CONSTRUCTION DOCUMENTS

FOR PROJECT NO. **E030280**

DESCRIPTION: **Electrical Pedestal Improvements**

LOCATION: **West Campground-Turkey Run State Park**

FOR AGENCY: **Department of Natural Resources**

The information contained in this Addendum shall become a part of the basic plans and specifications the same as if originally incorporated therein. The original plans and specifications shall remain in their entirety, except as modified by this Addendum. The items herein shall supersede information in the specifications and on the plans.

ITEM#1: Plan Sheet "E-5", sheet 6 of 6.

- A. Revise CONDUCTOR SCHEDULE Circuit B-5 "to" column to read as follows: "Sites:214,215,216,217,& 218", was "225,224, & 223".
- B. Revise PANELBOARD-"C" SCHEDULE Circuit C-5 "pole/amps" to read "3P-200A", was "2P-200A".
- C. Revise PANELBOARD-"C" SCHEDULE "Panel Rating" to include "3-Pole", was interpreted to be "2-Pole" (single phase) without designation.

ITEM#2: Specifications: Section 01020 Allowances, Part 1 – General.

- A. Paragraph 1.01: REMEDIATION ALLOWANCE. Add subparagraph D to read: "If any portion of the allowance is not used during the project, that portion will revert to the owner and will not be included in the contractor's final payment."
- B. Add Paragraph "1.02: PRIMARY POWER ALLOWANCE:"
 - A. Contractor shall include an allowance of **\$14,000.00** in the Base Bid for providing primary single phase underground electrical service to locations "A", "B", "E", & "D", and three phase underground electrical service to location "C" under this contract. This amount shall be included as a separate item in the schedule of values adding up to the total bid price.

- B. This allowance is only for the amount to be paid to the electric utility for bringing primary power to the property, providing the transformer, and installation of same.
- C. The transformer shall be pad mounted and the service conductors buried underground.
- D. Any portion of the allowance not used for this purpose on this contract will revert to the owner and will not be included in the contractor's final payment.
- E. The costs associated with the installation of the secondary voltage service entrance conductors are not part of this allowance.

END OF ADDENDUM

State Form 21208R4

DAPW-118