



DETAIL OF COIL



BRIDGE GROUNDING

GENERAL NOTES

- ① 1800 mm approach to foundation shall be trenched.
2. Bottom of trench shall be graded so as to provided a smooth, uniform ramp to the entry sleeve of the foundation.
3. Each cable-duct shall have its own entry sleeve. There shall be at least two entry sleeves per footing.
4. Coil to be of #6 AWG copper approximately 4.5 m long.
5. Place felt between concrete and coil to prevent bonding.
6. Coil method of grounding may be used with precast foundation.


All dimensions are in mm unless otherwise specified.

INDIANA DEPARTMENT OF TRANSPORTATION

LIGHT FOUNDATION

SEPTEMBER 2000

STANDARD DRAWING NO. 807-LTFD-06



/s/ Anthony L. Uremovich 9-01-00
DESIGN STANDARDS ENGINEER DATE

/s/ Firooz Zandi 9-01-00
CHIEF HIGHWAY ENGINEER DATE

DESIGN STANDARDS ENGINEER