



**NOTES:**

1. Joints in coping shall be at 2 panel intervals and coincide approximately with a panel joint. Reinforcing steel shall be stopped 50 short of near side of each joint.
2. Front face of cast in place coping shall match the front face of precast coping when used in conjunction.

**CAST IN PLACE CONCRETE COPING**

**CAST IN PLACE CONCRETE COPING WITH PEDESTRIAN FENCE**

All dimensions are in mm unless otherwise specified

INDIANA DEPARTMENT OF TRANSPORTATION

**MSE WALL C - I - P COPING AND PEDESTRIAN FENCE DETAILS**

SEPTEMBER 2006

STANDARD DRAWING NO. 731-BRRW-02

/s/ Richard L. VanCleave 9-01-06  
DESIGN STANDARDS ENGINEER DATE

/s/ Richard K. Smutzer 9-01-06  
CHIEF HIGHWAY ENGINEER DATE

DESIGN STANDARDS ENGINEER