


SECTION A-A




SECTION A-A
Where Existing Subbase
must be removed

NOTES

- 1 See Stanard Drawing E 503-CCPJ-06 for joint seal details.
- Saw cuts and joint seal shall be omitted if PCCP is to be overlaid.

DOWEL BAR SIZES	
Pavement Thickness, D	Minimum Dowel Bar Diameter
Less than 9"	1"
9" through 12"	1 <mark>1</mark> "
Greater than 12"	1 <mark>1</mark> "



SECTION B-B

Source Sheet:

