

- Connection to Sewer
 - The property line must be within 300 feet of a sewer
 - Cannot exceed 150% of the cost of a new OSS installation
 - It would require approval from the Huntington City Engineer
- Number of soil borings/pits
 - Three borings are required (most scientists in the area already do 3)
 - Helps to ensure proper sizing of the absorption field
 - More borings can ensure the proper water absorption rate in the area where the absorption field is planned to be installed
 - Can help to ensure proper wastewater filtration is achieved
 - Pits are required over borings in areas of bedrock to ensure proper distance can be achieved
- Separation Distance
 - Increased separation distance to wells protects drinking water supplies in areas of the county underlain by bedrock.
 - Fractured bedrock could allow untreated wastewater to enter the water supply, and increasing the required separation distance to wells provides an extra layer of security.