

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 06/14/2023  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>155631</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>01</b>  B. WING _____		(X3) DATE SURVEY COMPLETED  <b>R</b> <b>06/13/2023</b>
NAME OF PROVIDER OR SUPPLIER  <b>WHITE RIVER LODGE</b>			STREET ADDRESS, CITY, STATE, ZIP CODE <b>3710 KENNY SIMPSON LN</b> <b>BEDFORD, IN 47421</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{E 000}	Initial Comments  A Post Survey Revisit (PSR) to the Emergency Preparedness Survey conducted on 05/04/23 was conducted by the Indiana Department of Health in accordance with 42 CFR 483.73.  Survey Date: 06/13/23  Facility Number: 001153 Provider Number: 155631 AIM Number: 200155900  At this PSR survey, White River Lodge was found in compliance with Emergency Preparedness Requirements for Medicare and Medicaid Participating Providers and Suppliers, 42 CFR 483.73.  The facility has a total capacity of 84 with 74 certified beds and 10 Assisted Living beds. The facility had a total census of 43 at the time of this visit. The entire facility was surveyed due to the lack of a 2 hour fire-rated separation between the Skilled Unit and the Assisted Living Unit.	{E 000}			
{K 000}	Quality Review conducted on 06/13/23 INITIAL COMMENTS  A Post Survey Revisit (PSR) to the Life Safety Code Recertification and State Licensure Survey conducted on 05/04/23 was conducted by the Indiana Department of Health in accordance with 42 CFR 483.90(a).  Survey Date: 06/13/23  Facility Number: 001153 Provider Number: 155631	{K 000}			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (\*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 06/14/2023  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>155631</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>01</b>  B. WING _____		(X3) DATE SURVEY COMPLETED  <b>R</b> <b>06/13/2023</b>
NAME OF PROVIDER OR SUPPLIER  <b>WHITE RIVER LODGE</b>			STREET ADDRESS, CITY, STATE, ZIP CODE <b>3710 KENNY SIMPSON LN</b> <b>BEDFORD, IN 47421</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{K 000}	<p>Continued From page 1 AIM Number: 200155900</p> <p>At this PSR survey, White River Lodge was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.90(a), Life Safety from Fire and the 2012 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2.</p> <p>This one story facility was determined to be of Type II (000) construction and was fully sprinklered. The facility has a fire alarm system with hard wired smoke detectors in the corridors, spaces open to the corridors, and all resident sleeping rooms. The facility has a total capacity of 84 with 74 certified beds and 10 Assisted Living beds. The facility had a total census of 43 at the time of this visit. The entire facility was surveyed due to the lack of a 2 hour fire-rated separation between the Skilled Unit and the Assisted Living Unit.</p> <p>All areas where the residents have customary access were sprinklered, and all areas providing facility services were sprinklered.</p> <p>Quality Review conducted on 06/13/23</p>	{K 000}			