

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  155822	X2) MULTIPLE CONSTRUCTION A. BUILDING -- _____ B. WING _____	X3) DATE SURVEY COMPLETED  05/28/2024
--	---	--	---

NAME OF PROVIDER OR SUPPLIER  CEDAR CREEK HEALTH CAMPUS	STREET ADDRESS, CITY, STATE, ZIP COD 18275 BURR STREET LOWELL, IN 46356
---	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIE (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
E 0000  Bldg. --	<p>An Emergency Preparedness Survey was conducted by the Indiana Department of Health in accordance with 42 CFR 483.73.</p> <p>Survey Date: 05/28/24</p> <p>Facility Number: 013144 Provider Number: 155822 AIM Number: 201246060</p> <p>At this Emergency Preparedness survey, Cedar Creek Health Campus was found in compliance with Emergency Preparedness Requirements for Medicare and Medicaid Participating Providers and Suppliers, 42 CFR 483.73</p> <p>The facility has 58 certified beds. At the time of the survey, the census was 55.</p> <p>Quality Review completed on 05/31/24</p>	E 0000	The submission of this plan of correction does not indicate an admission by Cedar Creek Health Campus that the findings and allegations contained herein are accurate, true representation of the quality of care provided, and living environment provided to the residents of Cedar Creek Health Campus. The facility recognizes its obligation to provide legally and medically necessary care and services to its residents in an economic and efficient manner. The facility hereby maintains it is in substantial compliance with the requirements of participation for skilled health care facilities. To this end, the plan of correction shall serve as the credible allegation of compliance with all state and federal requirements governing the management of this facility. It is thus submitted as a matter of statute only. The facility respectfully requests from the department a desk review for substantial compliance.	
K 0000  Bldg. 01	<p>A Life Safety Code Recertification and State Licensure Survey was conducted by the Indiana Department of Health in accordance with 42 CFR 483.90(a).</p>	K 0000	The submission of this plan of correction does not indicate an admission by Cedar Creek Health Campus that the findings and allegations contained herein are	

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE	TITLE	(X6) DATE
Shelly Dyek	Executive Director	06/20/2024

Any deficiency statement ending with an asterisk (\*) denotes a deficiency which the institution may be excused from correcting providing it is determined other safeguards provide sufficient protection to the patients. (see instructions.) Except for nursing homes, the findings stated above are disclosable following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosed days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  155822	X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		X3) DATE SURVEY COMPLETED  05/28/2024
NAME OF PROVIDER OR SUPPLIER  CEDAR CREEK HEALTH CAMPUS			STREET ADDRESS, CITY, STATE, ZIP CODE 18275 BURR STREET LOWELL, IN 46356		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 0363 SS=D Bldg. 01	<p>Survey Date: 05/28/24</p> <p>Facility Number: 013144 Provider Number: 155822 AIM Number: 201246060</p> <p>At this Life Safety Code survey, Cedar Creek Health Campus was not found in compliance with Requirements for Participation in Medicare, 42 CFR Subpart 483.90(a), Life Safety from Fire and the 2012 Edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies. and 410 IAC 16.2.</p> <p>The one story facility was determined to be of Type V (111) construction and fully sprinklered. The facility has a fire alarm system with hard wired smoke detection in corridors, in spaces open to the corridor and in resident rooms. The building is fully protected by a 150 kW natural gas powered generator. The facility has the capacity for 58 and a census of 55.</p> <p>All areas with customary resident access and providing facility services were sprinklered.</p> <p>Quality Review completed on 05/31/24</p> <p>NFPA 101 Corridor - Doors Corridor - Doors Doors protecting corridor openings in other than required enclosures of vertical openings, exits, or hazardous areas resist the passage of smoke and are made of 1 3/4 inch solid-bonded core wood or other material capable of resisting fire for at least 20 minutes. Doors in fully sprinklered smoke compartments are only required to resist the</p>		<p>accurate, true representation of the quality of care provided, and living environment provided to the residents of Cedar Creek Health Campus. The facility recognizes its obligation to provide legally and medically necessary care and services to its residents in an economic and efficient manner. The facility hereby maintains it is in substantial compliance with the requirements of participation for skilled health care facilities. To this end, the plan of correction shall serve as the credible allegation of compliance with all state and federal requirements governing the management of this facility. It is thus submitted as a matter of statute only. The facility respectfully requests from the department a desk review for substantial compliance.</p>		

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  155822	X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____	X3) DATE SURVEY COMPLETED  05/28/2024
--	---	--	---

NAME OF PROVIDER OR SUPPLIER  CEDAR CREEK HEALTH CAMPUS	STREET ADDRESS, CITY, STATE, ZIP COD 18275 BURR STREET LOWELL, IN 46356
---	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
	<p>passage of smoke. Corridor doors and doors to rooms containing flammable or combustible materials have positive latching hardware. Roller latches are prohibited by CMS regulation. These requirements do not apply to auxiliary spaces that do not contain flammable or combustible material.</p> <p>Clearance between bottom of door and floor covering is not exceeding 1 inch. Powered doors complying with 7.2.1.9 are permissible if provided with a device capable of keeping the door closed when a force of 5 lbf is applied. There is no impediment to the closing of the doors. Hold open devices that release when the door is pushed or pulled are permitted. Nonrated protective plates of unlimited height are permitted. Dutch doors meeting 19.3.6.3.6 are permitted. Door frames shall be labeled and made of steel or other materials in compliance with 8.3, unless the smoke compartment is sprinklered. Fixed fire window assemblies are allowed per 8.3. In sprinklered compartments there are no restrictions in area or fire resistance of glass or frames in window assemblies.</p> <p>19.3.6.3, 42 CFR Parts 403, 418, 460, 482, 483, and 485</p> <p>Show in REMARKS details of doors such as fire protection ratings, automatics closing devices, etc.</p> <p>Based on observation and interview, the facility failed to ensure 1 of 44 resident room corridor doors were provided with a means suitable for keeping the door closed, had no impediment to closing, latching and would resist the passage of smoke. This deficient practice could affect approximately 4 residents and staff.</p>	K 0363	1. No ill effects for potential residents/staff were noted. 2. Door to Resident room 304 was corrected on 5/28/24. 3. Plant Ops did a whole house check on all resident doors. 4. Plant Ops or designee will audit 5 doors 3x a week on different halls for 4	06/17/2024

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  155822	X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____	X3) DATE SURVEY COMPLETED  05/28/2024
--	---	--	---

NAME OF PROVIDER OR SUPPLIER  CEDAR CREEK HEALTH CAMPUS	STREET ADDRESS, CITY, STATE, ZIP COD 18275 BURR STREET LOWELL, IN 46356
---	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 0920 SS=D Bldg. 01	<p>Findings include:</p> <p>Based on observation with the Director of Plant Operations and Executive Director on 05/28/24 between 11:36 a.m. and 12:43 p.m., the corridor door to resident room 304 did not latch into the frame when tested three times. Based on interview at the time of observation, the Director of Plant Operations agreed that the door did positively latch and further acknowledged that the latching hardware would have to be adjusted.</p> <p>The finding was reviewed with the Director of Plant Operations and Executive Director during the exit conference.</p> <p>3.1-19(b)</p> <p>NFPA 101 Electrical Equipment - Power Cords and Extens Electrical Equipment - Power Cords and Extension Cords Power strips in a patient care vicinity are only used for components of movable patient-care-related electrical equipment (PCREE) assemblies that have been assembled by qualified personnel and meet the conditions of 10.2.3.6. Power strips in the patient care vicinity may not be used for non-PCREE (e.g., personal electronics), except in long-term care resident rooms that do not use PCREE. Power strips for PCREE meet UL 1363A or UL 60601-1. Power strips for non-PCREE in the patient care rooms (outside of vicinity) meet UL 1363. In non-patient care rooms, power strips meet other UL standards. All power strips are used with general precautions. Extension cords are not used as a substitute for fixed</p>		<p>weeks. then 10 doors 2x a week on different halls for 4 weeks, then 10 doors 1x a week on different halls for 4 months or until compliance of 100% is reached . Plant Ops will bring audit sheets to monthly QAPI.</p>	

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  155822	X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____	X3) DATE SURVEY COMPLETED  05/28/2024
--	---	--	---

NAME OF PROVIDER OR SUPPLIER  CEDAR CREEK HEALTH CAMPUS	STREET ADDRESS, CITY, STATE, ZIP COD 18275 BURR STREET LOWELL, IN 46356
---	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
	<p>wiring of a structure. Extension cords used temporarily are removed immediately upon completion of the purpose for which it was installed and meets the conditions of 10.2.4. 10.2.3.6 (NFPA 99), 10.2.4 (NFPA 99), 400-8 (NFPA 70), 590.3(D) (NFPA 70), TIA 12-5</p> <p>Based on observation and interview, the facility failed to ensure 1 of 1 flexible cords were installed properly and used in a safe manor. NFPA 99, Section 10.2.4.2 states adapters and extension cords meeting the requirements of 10.2.4.2.1 through 10.2.4.2.3 shall be permitted. Section 10.2.4.2.3 states the cabling shall comply with 10.2.3. Section 10.2.3.5.1 states cord strain relief shall be provided at the attachment of the power cord to the appliance so that mechanical stress, either pull, twist, or bend, is not transmitted to internal connections. This deficient practice could affect approximately 3 staff.</p> <p>Findings include:</p> <p>Based on observation with the Director of Plant Operation on 05/28/24 between 11:36 a.m. and 12:43 p.m., in the Business Office near the healthcare entrance, there was a power strip located under the front desk, used to power computer equipment, but it was dangling from the connected power cords. This condition could put stress on the power cord causing damage to the power cord. Based on interview at the time of observation, the Director of Plant Operations confirmed that the power strip was dangling and would have to be secured.</p> <p>This finding was reviewed with the Director of Plant Operations and Executive Director during the exit conference.</p> <p>3.1-19(b)</p>	K 0920	<p>1. No ill effects for potential residents/staff were noted. 2. Power Strip was corrected on 5/28/24 by attaching to the wall. 3. Plant Ops did provide education to all staff on the correct use of power strips. 4. Plant Ops or designee will audit all offices 3x a week for 4 weeks. then 2x a week for 4 weeks, then 1x a week for 4 months or until compliance of 100% is reached . Plant Ops will bring audit sheets to monthly QAPI.</p>	06/19/2024

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 06/21/2024  
FORM APPROVED  
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER  155822	X2) MULTIPLE CONSTRUCTION A. BUILDING <u>01</u> B. WING _____		X3) DATE SURVEY COMPLETED 05/28/2024
NAME OF PROVIDER OR SUPPLIER  CEDAR CREEK HEALTH CAMPUS			STREET ADDRESS, CITY, STATE, ZIP COD 18275 BURR STREET LOWELL, IN 46356		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIE (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	