

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/04/2024  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>155783</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>02</b>  B. WING _____		(X3) DATE SURVEY COMPLETED  <b>R</b> <b>10/31/2024</b>
NAME OF PROVIDER OR SUPPLIER  <b>GREENLEAF HEALTH CAMPUS</b>			STREET ADDRESS, CITY, STATE, ZIP CODE <b>1201 E BEARDSLEY AVE</b> <b>ELKHART, IN 46514</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{E 000}	Initial Comments  A Post Survey Revisit (PSR) to the Emergency Preparedness Survey that exited on 09/26/24 was conducted by the Indiana Department of Health in accordance with 42 CFR 483.73.  Survey Date: 10/31/24  Facility Number: 002661 Provider Number: 155783 AIM Number: 201056540  At this PSR Survey, Greenleaf Health Campus was found in compliance with Emergency Preparedness Requirements for Medicare and Medicaid Participating Providers and Suppliers, 42 CFR 483.475.  The facility has 60 certified beds. At the time of the survey, the census was 54.	{E 000}			
{K 000}	Quality Review completed on 11/01/24 INITIAL COMMENTS  A Post Survey Revisit (PSR) to the Life Safety Code Recertification and State Licensure Survey that exited on 09/26/24 was conducted by the Indiana Department of Health in accordance 42 CFR Subpart 483.90(a).  Survey Date: 10/31/24  Facility Number: 002661 Provider Number: 155783 AIM Number: 201056540  At this PSR, Greenleaf Health Campus was found in compliance with Requirements for Participation	{K 000}			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (\*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/04/2024  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>155783</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>02</b>  B. WING _____		(X3) DATE SURVEY COMPLETED  <b>R</b> <b>10/31/2024</b>
NAME OF PROVIDER OR SUPPLIER  <b>GREENLEAF HEALTH CAMPUS</b>			STREET ADDRESS, CITY, STATE, ZIP CODE <b>1201 E BEARDSLEY AVE</b> <b>ELKHART, IN 46514</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{K 000}	<p>Continued From page 1</p> <p>in Medicare/Medicaid, 42 CFR Subpart 483.90(a), Life Safety from Fire and the 2012 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC) Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2.</p> <p>This one-story facility was determined to be of Type V (111) construction and was fully sprinklered. The building was constructed in 2010, is adjacent to an assisted living unit and separated by a Fire Wall with a two-hour Fire Resistive Rating. The facility has a fire alarm system with smoke detection in corridors, in areas open to the corridors and hard-wired smoke detectors in the resident rooms. The facility is partially protected by a 150 kW Natural Gas Generator.</p> <p>The facility has a capacity of 60 beds and had a census of 54 at the time of this survey.</p> <p>Quality Review completed on 11/01/24</p>	{K 000}			