

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 06/11/2025
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155758	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02 B. WING _____		(X3) DATE SURVEY COMPLETED R 06/05/2025
NAME OF PROVIDER OR SUPPLIER ASBURY TOWERS HEALTH CARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 102 W POPLAR ST GREENCASTLE, IN 46135		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{K 000}	<p>INITIAL COMMENTS</p> <p>A Post Survey Revisit (PSR) to the Life Safety Code Recertification and State Licensure Survey conducted on 04/23/25 was conducted by the Indiana Department of Health in accordance with 42 CFR 483.90(a).</p> <p>Survey Date: 06/05/25</p> <p>Facility Number: 001120 Provider Number: 155758 AIM Number: 200525120</p> <p>At this PSR survey, Asbury Towers Health Care Center was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.70(a), Life Safety from Fire, and the 2012 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2.</p> <p>This facility was located on the ground and first floors of a four-story building and surveyed as one building since the construction dates of the original building and an addition were built prior to March 1, 2003. The facility was determined to be of Type II (222) construction and was fully sprinklered. The facility identifies the ground floor as HCC Comprehensive Care Unit 1 and the first floor as Comprehensive Care Unit II. The facility also has a partial basement. The facility has a fire alarm system with smoke detection in the corridors and spaces open to the corridors. All resident rooms have battery powered smoke detection except rooms 9 through 22 on the south wing of the ground floor. Hard wired smoke detectors in resident rooms 117, 118, and rooms</p>	{K 000}			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 06/11/2025
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155758	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02 B. WING _____		(X3) DATE SURVEY COMPLETED R 06/05/2025
NAME OF PROVIDER OR SUPPLIER ASBURY TOWERS HEALTH CARE CENTER		STREET ADDRESS, CITY, STATE, ZIP CODE 102 W POPLAR ST GREENCASTLE, IN 46135		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
{K 000}	Continued From page 1 9 through 22 alarm at the smoke detector only. The facility has a capacity of 48 and had a census of 24 at the time of this survey. All areas where the residents have customary access were sprinklered and all areas which provide facility services were sprinklered except for the Electrical room on North wing hall on the ground floor. Quality Review completed on 06/09/25	{K 000}		