

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 09/18/2023
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155789	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01, 02 B. WING _____		(X3) DATE SURVEY COMPLETED R 09/14/2023
NAME OF PROVIDER OR SUPPLIER RIDGEWOOD HEALTH CAMPUS			STREET ADDRESS, CITY, STATE, ZIP CODE 181 CAMPUS DR LAWRENCEBURG, IN 47025		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{K 000}	<p>INITIAL COMMENTS</p> <p>A Post Survey Revisit (PSR) to the Life Safety Code Recertification and State Licensure Survey conducted on 07/27/23 was conducted by the Indiana Department of Health in accordance with 42 CFR 483.90(a).</p> <p>Survey Date: 09/14/23</p> <p>Facility Number: 012523 Provider Number: 155789 AIM Number: 201027870</p> <p>At this PSR survey, Ridgewood Health Campus was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.90(a), Life Safety from Fire and the 2012 Edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2.</p> <p>Ridgewood Health Campus consists of two separate buildings. The Main Campus, Building 01, is a one story building and was determined to be of Type V (111) construction and fully sprinklered. The Legacy Building, Building 02, located to the southeast of the Main Campus building was determined to be of Type V (111) construction and fully sprinklered. Both buildings have a fire alarm system with smoke detection in the corridors, in all areas open to the corridor and has smoke detectors hard wired to the fire alarm system in all resident sleeping rooms. The facility has a capacity of 71 and had a census of 64 at the time of this survey.</p> <p>All areas where residents have customary access</p>	{K 000}			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 09/18/2023
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155789	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01, 02 B. WING _____		(X3) DATE SURVEY COMPLETED R 09/14/2023
NAME OF PROVIDER OR SUPPLIER RIDGEWOOD HEALTH CAMPUS			STREET ADDRESS, CITY, STATE, ZIP CODE 181 CAMPUS DR LAWRENCEBURG, IN 47025		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{K 000}	Continued From page 1 were sprinklered and all areas providing facility services were sprinklered.	{K 000}			
{K 000}	Quality Review completed on 09/15/23 INITIAL COMMENTS	{K 000}			