

UNVENTED GAS SPACE HEATER INSPECTION FORM

Client Name: _____ Agency: _____

Address: _____ Contact: _____

DOE will allow secondary unvented units that conform to the safety standards of ANSI Z21.11.2 to remain as back-up heat sources. DOE is allowing this flexibility primarily to provide low-income clients an emergency back-up source of heat in the event of electrical power outage.

Secondary unvented units that do not meet ANSI Z21.11.2 must be removed and properly disposed of prior to weatherization but may remain until a replacement heating system is in place.

Make: _____ Model #: _____ Serial #: _____

Please note all questions must be true, or the unvented space heater must be removed or decommissioned

The home is not a mobile home ☐ TRUE ☐ FALSE Type of home _____

The unit is in working order ☐ TRUE ☐ FALSE _____

The unit does not require electricity ☐ TRUE ☐ FALSE _____

Space heater does not exceed 40,000 BTU's ☐ TRUE ☐ FALSE BTU of UNIT _____

It is not located in bedrooms, bathrooms, or storage area ☐ TRUE ☐ FALSE Location _____

Does not obtain combustion air from bedrooms, bathrooms, or storage area. ☐ TRUE ☐ FALSE Combustion from _____

Space heater has an oxygen-depletion sensing safety shut off system. ☐ TRUE ☐ FALSE _____

C/O did not exceed 200 PPM **AIR FREE** when measured 6 to 9 inches ☐ TRUE ☐ FALSE Ambient before/After
above the unvented space heater burner(s) CO **AIR FREE** ppm _____

The heater zone has smoke and carbon monoxide alarm(s) ☐ TRUE ☐ FALSE _____

The unvented space heater ☐ PASSED ☐ FAILED DATE: _____

If the unvented space heater fails inspection, removal of the unit or deferral is required. Inspector's Signature: _____

FAILED	I understand that the unvented space heater failed inspection and must be removed for weatherization to continue.			
	I will allow the space heater to be removed. Initial here: _____	I will NOT allow the space heater to be removed. Initial here: _____	DATE: _____	Client's Signature _____

PASSED	Client understands the unvented space heater is for emergency back-up only.		☐ TRUE ☒ FALSE	Client Initials _____
	Client understands to leave a door or window open during use of the space heater.		☐ TRUE ☐ FALSE	Client Initials _____
	I _____ agree to the outlined safety concerns and operational precautions when this unvented space heater is used, including opening a window or exterior door. I also understand by keeping this unvented space heater all liability for any moisture issues; resulting from the un-vented gas products venting directly into my home, fire, health or even death of occupant(s) will be solely my responsibility and will not hold any employee, or affiliate of this agency liable.			
	I understand and will comply with the above statement.			
Client's Signature _____		Date: _____		