

**MANUAL FOR FREQUENCY OF
SAMPLING AND TESTING
AND
BASIS FOR USE OF MATERIALS**



**INDIANA DEPARTMENT OF TRANSPORTATION
DIVISION OF MATERIALS AND TESTS**

REVISED JANUARY 2021

MANUAL FOR FREQUENCY OF SAMPLING AND TESTING AND BASIS FOR USE OF MATERIALS

GENERAL

Please note that “attach Buy America certification(s) in SM” (Acceptance Template SM1004) has been added to several items in this update. If Buy America is unknowingly omitted on an item that requires it, then it shall automatically become a requirement. The Department Standard Specifications, Section 106.02, states that the minimum required number of samples and tests will be as set out in the Frequency Manual. This edition of the Frequency Manual was prepared to make the frequency of sampling and testing conform to the requirements of the 23 Code of Federal Regulations (CFR) 637 Subpart B.

The schedules and instructions supersede all those previously issued and are effective upon receipt for all new contracts, and for all uncompleted work on existing contracts, unless there is a conflict with Special Provisions or Specifications.

The Frequency Manual is a tabulation of various items of materials and tests normally used in the construction and maintenance of highways and bridges. The manual specifies the minimum schedule necessary to satisfy the requirements for acceptance samples and tests for each item. The location (i.e. job site, source, mixing plant etc.) from which samples are to be taken or tests conducted is also specified for each item. The Department requires that samples be taken or tests conducted at these specified locations; however, occasional situations may occur that do not permit this procedure. When these occasions occur, the District Testing Engineer is required to determine if an alternate location is desirable. Samples are required to be taken and tests conducted as soon as possible after the material becomes available. Each sample is required to represent no more than the quantities listed by the Job Control Frequency of this manual. The frequency of samples or tests applies to quantities shown or fractions thereof.

Many of the items listed allow small quantities of the material to be accepted without samples or tests. When this procedure is permitted, the quantities are specified as approximate amounts.

The frequencies herein are the minimum required. The PE/PS always has the right and responsibility to have a questionable product re-tested.

COLUMN FORMAT EXPLANATION

Specification Reference

The Department Standard Specification references are provided as a convenience for research of additional material requirements.

Item

The current edition of the Department Standard of Specifications will govern over any material listed in this manual. All items listed in the Standard Specifications, which require acceptance samples and tests, are listed. Items either added to or deleted from the previous manual reflect changes in the Standard Specifications. Instructions in parentheses provide additional information or explanation.

Job Control Location, Job Control Notes, Job Control Frequency, and Acceptance Templates

The Job Control Location, Job Control Notes, and Job Control Frequency address the location and frequency for all sampling and testing for approval for incorporation of material into the contract. Sampling and testing is conducted by Qualified Technicians; however, out-of-state consulting firms and other State DOT's also conduct sampling duties for the Department. The person responsible for acceptance samples and tests is not specified in this manual. Any material received at the job-site that has not been approved is required to be sampled, tested, and approved prior to use. Questionable materials that have been approved should be resampled and tested for verification. Also, material accepted by visual inspection is required to be checked upon installation into the contract.

Terms used in these columns are explained as follows:

- A. No Sample ID Required (Visual examination, dimensional check, where applicable, and a knowledge of past performance) -- this type of approval is given by the PE/PS on the basis of their own knowledge of the source of material or advice by other Department personnel. Sources will be considered acceptable provided the materials and supplies are the required quality.
- B. Approval on the basis of certification -- for approval by certification, no test sample is required
- C. Verification sampling -- this is a sample taken at random intervals for confirmation of quality and conformance
- D. Approval Number -- a letter followed by a six-digit number that indicates the material has been tested and at a given period in time was approved for use
- E. Approved Lot or Batch Number -- For materials that are pre-tested and stocked by material sources, the PE/PS is required to check the Office of Materials Management Pre-Approved Materials List for material, lot or batch number, and quantity delivered. If the material has been pre-tested and approved, the material is allowed for immediate use. The approval number will be entered into SiteManager.

- F. SiteManager Sample ID Number -- A laboratory testing report twelve-digit sequence number which will govern over all other basis of approval

- G. Type A, B, C, D, or Other Certifications -- When required, the PE/PS will have these documents before the material may be incorporated into the contract. The Certifications are required to be in accordance with the Standard Specifications, Section 916. Type A Certifications are to be scanned into SiteManager and attached to the Sample Record. The original certification will be placed in the project files. Type B, C, D, and mill Certifications, external documents, and other Certifications will also be placed in the project files.

ALPHABETICAL INDEX

<u>ITEM</u>	<u>REF. NO.</u>
ADMIXTURES	
Air Entraining	12
Type A - Water Reducer	12
Type B – Retarder	12
Type C – Accelerator	12
Type D - Water Reducer and Retarder	12
Type E - Water Reducer and Accelerator	12
Type F - High Range Water Reducer	12
Type G - High Range Water Reducer and Retarder	12
Latex Modifier	12
AGGREGATE	
Aggregate for Underdrains, Seal Coats, Riprap, and Miscellaneous Uses	48
Coarse Aggregates for Stormwater Management	48
B Borrow	22
Structure Backfill	22
Hot Mix Asphalt (including dolomites)	2
Compacted Aggregate Base, Shoulder, and Surface	23
Concrete	8
Subbase	24
AGRICULTURAL LIMESTONE	38
ANCHOR BOLTS	
Guard Rail	34
Anchor Systems	16
Chemical Anchor Systems	16
ASPHALT MATERIALS	
Paving Grades	1
Non-Paving Grades	1, 72
BARRICADES - STANDARD	98
BEARING PADS - ELASTOMERIC (BRIDGE)	6
BENCH MARK POSTS - CONCRETE	76
BENT TIE BARS	16
BLOCKS	
Concrete	74
Modular Concrete	60

<u>ITEM</u>	<u>REF. NO.</u>
BOLTS, NUTS, AND WASHERS	
High Strength.....	100
Other Than High Strength.....	101
BONDING AGENT - FOR GROUT FINISH.....	21
BRICK - CLAY OR CONCRETE	74
BRIDGE DECK DRAIN SYSTEM	127
BRIDGE RAILING AND ACCESSORIES.....	34
BRONZE ALLOY PLATES	50
BRONZE CASTINGS	105
CALCIUM CHLORIDE.....	52
CARBON AND ALLOY STEEL FORGINGS AND CARBON STEEL SHAFTINGS	103
CASTINGS - IRON AND STEEL	104
CELLULAR CONCRETE FILL	111
CELLULAR CONCRETE GROUT.....	112
CEMENT	
Bagged	10
Bulk.....	10
COLD MIX ASPHALT	2
COMPOST.....	39
CONCRETE	
Admixtures.....	12
Aggregates	8
Air Test	15
Bagged	11
Cement	9, 10
Concrete (Including PCCP Profilograph)	15
Compressive Strength.....	15
Flexural Strength.....	15
Fly Ash.....	9
Pavements (Including Latex Modified Overlays).....	15
Structures	15
Silica Fume Modified Concrete Overlay	15

<u>ITEM</u>	<u>REF. NO.</u>
Reinforcing Steel (Including Synthetic Fibers)	16
Slump Test	15
Water-Cement Ratio	15
Yield Test.....	15
Concrete Patching Materials	128
 COPPER ALLOY PLATES	 50
 COPPER FLASHING.....	 49
 CRACK AND JOINT FILLER/SEALANT	
Hot Applied Joint Sealing Compound	17
Preformed Elastomeric Joint Seals	17
Preformed Elastomeric Joint Seal Lubricant, Adhesive, and Backer Rod	17
Preformed Joint Filler for Concrete	17
Single Component Low Modulus	17
Sealer/Healer (Latex Overlays).....	109
 CURB - PRECAST CONCRETE.....	 76
 CURING MATERIALS	
Concrete Sealers, Proprietary.....	13
Liquid Membrane Curing Materials	13
 DECKFORMS – PERMANENT.....	 102
 DELINEATOR POSTS	
Metal	81
Plastic.....	81
 DETECTABLE WARNING SURFACES	 113
 DELINEATORS	
Acrylic Plastic	91
Barrier.....	93
Reflective Sheeting.....	92
 DRAIN TILE-CONCRETE.....	 61
 EMBANKMENT	
Strength or Density	25
Subgrade Treatment	26
 EPOXY PENETRATING SEALERS	 18
 EPOXY - RESIN BASE SYSTEM OR ADHESIVE FOR BONDING PLASTIC CONCRETE TO HARDENED CONCRETE	 20

<u>ITEM</u>	<u>REF. NO.</u>
FENCE	
Fence Fabric, Posts, Gates, Accessories	27
FERTILIZER (COMPOST).....	39
FLASHING ARROW SIGN.....	97
FLOWABLE BACKFILL	110
FLY ASH	9
GABIONS AND REVET MATTRESS	124
GATES - ALUMINUM OR STEEL	27
GEOSYNTHETICS	
Geocell Confining System	55
Geogrid	55
Geomembrane	55
Geotextile (For Riprap, Underdrains, Pavement & Subgrade).....	55
Silt Fence	55
GLASS SPHERES (BEADS).....	94
GRADE RINGS (OTHER THAN PRECAST CONCRETE).....	121
GRATED BOX END SECTIONS.....	64
GROUT	
Cellular Concrete	112
Non-Shrink.....	108
GUARD RAIL AND ACCESSORIES	
Impact and Truck Mounted Attenuators.....	36
Steel Bridge Railing Components.....	34
Guard Rail End Treatments	35
Sawn Timber Posts and Blockouts (All Uses).....	33
Guardrail (see REF 32 Job Control Notes).....	32
HANDHOLES	89
HERBICIDES.....	45
HIGH DENSITY BEARING STRIP.....	119
HIGHWAY ILLUMINATING MATERIALS.....	83, 118

ITEM

REF. NO.

HOT MIX ASPHALT
Mixture, Acceptance Testing and HMA Profilograph.....2
Density3

HYDRATED LIME, QUICKLIME AND LIME BYPRODUCT.....53

JOINT - BRIDGE (EXPANSION).....7

JOINT – FLEXIBLE FOAM EXPANSION JOINT134

JOINT – HOT MIX ASPHALT17

JOINT - PAVEMENT (CONTRACTION)16

JOINT and CRACK FILLER17

JOINT SYSTEMS – ELASTOMERIC17

LATEX MODIFIED OVERLAYS.....15

LEAD – SHEET106

LIGHTS - WARNING, CONSTRUCTION (FLASHING)86

LUMBER - UNTREATED OR TREATED.....46, 47

MAIL BOX ASSEMBLIES54

MANHOLE STEPS59, 68

MEDIAN BARRIERS (PERMANENT) - PRECAST CONCRETE.....78

TEMPORARY TRAFFIC BARRIERS – PRECAST CONCRETE-----79

TYPE 2 TEMP. TRAFFIC BARRIERS – FHWA APPROVED, NOT PRECAST CONC.--79

MICROSURFACING.....114

MONUMENTS – CONCRETE.....76

MORTAR MIX – BAGGED11

MULCHING MATERIAL – MOISTURE.....41

OVERHEAD SIGN STRUCTURES.....82

PARKING LOT BARRIERS – CONCRETE76

ITEM

REF. NO.

PAVEMENT STRIPING

Traffic Paint94
Thermoplastic and Preformed Plastic94
Marking Tape.....94
Glass Spheres (Beads)..... 94

PAVEMENT MARKERS

Snowplowable Raised Pavement Markers 95
Temporary Raised Pavement Markers..... 96

PILES

Steel H, Steel Encased Concrete, and Steel Sheet4
Wood - Treated and Untreated.....5

PIPE - CONCRETE OR CLAY AND ACCESSORIES

Asphaltic Mastic Pipe Joint66
Clay Pipe.....116
Concrete Pipe57
Reinforcing Steel for Concrete Pipe57
Precast Concrete End Section58
Precast Concrete Manholes, Inlets, Catch Basins, and Grade Rings59
Rubber Type Gaskets (Ring)65
Joint Membrane System for Precast Concrete Box Culverts.....67

PIPE – SEWER.....62

PIPE - CAST IRON CULVERT.....69

PIPE - CAST IRON SOIL & FIBERGLASS (FOR BRIDGE DRAINS).....73

PIPE – STEEL73

PIPE - STEEL (DRAIN).....73

PIPE - METAL AND ACCESSORIES

Asphalt Material for Pipe.....72
Corrugated Metal Culvert Pipe, Pipe Arches, and Underdrains70
Metal End Sections71
Structural Plate Pipe and Pipe Arches73

PIPE – PLASTIC63

PIPE LINERS

Thermoplastic Liner Pipe.....63
Cured-in-Place Liner.....129

PLANTS (LANDSCAPING).....43

<u>ITEM</u>	<u>REF. NO.</u>
PNEUMATICALLY PLACED MORTAR	130
POLES	
Signs and Lighting	81
POLYMERIC CONCRETE BRIDGE DECK OVERLAY	122
PORTABLE CHANGEABLE MESSAGE SIGNS (Solar-Powered)	97
POSTS AND BRACES - METAL	
Delineator Posts	81
Guard Rail Posts	32
Signs and Lighting	81
PRECAST CONCRETE ITEMS	
Bench Mark Posts	76
Box Culvert and Three-Sided Culvert Sections	59
Bricks and Blocks	74
Cable Markers	76
Catch Basins	59
Curb	76
End Sections	58
Grated Box End Sections	64
Handholes	89
Inlets	59
Mechanically Stabilized Earth Retaining Walls	22, 60
Median Barriers	78, 79
Miscellaneous Items	77
Monuments	76
Parking Barriers	76
Right-Of-Way Markers	76
Riprap	75
Structural Members	80
PREPARATION OF FOUNDATION: SPREAD FOOTING ON ROCK	131
PROOFROLLING	133
PROPRIETARY PORTLAND CEMENT CONCRETE SEALER	19
REINFORCING STEEL	
Anchor Systems	16
Bars - Plain or Epoxy Coated	16
Bar Mats	16
Bar Splicers	16
Bent Tie Bars and Tie Bar Assemblies	16
Dowels	16

<u>ITEM</u>	<u>REF. NO.</u>
Reinforcing Steel for Concrete Pipe	57
Spiral	16
Welded Wire Reinforcement	16
 ROADSIDE DEVELOPMENT MATERIALS - MISC.....	 44
 ROADWAY DRAIN CASTING EXTENSION.....	 126
 SEALER/HEALER (LATEX OVERLAYS)	 109
 SEED.....	 40
 SERVICE POINT	 125
 SIGNAL - TRAFFIC	
Component Materials and Equipment	88
Conduit.....	118
Controller, Cabinet, and Interconnect Equip.	87
Handhole Ring and Cover.....	90
Handhole	89
Pedestrian Push Button	87
Fixed Temporary Signal	87
Portable Temporary Signal	87
 SIGNS	
Construction.....	85
Traffic	84
 SILICA SAND.....	 18
 SOD.....	 42
 SODIUM CHLORIDE.....	 52
 SOIL – TOPSOIL AND PLANT GROWTH LAYER.....	 37
 SOIL DRYING OR SUBGRADE FOUNDATIONS	 132
 SOUND BARRIER SYSTEMS	 123
 STEEL FORGINGS AND STEEL SHAFTINGS.....	 103
 STRUCTURAL MEMBERS	
Precast/Prestressed Concrete	80
Steel.....	99
 STRUCTURAL PLATE PIPE, PIPE ARCHES, AND ARCHES	 73
 STRUCTURAL STEEL COATINGS	 56

<u>ITEM</u>	<u>REF. NO.</u>
STUD SHEAR CONNECTORS	107
SUBBASE.....	24
SUBGRADE TREATMENT.....	26
THREADED TIE BAR ASSEMBLIES	16
TURBIDITY CURTAIN – TEMPORARY.....	120
ULTRATHIN BONDED WEARING COURSE	115
WATER	51
WATERPROOFING MATERIALS	
Asphalt for Waterproofing.....	14
Glass Fiber Mat.....	14
Treated Cotton Fabric	14
Woven Glass Fabric.....	14
ZINC – SHEET.....	106

REF	SUB REF.	SPEC REFERENCE	ITEM	JOB CONTROL LOCATION	JOB CONTROL NOTES	JOB CONTROL FREQUENCY	ACCEPTANCE TEMPLATES
1	01 of 02	902.01a 581 ITM 583	ITM ASPHALT MATERIALS	HMA PLANT	PAVING GRADES. Two verification samples per year per certified plant per grade.	Certification - Type A shall be maintained at the certified plant per ITM 583.	No Sample ID Required (for Type A Cert) SM9015 (Verification by INDOT Testing)
1	02 of 02	902.01b through 902.01e	ASPHALT MATERIALS	POINT OF DELIVERY	NON-PAVING GRADES. Emulsions (b), Cutbacks (c), Utility Asphalt (d), Pipe Coating (e)	Certification-Type A Material is required to be sampled and tested by supplier every 14 days in storage and every 14 days after delivery of material.	SM9003
2	01 of 11	401.05	QC/QA-HMA	JOBSITE	Schedule to apply to each type of mixture.	Binder Content Bulk Specific Gravity Maximum Specific Gravity Gradation 1 each per subplot for ≥300 ton, per CLN.	IT586 or IT571 T166 T209 T30
2	02 of 11	401.05	QC/QA-HMA	JOBSITE	Schedule to apply to each type of mixture.	Certification-Type D for <300 ton, per CLN	SM9003
2	03 of 11	410.05	SMA	JOBSITE	Schedule to apply to surface course only.	Binder Content Gradation 1 each per subplot.	IT586 or IT571 T30
2	04 of 11	401.05 402.04	QC/QA-HMA	PLANT, SOURCE	DOLOMITE. One verification sample per year per plant where Dolomite is used.	One verification sample per year per plant where Dolomite is used.	IT205
2	05 of 11	ITM 583	HMA	MIXING PLANT	<i>PLANT PRODUCTION PER DMF.</i> Schedule to apply to each type of mixture after the first 250 ton of mix for the season is produced.	For Base and Intermediate a minimum of one sample for 1st 250 ton and a minimum of one sample for each 1000 ton thereafter. For Surface a minimum of one sample for 1st 250 ton and a minimum of one sample for each 600 ton thereafter. Frequency per Producer QCP.	No Sample ID Required for Contractor Acceptance
2	06 of 11	402.04 402.07 402.09 ITM 583	HMA	JOBSITE	<i>FOR CONTRACT PER DMF.</i> Contractor Acceptance Testing per ITM 583. A certification reflecting the test results from the latest producer sample shall be provided with the 1st delivery per contract per DMF per day.	<i>Certification-Type D. For Base and Intermediate: Minimum one certification for each 1000 tons. For Surface: Minimum one certification for each 600 tons.</i>	SM9003
2	07 of 11	403.05	CMA	MIXING PLANT	Schedule to apply to each type of mixture.	Certification-Type D	SM9003
2	08 of 11	307 308	FULL DEPTH RECLAMATION	JOBSITE	FDR Cement FDR Asphalt Emulsion	Certification Type D. 1 Per Day of Production	SM 9003/ITM 804
2	09 of 11	416 417	COLD RECYCLING	JOBSITE	Cold In Place Cold Central Plant	Certification Type D. 1 Per Day of Production	SM 9003/ITM 804
2	10 of 11	306.04 306.05 306.07	ROADWAY MILLING	JOBSITE	Scarification Profile/Cross-Slope Specified Depth	Macrotexture, 1 per day minimum (Testing by contractor)	ITM 812-No Sample ID Required

2	11 of 11	401.18(a) and ITM 912, Sec 5.0	PROFILOGRAPH, HMA	JOBSITE	For Contracts which include the Profilograph, HMA pay item. The profilograph shall be calibrated prior to use for both horizontal and vertical scales once each day on each contract.	Profilograph Verification (Machine Certification ID & Machine Operator).	IT912
3	01 of 02	401.16 410.16	QC/QA-HMA and SMA (DENSITY-MAINLINE)	JOBSITE	For each type of mixture.	Two cores required for each subplot of mainline mixture.	T166
3	02 of 02	401.16	QC/QA-HMA (DENSITY-SHOULDERS)	JOBSITE	For each type of mixture except for the first 385 lb/sys over existing shoulders.	Two cores required for each subplot of shoulder mixture.	T166
4	01 of 04	915.01 or 915.02 or 910.21	STEEL PILES	JOBSITE	UNCOATED STEEL H PILES, STEEL ENCASED CONCRETE PILES AND STEEL SHEET PILES.	External Document-Mill Certification Certification (shoes and tips)- Type C	SM1002 SM9003 SM1004 (attach Buy America certification(s) in SM)
4	02 of 04	915.01 or 915.02 or 910.21	STEEL PILES	JOBSITE	EPOXY COATED STEEL H PILES, STEEL ENCASED CONCRETE PILES AND STEEL SHEET PILES.	External Document-Mill Certification Certification (epoxy coating)- Type C Approval Number (epoxy coating)	SM1002 SM9003 SM9004 SM1004 (attach Buy America certification(s) in SM)
4	03 of 04	910.21	STEEL PILES	JOBSITE	STEEL SHEET PILES. Temporary.	Visually inspect for suitability of use.	No Sample ID required. SM1004 (attach Buy America certification(s) in SM)
4	04 of 04	701.11	H-PILE SPLICER COMMERCIAL	JOBSITE	UNCOATED STEEL H PILE SPLICERS.	External Document-Mill Certification	SM1002 SM1004 (attach Buy America certification(s) in SM)
5	01 of 01	911.01e	WOODEN PILES (TEMPORARY)	ANY LOCATION PRIOR TO USE	UNTREATED.	Visually inspect each piece for species, straightness and quality.	No Sample ID required.
6	01 of 01	915.04	ELASTOMERIC BEARING PADS (BR)	ANY LOCATION PRIOR TO USE	Allow 30 days for testing.	Certification-Type B One sample (one pad) of each type, for each lot. When shapes A and B of any type are required, only shape A shall be furnished for testing.	SM9003 Sample ID Number (from M&T) SM1004 (attach Buy America certification(s) in SM)
7	01 of 03	906.07a	EXPANSION JOINTS	JOBSITE	Type SS. Inspect for dimensions and workmanship.	Certification for Elastomer-Type B Certification for Str. Steel and Sealant- Type C	SM9003 SM9003 SM1004 (attach Buy America certification(s) in SM)
7	02 of 03	906.07b	EXPANSION JOINTS	JOBSITE	Type M. Inspect for dimensions and workmanship.	Certification for Elastomer-Type B Certification for Str. Steel and Sealant-Type C	SM9003 SM9003 SM1004 (attach Buy America certification(s) in SM)

7	03 of 03	RSP 724-B-145	EXPANSION JOINTS	JOBSITE	EXPANSION JOINT SEALING SYSTEM	Certification for Silicone Sealant - Type A Certification for Polymer Nosing System Binder - Type A Certification for Polymer Nosing System Mortar - Type A Certification for Bond Breaker - Type C	SM9003 SM9003 SM9003 SM9003
8	01 of 01	904	AGGREGATES	CAPP SOURCE	USED IN CONCRETE AND HMA PLANTS.	Approval Number	IT211
9	01 of 02	901.01	CEMENT	BATCH PLANT	One 12 lb random verification sample required as directed by Directive 401.	Approval Number	SM9004 SM1002
9	02 of 02	901.02	FLY ASH	BATCH PLANT	One 5 lb random verification sample required as directed by Directive 401.	Approval Number	SM9004 SM1002
10	01 of 02	901.08	BAGGED CEMENTS	JOBSITE	Portland and Masonry cements.	< 75 Bags Visual Inspection	No Sample ID required.
10	02 of 02	901.08	BAGGED CEMENTS	JOBSITE	Portland and Masonry cements.	≥ 75 Bags, test results (from M&T) One unopened bag for each 250 bags.	
11	01 of 01	901.08	BAGGED MORTAR MIX	JOBSITE	All packages shall be identified as conforming to ASTM C-387.	Visual Inspection	No Sample ID required.
12	01 of 02	912.03	CONCRETE ADMIXTURE	BATCH PLANT	TYPE A, B, C, D, E, F, G, and AIR ENTRAINMENT	Approval Number	SM9004
12	02 of 02	912.04	CONCRETE ADMIXTURE	BATCH PLANT	LATEX MODIFIER	Approval Number	SM9004
13	01 of 03	912.01	CONCRETE CURING MATERIALS	JOBSITE	Liquid Membrane Curing Materials.	≤ 1000 gal Visual Inspection	No Sample ID required.
13	02 of 03	912.01	CONCRETE CURING MATERIALS	JOBSITE	Liquid Membrane Curing Materials. Sample will be obtained at sprayer nozzle to obtain one 1 gal sample.	> 1000 gal, test results (from M&T) Sample once per source per contract which use > 1000 gal or as requested.	T155
13	03 of 03	912.02	CONCRETE CURING MATERIALS	JOBSITE	CONCRETE SEALERS, PROPRIETARY. One 1 qt random verification sample required per year per manufacturer as directed. Sample at sprayer nozzle.	Approval Number Certification-Type C	SM9004 SM9003
14	01 of 02	702.23	CONCRETE WATER PROOFING MATERIALS	JOBSITE	Treated cotton fabric, woven glass fabric and glass fiber material.	Certification-Type C	SM9003
14	02 of 02	702.23	CONCRETE WATER PROOFING MATERIALS	JOBSITE	Asphalt for waterproofing.	Certification-Type A	SM9003
15	01 of 24	501.05	CONCRETE	JOBSITE	PAVEMENT-QC/QA (Acceptance). Approved CMD Required.	Unit weight 1/2400 syd Air Content 1/2400 syd W/C Ratio 1/14,400 syd	T121QC T152QC IT403Q
15	02 of 24	501.05	CONCRETE	JOBSITE	PAVEMENT-QC/QA (Acceptance). Approved CMD Required.	Thickness: two cores per 2400 syd	IT404Q

15	03 of 24	501.05	CONCRETE	JOBSITE	PAVEMENT-QC/QA (Acceptance). Approved CMD Required.	Flexural: two beams per 2400 syd	T97Q
15	04 of 24	501.23	CONCRETE	JOBSITE	PAVEMENT-QC/QA (Opening to Traffic). Test beams for flexural strength shall be obtained at the end of each day's production.	Age requirement or Strength by maturity method or Flexural Strength	No Sample ID required. No Sample ID required. No Sample ID required.
15	05 of 24	502.04	CONCRETE	JOBSITE	PAVEMENT-NON QC/QA (Acceptance). Approved CMD Required.(Includes Driveways).	Yield 1/2400 syd Air Content 1/1200 syd Slump 1/1200 syd	T121 T152 T119
15	06 of 24	502.21	CONCRETE	JOBSITE	PAVEMENT-NON QC/QA (Acceptance). Approved CMD Required. Cores not required for patches, moment slab, sidewalks, nor driveways.	Thickness: one core per 1200 syd <i>per CLN (minimum 4 cores per section, and minimum of 1 core per subsection).</i> For <1200 syd, no sampling required.	IT404 No Sample ID required.
15	07 of 24	502.18	CONCRETE	JOBSITE	PAVEMENT-NON QC/QA (Opening to Traffic). Test beams shall be obtained at the end of each day's production.	Age requirement Flexural Strength	No Sample ID required. No Sample ID required.
15	08 of 24	702	CONCRETE	JOBSITE	SUPERSTRUCTURE (Acceptance).	Yield 1/100 cyd Air Content 1/50 cyd Slump 1/100 cyd W/C Ratio 1/400 cyd	T121 T152 T119 IT403
15	09 of 24	609	CONCRETE	JOBSITE	BRIDGE APPROACHES (Acceptance).	Yield 1/100 cyd Air Content 1/50 cyd Slump 1/100 cyd	T121 T152 T119
15	10 of 24	609.12	CONCRETE	JOBSITE	BRIDGE APPROACHES (Opening to Traffic). Test beams shall be obtained at the end of each day's production.	Age requirement or Flexural Strength	No Sample ID required. No Sample ID required.
15	11 of 24	702	CONCRETE	JOBSITE	STRUCTURES (Acceptance). Bridge substructures, wingwalls, drainage boxes, and railing.	Yield 1/50 cyd Air Content 1/50 cyd Slump 1/100 cyd Visual (For PLN quantity ≤ 20 cyd)	T121 T152 T119 No Sample ID required.
15	12 of 24	702.13g	CONCRETE	JOBSITE	STRUCTURES (Form removal). Test beams shall be obtained at the end of each day's production.	Age requirement or Flexural Strength	No Sample ID required. T97 T22
15	13 of 24	702.24	CONCRETE	JOBSITE	STRUCTURES (Load Application). Test beams (and/or cylinders if required by contract) shall be obtained at the end of each day's production.	Age requirement or Flexural Strength and/or Compressive Cylinders	No Sample ID required. T97 T22
15	14 of 24	702.24	CONCRETE	JOBSITE	STRUCTURES (Opening to Traffic or Form Removal or Load Application)	Flexural Strength Compressive Cylinders	No Sample ID required. T22

15	15 of 24	502 702	CONCRETE	JOBSITE	MISCELLANEOUS (Acceptance). Curb, Curb Ramps, Sidewalk, Traffic Items, Slopewalls, Anchors, Monuments, Pole Foundations, etc.	Yield 1/100 cyd Air Content 1/50 cyd Slump 1/100 cyd Visual (For PLN quantity ≤ 40 cyd)	T121 T152 T119 No Sample ID required.
15	16 of 24	602 RSP 620-R-483	CONCRETE	JOBSITE	MISCELLANEOUS (Acceptance). Concrete Barrier Walls and Sound Wall Foundations.	Yield 1/200 cyd Air Content 1/200 cyd Visual (For PLN quantity ≤ 40 cyd)	T121 T152 No Sample ID required.
15	17 of 24	722	CONCRETE	JOBSITE	LATEX-MODIFIED (Acceptance). One series of tests on first load of each truck and every third load per truck thereafter.	Yield 1/30 cyd Air Content 1/30 cyd Slump 1/30 cyd	SM7009 T152 T119LM
15	18 of 24	722.12	CONCRETE	JOBSITE	LATEX-MODIFIED (Opening to Traffic when Contractor elects to decrease the dry cure timeline per 722.12 .) Test cylinders shall be obtained at the end of each day's production. (Wet cure time shall not be reduced.)	Compressive Cylinders (optional) 2 (min./day)	T22
15	19 of 24	722	CONCRETE	JOBSITE	LATEX-MODIFIED, VERY EARLY STRENGTH (VES) (Acceptance). One series of tests on first load of each truck and every third load per truck thereafter.	Yield 1/30 cyd Air Content 1/30 cyd Slump 1/30 cyd	SM7009 T152 T119LM
15	20 of 24	722	CONCRETE	JOBSITE	LATEX-MODIFIED, VERY EARLY STRENGTH (VES) (Acceptance). Test cylinders shall be obtained at the end of each day's production.	Opening to Traffic: After 3 hr wet cure is complete. Minimum 2,500 psi compressive strength after 3 hr wet cure has concluded.	T22
15	21 of 24	722	CONCRETE	JOBSITE	SILICA FUME MODIFIED CONCRETE OVERLAY W/C ratio determined soon after pour begins for each day of placement and if there is a significant change in aggregate moisture	Yield 1/20 cyd Air Content 1/20 cyd Slump 1/20 cyd Compressive Cylinders, 4 cylinders/20 cyd (2 for 7 day, 2 for backup) W/C Ratio 1/day	T121 T152 T119 T22 IT403
15	22 of 24	506	CONCRETE	JOBSITE	FULL-DEPTH and PARTIAL DEPTH PATCHING-PCCP.	Air Content 1/50 cyd Flexural Beams (Opening to traffic) Flexural Beams (3-day flexural strength verification, average of at least 2 test beams) 2 beams (minimum) /150 cyd	T152 No Sample ID Required T97EP (T97 MP)

15	23 of 24	501.25(a) and ITM 912, Sec 5.0	PROFILOGRAPH, PCCP	JOBSITE	For Contracts which include the Profilograph, PCCP pay item. The profilograph shall be calibrated prior to use for both horizontal and vertical scales once each day on each contract.	Profilograph Verification (Machine Certification ID & Machine Operator).	IT912
15	24 of 24	RSP-912-M-050	CONCRETE	JOBSITE	SYNTHETIC FIBERS FOR USE IN PCC	Approval Number	SM9004
16	01 of 11	910.01b	REINFORCING STEEL	CERTIFIED MANUFACTURER	REINFORCING BAR-UNCOATED. Straight or Spiral. One 5 ft random verification sample required per year per manufacturer as directed.	Approval Number-J Number	SM9004 SM1004 (attach Buy America certification(s) in SM)
16	02 of 11	910.01b9	REINFORCING STEEL	CERTIFIED COATER	REINFORCING BAR-COATED. Straight, Bent, or Spiral. One 5 ft random verification sample required per year per manufacturer as directed.	Approval Number-J Number (Certified Reinforcing Bar Epoxy Coater)	SM9004 SM1004 (attach Buy America certification(s) in SM)
16	03 of 11	910.01b10	REINFORCING STEEL	CERTIFIED COATER	DOWEL. One random verification sample required per year per manufacturer as directed.	Approval Number-J Number (Certified Reinforcing Bar Epoxy Coater)	SM9004 SM1004 (attach Buy America certification(s) in SM)
16	04 of 11	503.04	REINFORCING STEEL	JOBSITE	DOWEL BAR ASSEMBLIES. Support baskets for D-1 contraction joints.	Visually inspect for compliance.	No Sample ID required. SM1004 (attach Buy America certification(s) in SM)
16	05 of 11	910.01b5 or 910.01b6	REINFORCING STEEL	JOBSITE OR FABRICATOR	WELDED WIRE. Smooth or Deformed.	Approval Number	SM9004 SM1004 (attach Buy America certification(s) in SM)
16	06 of 11	910.01b5 or 910.01b6	REINFORCING STEEL	JOBSITE OR FABRICATOR	WELDED WIRE. For Bridge Deck Reinforcement. Smooth or Deformed. (Must be from an approved source.)	One 3 ft x 3 ft sample per wire size for each 20 T from each source.	SM9039, SM9040, SM9041 or SM9042 Sample ID Number (Templates by M&T) SM1004 (attach Buy America certification(s) in SM)
16	07 of 11	910.01b2	REINFORCING STEEL	JOBSITE	THREADED TIE BAR ASSEMBLY. For each bar size.	For ≤ 10 units of each bar size, visual inspection	No Sample ID required. SM1004 (attach Buy America certification(s) in SM)
16	08 of 11	910.01b2	REINFORCING STEEL	JOBSITE	THREADED TIE BAR ASSEMBLY. For each bar size.	For > 10 units, two complete assemblies when less than 8 ft, one complete assembly otherwise, for each 4000 assemblies.	SM9009 Epoxy Assemblies or SM9009 Plain Assemblies SM1004 (attach Buy America certification(s) in SM)

16	09 of 11	910.01b3	REINFORCING STEEL	JOBSITE	SPLICING SYSTEM for reinforcing bar. Two 3 ft bars and coupler random verification sample required per year per manufacturer as directed.	Approval Number	SM9004 SM1004 (attach Buy America certification(s) in SM)
16	10 of 11	910.01a	REINFORCING STEEL	JOBSITE	BENT TIE BAR. One random verification sample required per year per manufacturer as directed. Two complete bar samples when less than 8 ft, otherwise one complete bar sample.	Approval Number Sample ID Number	SM9004 SM1004 (attach Buy America certification(s) in SM)
16	11 of 11	901.05	REINFORCING STEEL	JOBSITE	CHEMICAL ANCHOR SYSTEM. One 1 qt random verification sample required per year per manufacturer as directed.	Approval Number	SM9004 SM1004 (attach Buy America certification(s) in SM)
17	01 of 10	906.02a	CRACK, JOINT and LOOP SEALANT	JOBSITE, SOURCE, or DISTRIBUTOR	SINGLE COMPONENT LOW MODULUS.	Approval Number	SM9004
17	02 of 10	906.02a2	CRACK, JOINT and LOOP SEALANT	JOBSITE, SOURCE, or DISTRIBUTOR	HOT POURED JOINT SEALANT.	Certification Type A	SM9003
17	03 of 10	906.02a	HOT POURED JOINT ADHESIVE	JOBSITE	HOT POURED JOINT ADHESIVE. Used to seal joint between adjacent HMA surface and int. courses.	Certification for Joint Adhesive - Type A	SM9003
17	04 of 10	902.01b	ASPHALT EMULSION	JOBSITE	LIQUID ASPHALT SEALANT. AE-NT or SS-1h. Used over finished HMA surface joint to prevent water intrusion.	Certification for Liquid Asphalt Sealant - Type A	SM9003
17	05 of 10	902.01b	ASPHALT EMULSION	JOBSITE	LIQUID ASPHALT SEALANT. VRAM. Used under finished HMA surface joint to prevent water intrusion.	Certification for Liquid Asphalt Sealant - Type A	SM9003
17	06 of 10	408 902.01(a) 902.01(b)	CRACK, JOINT and LOOP SEALANT	JOBSITE	PAVING GRADES AND NON PAVING GRADES. Material in storage for more than 60 days without testing must be sampled, tested and approved prior to use.	Certification Type A	SM9003
17	07 of 10	906.02a3	CRACK and JOINT FILLER	JOBSITE, SOURCE, or DISTRIBUTOR	PREFORMED ELASTOMERIC JOINT SEAL.	Certification for joint material- Type A	SM9003
17	08 of 10	Special Provision	CRACK and JOINT FILLER	JOBSITE, SOURCE, or DISTRIBUTOR	PREFORMED JOINT FILLER FOR CONCRETE.	Certification - Type B One 5 ft sample of each thickness for each 1000 sys per shipment.	SM9003
17	09 of 10	906.02a1 906.02b	CRACK and JOINT FILLER	JOBSITE, SOURCE, or DISTRIBUTOR	SILICONE JOINT SEALANTS FOR I-A JOINTS. Transverse joints for RCBAs.	Approval Number Certification for Backer Rod - Type C	SM9004 SM9003

17	10 of 10	906.02(a)4 and 906.02(b)	BRIDGE JOINT MEMBRANE (FOR SEMI-INTEGRAL END BENTS)	JOBSITE, SOURCE, or DISTRIBUTOR	POLYCHLOROPRENE JOINT MEMBRANE, ADHESIVE AND BACKER ROD	Certification for Membrane-Type B Certification for Adhesive and Backer Rod-Type C	SM9003 SM9003
18	01 of 03	909.09	EPOXY PENETRATING SEALERS	JOBSITE, SOURCE, or DISTRIBUTOR	POLYSULFIDE TYPE, UNMODIFIED TYPE, and LOW TEMPERATURE TYPE Applies only to contracts let prior to 9/1/2019	Approval Number-CF Number (Coating Formulations)	SM9004
18	02 of 03	709.05b	SILICA SAND BAGGED	JOBSITE		Visually inspect bag label or MSDS. (Applies only to contracts let prior to 9/1/2019)	No Sample ID required.
18	03 of 03	709.05b	SILICA SAND BULK	JOBSITE		Certification-Type C (Applies only to contracts let prior to 9/1/2019)	SM9003
19	01 of 01	909.10	PROPRIETARY PCC SEALER	JOBSITE	One 1 qt random verification sample required per year per manufacturer as directed.	Approval Number	SM9004
20	01 of 02	909.11	EPOXY	JOBSITE	RESIN BASE SYSTEM or ADHESIVE. For bonding plastic concrete to hardened concrete. Inspect for dimensions and/or workmanship.	Certification-Type C	SM9003
20	02 of 02	909.12	EPOXY	JOBSITE	RESIN ADDITIVES. For injection into cracks in hardened concrete.	Certification-Type C	SM9003
21	01 of 01	506.02	BONDING AGENT	JOBSITE	For grout finish.	Approval Number	SM9004
22	01 of 05	211.02	B BORROW / STRUCTURE BACKFILL, GRADATION	CAPP SOURCE	ALL USES.	Approval Number-Approved CAPP Source	IT211
22	02 of 05	211.02	B BORROW / STRUCTURE BACKFILL, GRADATION	PIT, OTHER (NON- CAPP SOURCE)	1 cyd=3000 lb for material placed above water.	Name of Certified Technician or Qualified Geotechnical Technician Contractor's Test Results. One test per 2000 T based on production samples into a stockpile or by over the scales measurement. Minimum two tests per contract.	IT211-Certified Technician/Qualified Geotechnical Technician

22	03 of 05	211.02	B BORROW, DENSITY OR STIFFNESS AND MOISTURE	JOBSITE	1 cyd=3000 lb for material placed above water.	For less than or equal to 700 cy, one in- place density or stiffness test for each two-lane pavement, for each lift. A minimum of one moisture test per day. The testing frequency in SiteManager will need to be changed to reflect actual number of moisture tests required per PLN.	T191, ITM 508 or ITM 509 IT506 (for sand/granular soils) or T255 (for coarse aggregate)
22	04 of 05	211.02	STRUCTURE BACKFILL, DENSITY OR STIFFNESS AND MOISTURE	JOBSITE	1 cyd=3000 lb for material placed above water.	One in-place density or stiffness test per 500 cyd. A minimum of one moisture test per day is required. The testing frequency in SiteManager will need to be changed to reflect actual number of moisture tests required per PLN.	T191, ITM 508 or ITM 509 IT506 (for sand/granular soils) or T255 (for coarse aggregate)
22	05 of 05	731.11	STRUCTURE BACKFILL	JOBSITE	FOR RETAINING WALL SYSTEMS (MSE and MODULAR BLOCK)	Certification-Type A	SM9003
23	01 of 03	303.06	COMPACTED AGGREGATE GRADATION	SOURCE	ALL USES.	Approval Number-Approved CAPP Source	IT211
23	02 of 03	303.06	COMPACTED AGGREGATE DENSITY OR STIFFNESS AND MOISTURE	JOBSITE	ALL USES.	For < 20 T or if depth of material < 3 in. no density or stiffness testing is required. Otherwise, 1/800 T. For < 20 T, no moisture test is required. Otherwise, a minimum of one moisture taken from the first truck of the day for each day of aggregate placement. The testing frequency in SiteManager will need to be changed to reflect actual number of moisture tests required per PLN.	No Sample ID required. IT508 or T191 T255
23	03 of 03	303.06	COMPACTED AGGREGATE PI, LL and DENSITY	SOURCE	ALL USES. District Testing will sample and test annually. If material is plastic, LL and PI will be tested monthly when used.	District Testing Test Results.	T90
24	01 of 02	302.06	SUBBASE, GRADATION	SOURCE	ALL USES.	Approval Number-Approved CAPP Source	IT211
24	02 of 02	302.06	SUBBASE, DENSITY OR STIFFNESS	JOBSITE	ALL USES.	For < 20 T or if depth of material < 3 in. no testing required. Otherwise, 1/800 T	No Sample ID required. IT508 or T191 with moisture

25	01 of 01	203.23 207.03	EMBANKMENT, SUBGRADE STRENGTH OR DENSITY AND MOISTURE	JOBSITE	If fill is being placed in multiple locations, additional tests will be required.	Three DCP or Density tests per 2,000 cyd for each lift. One Moisture Test each 4 hours for Clay; and one test daily for Silty, Sandy or Granular Soils. The testing frequency in SiteManager will need to be changed to reflect actual number of moisture tests required for the per PLN.	IT509 or T191 IT506
26	01 of 03	207.03 215.09	SUBGRADE TREATMENT, STIFFNESS OR STRENGTH AND MOISTURE (CHEMICAL MODIFIED SUBGRADE)	JOBSITE	FOR PAVEMENT (Mainline and Shoulders). Chemically Modified Soils.	Three DCP tests per 1,400 cu yd OR Three LWD Tests per 1,400 cu yd. One Moisture Test each 4 hours during chemical modification/soil mixing. The testing frequency in SiteManager will need to be changed to reflect actual number of moisture tests required per PLN.	IT509 or IT508 IT506 (Stovetop)
26	02 of 03	RSP 215-R-715 215.09	SUBGRADE TREATMENT, GRADATION (CHEMICAL MODIFIED SUBGRADE)	JOBSITE	FOR PAVEMENT (Mainline and Shoulders). Chemical Modification.	One Gradation Test per 2,500 cu yds	IT506
26	03 of 03	207.03 301.05	SUBGRADE TREATMENT, STIFFNESS AND MOISTURE (COMPACTED AGGREGATE)	JOBSITE	FOR PAVEMENT (Mainline and Shoulders). Compacted Coarse Aggregate No. 53.	Three LWD Tests per 800 tons of compacted aggregate for the width of the constructed area. For < 20 T, no moisture test is required. Otherwise, a minimum of one moisture taken from the first truck of the day for each day of aggregate placement. The testing frequency in SiteManager will need to be changed to reflect actual number of moisture tests required per PLN.	IT508 T255
27	01 of 01	910.18 910.13	METAL FENCE MATERIALS	INSTALLER or JOBSITE	FENCE FABRIC, POSTS, GATES, AND ACCESSORIES	Certification - Type C	SM9003 SM1004 (attach Buy America certification(s) in SM)
32	01 of 02	910.09	GUARDRAIL	JOBSITE	STEEL W BEAM, THRIE BEAM, W TO THRIE BEAM TRANSITION PIECES. SPLICE PLATES, TERMINAL ENDS, BUFFER ENDS, AND FASTENERS. For use with Guardrail, Guardrail Transitions and Terminal Systems.	Approval Number (<i>Certified Guardrail Manufacturer, one for each component manufacturer</i>) <i>Buy America (one for each component and manufacturer)</i>	SM9004 SM1004 (attach Buy America certification(s) in SM)

32	02 of 02	910.10(a), 910.11 (excluding fasteners)	GUARDRAIL	JOBSITE	STEEL POSTS & MISCELLANEOUS ACCESSORIES (e.g. STEEL CHANNELS, CABLES, ANCHOR PLATES, etc.) For use with Guardrail, Guardrail Transitions and Terminal Systems.	Certification - Type C Buy America (one for each component and manufacturer)	SM9003 SM1004 (attach Buy America certification(s) in SM)
33	01 of 02	911.02f	SAWN TIMBER POSTS AND BLOCKOUTS	JOBSITE or SUPPLIER	ALL USES. Inspect for dimensions and wood defects.	Visual Inspection	No sample ID required.
33	02 of 02	926.03	GUARDRAIL BLOCKS, OTHER THAN WOOD	JOBSITE	OTHER THAN WOOD GUARD RAIL BLOCKOUTS	<i>External Document</i> (Manufacturer's FHWA eligibility letter stating NCHRP 350 or MASH TL-3 Compliance) Buy America (one for each steel blockout manufacturer)	SM1002 SM1004 (attach Buy America certification(s) in SM)
34	01 of 02	910.20	STEEL BRIDGE RAILING COMPONENTS	JOBSITE	ANCHOR BOLTS.	Certification-Type A	SM9003 SM1004 (attach Buy America certification(s) in SM)
34	02 of 02	910.20	STEEL BRIDGE RAILING COMPONENTS	JOBSITE	ALL OTHER COMPONENTS.	Certification-Type C	SM9003 SM1004 (attach Buy America certification(s) in SM)
35	01 of 01	601.07	GUARDRAIL END TREATMENT	JOBSITE	GUARD RAIL END TREATMENTS FOR W- BEAM AND THRIE BEAM RAIL SECTIONS.	Approval Number-W# Certification-Other (Verify Installer's Name to be on Certified Guardrail End Treatment and Impact Attenuator Installers List) <i>External Document</i> (Manufacturer's FHWA eligibility letter stating NCHRP 350 or MASH TL-2 or TL-3 Compliance)	SM9004 SM9003 (Identify Certified <i>Installer's Name and Company in Remarks</i>) SM1002 SM1004 (attach Buy America certification(s) in SM)
36	01 of 03	801.10.1	IMPACT ATTENUATORS	JOBSITE	TEMPORARY UNIT (CZ)	Certification-Other Copy of Certificate from unit's manufacturer indicating the installer has been trained in installation of the unit.) <i>External Document</i> (Manufacturer's FHWA eligibility letter stating NCHRP 350 or MASH TL-2 or TL-3 Compliance)	SM9003 (Identify Certified Installer's <i>Name and Company in Remarks</i>) SM1002
36	02 of 03	601.08	IMPACT ATTENUATORS	JOBSITE	PERMANENT	Approval Number-W# Certification-Other (Verify Installer's Name to be on Certified Guardrail End Treatment and Impact Attenuator Installers List) <i>External Document</i> (Manufacturer's FHWA eligibility letter stating NCHRP 350 or MASH TL-2 or TL-3 Compliance)	SM9004 SM9003 (Identify Certified Installer's <i>Name and Company in Remarks</i>) SM1002 SM1004 (attach Buy America certification(s) in SM)

36	03 of 03	RSP 801-T-227	TRUCK MOUNTED ATTENUATOR	JOBSITE	TRUCK MOUNTED	External Document (Manufacturer's FHWA eligibility letter stating NCHRP 350 or MASH TL-2 or TL-3 Compliance)	SM1002
37	01 of 02	914.01	TOPSOIL	SOURCE	Visually inspect for material detrimental to proper development of ground vegetation.	One 1 lb sample for pH testing. Visual Inspection	SM6009
37	02 of 02	914.01 RSP 629-R-630	PLANT GROWTH LAYER	JOBSITE	Visually inspect for material detrimental to proper development of ground vegetation.	Certification-Type A. One 5 U.S. cup sample (1 lb minimum) for each 10,000 square yards installed.	SM9003
38	01 of 01	914.01	AGRICULTURAL LIMESTONE	SOURCE	TOP SOIL ADDITIVE WHEN USED TO RAISE pH.	Visual Inspection	No Sample ID required.
39	01 of 02	914.03 RSP 629-R-630	FERTILIZER	JOBSITE	ALL USES. BAGGED, BULK, OR LIQUID. Analysis from bag or weigh ticket.	Visual Inspection	No Sample ID required.
39	02 of 02	914.03	COMPOST	SUPPLIER	ALL USES.	Certification-Type C	SM9003
40	01 of 03	914.04 621	SEED	JOBSITE	Seed may only be used within 9 months of certification date.	Certification-Other (Letter from State Seed Commissioner)	SM9003
40	02 of 03	914.04 621	SEED. (Temporary Only- Seed Mix T)	JOBSITE or SUPPLIER	Visual Inspection to ensure that the seed's package is clearly marked and labeled by the manufacturer as to its content and weight.	Visual Inspection.	No Sample ID required.
40	03 of 03	Unique Special Provision	NATIVE GRASSES AND FORB SEEDING (Wildflower and Prairie Grasses)	JOBSITE	Seed may only be used within 9 months of certification date.	Certification-Other (Letter from State Seed Commissioner)	SM9003
41	01 of 03	914.05	MULCH	JOBSITE	For all types of mulch (when paid by weight), visually inspect each shipment.	For < 40 T, Visual Inspection.	No Sample ID required.
41	02 of 03	914.05	MULCH	JOBSITE	For all types of mulch (when paid by weight), inspect each shipment.	For ≥ 40 T, one moisture test. Additional tests when inspection indicates a significant amount of moisture in the mulch.	SM6004
41	03 of 03	914.05	MULCH	JOBSITE	EROSION CONTROL BLANKETS	Certification-Type C	SM9003
42	01 of 02	914.07	SOD	JOBSITE	NURSERY.	Certification-Type C	SM9003
42	02 of 02	914.07	SOD	JOBSITE	OTHER.	Visual Inspection	No Sample ID required.
43	01 of 02	914.08	PLANTS	JOBSITE or NURSERY	SEEDLINGS. Certificate of compliance for plants required. Inspect plants for quality.	Approval Number-W Number for Seedling Source	SM9004
43	02 of 02	914.08	PLANTS	JOBSITE	PLANTS. (Balled and Burlapped, Container Grown, Bare Rooted, etc.). Certificate of compliance for plants required. Inspect plants for quality.	Certification-Type C	SM9003

44	01 of 01	914.09	MISCELLANEOUS ROADSIDE DEVELOPMENT MATERIALS	JOBSITE or SOURCE	WATER, STAKES FOR BRACING OR ANCHORING, TREE WOUND DRESSING, POROUS MATERIAL, PIPE, STAPLES AND PLASTIC NET.	Certification-Type C	SM9003
45	01 of 01	RSP 624-M-024	HERBICIDES	CONTRACTOR CENTRAL STORAGE AREA	Visually inspect for verification of manufacturer and active ingredients.	Certification-Type B	SM9003
46	01 of 02	911.01	LUMBER, UNTREATED (PERMANENT USE)	JOBSITE or SUPPLIER	Visually inspect for dimension and wood defects.	Visual Inspection-State Stamp or Grade Mark (One End Only)	No Sample ID required.
46	02 of 02	911.01	LUMBER, UNTREATED (TEMPORARY USE)	JOBSITE	N/A	Visual Inspection of each item	No Sample ID required.
47	01 of 03	911.02(g)	TREATED: LUMBER, FOR RECREATIONAL APPLICATIONS ONLY	JOBSITE or CONTRACTOR YARD	Picnic tables, decking, benches, handrails, etc. and other uses where human contact will occur. Inspect for dimensions.	Certification-Type C	SM9003
47	02 of 03	911.02	LUMBER AND TIMBER, TREATED: BRIDGE LUMBER, PILING, SAWN TIMBER POSTS AND BLOCKOUTS, ETC. (PERMANENT USE)	TREATMENT PLANT, JOBSITE or CONTRACTOR YARD	Inspect after treatment, and perform assay test.	Visually inspect each piece for species, straightness, and quality.	No sample ID required.
47	03 of 03	911.02	LUMBER AND TIMBER, TREATED (TEMPORARY USE)	TREATMENT PLANT, JOBSITE or CONTRACTOR YARD	TREATED WOOD (TEMPORARY). Visually inspect each item after treatment.	Visual Inspection	No Sample ID required.
48	01 of 03	404 608 616 904.02g 718 RSP 205-R-636	AGGREGATE	CAPP SOURCE	SHOULDER DRAINS, UNDERDRAINS, SEAL COATS, RIPRAP, SNOW AND ICE ABRASIVE, COARSE AGGREGATES FOR STORM WATER MANAGEMENT, AND MISCELLANEOUS USE.	Approval Number-CAPP Q and D Numbers	IT211
48	02 of 03	904	AGGREGATE for PRECAST CONCRETE	SOURCE	Quality Test Required.	N/A	No Sample ID required.
48	03 of 03	904.02g	AGGREGATE SNOW and ICE	NON-CAPP SOURCE	One Gradation by INDOT per 1000 T.	Sample ID Number	T27FA
49	01 of 01	910.16	COPPER FLASHING	JOBSITE	Inspect for dimensions and/or workmanship.	Certification-Type C	SM9003
50	01 of 01	910.17	BRONZE OR COPPER ALLOY PLATES	POINT OF DELIVERY	Inspect for dimensions and/or workmanship.	Certification-Type C	SM9003
51	01 of 01	913.01	WATER	SOURCE	Based on intended use. When source is of questionable quality for intended use, consult the DTE.	Visual Inspection.	No Sample ID required.

52	01 of 03	913.02 913.03 ITM 810	CALCIUM AND SODIUM CHLORIDE	POINT OF DELIVERY	ICE AND SNOW REMOVAL.	One 1 gal sample for each 200 T per source for gradation and moisture. One quart sample for purity per purchase order.	M143 and T255
52	02 of 03	913.02 913.03	CALCIUM AND SODIUM CHLORIDE	POINT OF USAGE	ALL OTHER USES.	For ≤ 5 T, no sampling required.	No Sample ID required.
52	03 of 03	913.02 913.03	CALCIUM AND SODIUM CHLORIDE	POINT OF USAGE	ALL OTHER USES.	For > 5 T, one 1 gal sample for each 200 T per source.	M143, M144 and T255
53	01 of 02	913.04(a)	HYDRATED LIME	JOBSITE	MASONRY One 50 lb random verification sample required per year per manufacturer as directed.	Certification-Type C	SM9003
53	02 of 02	913.04(b)	HYDRATED LIME, QUICKLIME, AND LIME BY- PRODUCT	JOBSITE	FOR CHEMICAL MODIFICATION. One 1 lb random verification sample required per year per manufacturer as directed.	Approval Number	SM9004
54	01 of 01	611	MAIL BOX ASSEMBLY	JOBSITE	Visually inspect for dimensions and workmanship.	Visual Inspection	No Sample ID required. SM1004 (attach Buy America certification(s) in SM)
55	01 of 07	918.02(a)	GEOSYNTHETIC MATERIALS	JOBSITE or SOURCE	GEOTEXTILE FOR RIPRAP	Approval Number	SM9004
55	02 of 07	918.02(b)	GEOSYNTHETIC MATERIALS	JOBSITE or SOURCE	GEOTEXTILE FOR UNDERDRAINS	Approval Number	SM9004
55	03 of 07	918.02(c)	GEOSYNTHETIC MATERIALS	JOBSITE or SOURCE	GEOTEXTILE FOR PAVEMENT AND SUBGRADE	Approval Number	SM9004
55	04 of 07	918.02(d)	GEOSYNTHETIC MATERIALS	JOBSITE or SOURCE	SILT FENCE. Inspect for dimensions and/or workmanship.	Approval Number	SM9004
55	05 of 07	918.03	GEOSYNTHETIC MATERIALS	JOBSITE or SOURCE	GEOMEMBRANE	Approval Number	SM9004
55	06 of 07	918.04	GEOSYNTHETIC MATERIALS	JOBSITE or SOURCE	GEOCELL CONFINING SYSTEM	Approval Number	SM9004
55	07 of 07	918.05	GEOSYNTHETIC MATERIALS	JOBSITE or SOURCE	GEOGRID	Approval Number	SM9004
56	01 of 02	909.03	STRUCTURAL STEEL COATING SYSTEM (THREE COAT)	JOBSITE or SUPPLIER	Coating systems must be from the Department's list of approved structural steel coating systems, and all system components must be pre-tested.	Approval Number (W-number for coating system) and Approval Number (M- number for each of the three system components)	SM9004 (1 for the Coating System, and 1 for each System Component Material)
56	02 of 02	909.02(a) and 909.02(d)	STRUCTURAL STEEL PARTIAL PAINT SYSTEM (TWO COAT)	JOBSITE or SUPPLIER	Coating components must be from the Department's list of approved Coating Formulations and each component must be pre-tested.	Approval Number (M-Number for each of the two components)	SM9004 (1 for each System Component Material)

57	01 of 01	715	CONCRETE PIPE	JOBSITE	Certified Precast Concrete Producers. Marked with ACPA, NPCA or PCI B1 Product Marking, Source No., Date of Manufacture and any Std. Spec. Req.	Approval Number- Source Number Certification - Other (Refer to 907.02)	SM9004 SM9003 SM1004 (attach Buy America certification(s) in SM)
58	01 of 01	715.02(k)	PRECAST CONCRETE UNIT	SOURCE	END SECTIONS. Certified Precast Concrete Producers. Marked with ACPA, NPCA or PCI B1 Product Marking, Source No., Date of Manufacture and any Std. Spec. Req.	Approval Number- Source Number	SM9004 SM1004 (attach Buy America certification(s) in SM)
59	01 of 01	907.04 907.05	PRECAST CONCRETE UNIT.	JOBSITE	MANHOLES, INLETS, CATCH BASINS, AND GRADE RINGS. REINFORCED CONCRETE STRUCTURE SECTIONS. Certified Precast Concrete Producers. Marked with ACPA, NPCA or PCI B1 Product Marking, Source No., Date of Manufacture and any Std. Spec. Req.	Approval Number- Source Number Approval Number (Manhole Steps, if necessary)	SM9004 SM9004 SM1004 (attach Buy America certification(s) in SM)
60	01 of 04	731 901.10(b)	PRECAST CONCRETE UNIT	JOBSITE	MECHANICALLY STABILIZED EARTH RETAINING WALLS. Certified Precast Concrete Producers. Marked with ACPA, NPCA or PCI B1 Product Marking, Source No., Date of Manufacture and any Std. Spec. Req.	Approval Number-Precast Concrete Producer (4-digit Source #) Approval Number-Retaining Wall Systems (W#) For ≤ 750 panels, one sample for compressive strength verification (two cores) For > 750 panels, two cores per 750 panels Joint Spacer and Joint Cover Adhesive (Certification-Other) Joint Cover Material (Certification-Type C) Reinforcement Galvanization Certification (Certification Type A)	SM9004 SM9004 T24 T24 SM9003 SM9003 SM9003 SM1004 (attach Buy America certification(s) in SM)
60	02 of 04	732	MODULAR CONCRETE BLOCKS	SOURCE	N/A	For ≤ 200 blocks, visually inspect for dimensions and workmanship. Certification-Type A (Freeze/Thaw ASTM C1372 within 12 months of delivery)	No Sample ID required. SM9003

60	03 of 04	732	MODULAR CONCRETE BLOCKS	SOURCE	A lot is not more than 10,000 blocks. Verify Delivery Ticket with SiteManager remarks.	For > 200 blocks, six blocks for Compressive strength and Absorption per lot. Certification-Type A (Freeze/Thaw ASTM C1372 within 12 months of delivery)	Sample ID (Templates by M&T); assign PLN and represented quantity to Contract tab in SiteManager SM9003
60	04 of 04	732	MODULAR CONCRETE BLOCKS	SOURCE	Cap blocks.	Visually inspect for dimensions and workmanship. Certification-Type A (Freeze/Thaw ASTM C1372 within 12 months of delivery)	No Sample ID required. SM9003
61	01 of 01	907.10	CONCRETE DRAIN TILE	SOURCE	Certified Precast Concrete Producers.	Approval Number - Source Number	SM9004 SM1004 (attach Buy America certification(s) in SM)
63	01 of 08	907.17 901.18	PLASTIC PIPE	JOBSITE	PLASTIC CORRUGATED DRAINAGE TUBING AND PERFORATED PLASTIC SEMI-CIRCULAR PIPE. Inspect for dimensions and workmanship.	Approval Number	SM9004
63	02 of 08	907.19 through 907.24 715.09	PLASTIC PIPE	JOBSITE	PLASTIC PIPE FOR USE IN CULVERTS, STORM SEWERS. Inspect for dimensions and workmanship.	Approval Number Mandrel Testing	SM9004 SM9043
63	03 of 08	907.24b	PLASTIC PIPE	JOBSITE	SCHEDULE 40 PVC PIPE. For underdrain outlets and miscellaneous applications. Inspect for dimensions and workmanship. ASTM stamp required on pipe.	Certification-Type C	SM9003
63	04 of 08	907.23	PLASTIC PIPE	JOBSITE	SMOOTH WALL PVC. Storm drainage pipe when in close proximity to water distribution lines as regulated by IDEM.	Certification-Type A (include Lot # and Date of Manufacture).	SM9003
63	05 of 08	715.02h	PLASTIC PIPE	JOBSITE	END BENT DRAIN PIPE. Perforated profile wall PVC pipe, perforated smooth wall PVC pipe, or corrugated polyethylene drainage tubing Type SP.	Approval Number	SM9004
63	06 of 08	907.25	PIPE LINERS	JOBSITE	THERMOPLASTIC LINER PIPE. Pipe Liners to be inspected.	Approval Number or Certification - Type A	SM9004 or SM9003
63	07 of 08	907.26	SOLVENT CEMENTS	JOBSITE		Certification-Type C	SM9003
63	08 of 08	907.27	ELASTOMERIC SEALS	JOBSITE		Certification-Type B	SM9003

64	01 of 01	715.10	GRATED BOX END SECTIONS	SOURCE	Certified Precast Concrete Producers. Marked with ACPA, NPCA or PCI B1 Product Marking, Source No., Date of Manufacture and any Std. Spec. Req.	Approval Number- Source Number	SM9004 SM1004 (attach Buy America certification(s) in SM)
65	01 of 01	907.13	RUBBER TYPE GASKETS (RING)	JOBSITE	Inspect for dimension and/or workmanship.	Certification-Type B	SM9003
66	01 of 01	907.11	MASTIC PIPE JOINT SEALERS	JOBSITE	Inspect for dimension and/or workmanship.	Certification-Type B	SM9003
67	01 of 01	907.07	JOINT MEMBRANE SYSTEM FOR PRECAST CONCRETE BOX CULVERTS	JOBSITE	Inspect for dimension and/or workmanship.	Certification-Type B	SM9003
68	01 of 01	907.04	MANHOLE STEPS	SOURCE	FOR CONCRETE LIFT STATIONS.	Approval Number	SM9004 SM1004 (attach Buy America certification(s) in SM)
69	01 of 01		CAST IRON CULVERT PIPE	JOBSITE	Field check for dimensions and weight.	Visual Inspection	No Sample ID required.
70	01 of 02	908.02 908.04 908.08 908.14	PIPE	SOURCE	CORRUGATED METAL CULVERT PIPE, PIPE ARCHES, SLOTTED DRAIN AND UNDERDRAINS. One verification sample by Testing per mill per fabricator per calendar year per gauge.	External Document-Mill Report and Fabricator Certification	SM1002 SM1004 (attach Buy America certification(s) in SM)
70	02 of 02	908.02 908.04 908.08 908.14	PIPE	JOBSITE	CORRUGATED METAL CULVERT PIPE, PIPE ARCHES, SLOTTED DRAIN AND UNDERDRAINS.	Approval Number-Seal Numbers (PIPE)	SM9019 SM1004 (attach Buy America certification(s) in SM)
71	01 of 01	908.06	METAL END SECTIONS	SOURCE	One verification sample by Testing per mill per fabricator per calendar year per gauge.	External Document-Mill Report and Fabricator Certification	SM1002 SM1004 (attach Buy America certification(s) in SM)
72	01 of 01	908.07	ASPHALT MATERIAL FOR PIPE	SOURCE	ASPHALT MATERIAL FOR PIPE COATING. Verification sample from the tank used in production after replenishment and every 30 days thereafter.	Certification-Type A	SM9003
73	01 of 04	908.09	PIPE	ANY LOCATION PRIOR TO USE	STRUCTURAL PLATE PIPE, PIPE ARCHES, AND ARCHES. One verification sample by Testing per fabricator per calendar year per gauge.	External Document-Mill Report and Fabricator Certification	SM1002 SM1004 (attach Buy America certification(s) in SM)
73	02 of 04	908.10	PIPE	JOBSITE	CAST IRON SOIL PIPE. For bridge drains. Field check for dimensions and weight.	Visual Inspection	No Sample ID required. SM1004 (attach Buy America certification(s) in SM)
73	03 of 04	907.28	REINFORCED THERMOSETTING RESIN PIPE	JOBSITE	FIBERGLASS PIPE FOR BRIDGE DRAINAGE SYSTEMS. Inspect for dimensions and workmanship.	Certification-Type A	SM9003

73	04 of 04	910.07 908.11	STEEL PIPE	JOBSITE	Inspect for dimensions and workmanship.	Certification-Type C	SM9003 SM1004 (attach Buy America certification(s) in SM)
74	01 of 03	905.02 or 905.03	BRICKS AND BLOCKS	JOBSITE or SOURCE	BRICK AND BLOCK.	For lots ≤ 200 units, visually inspect for dimensions and workmanship	No Sample ID required.
74	02 of 03	905.02 or 905.03	BRICKS AND BLOCKS	JOBSITE or SOURCE	BRICK AND BLOCK. Verify Delivery Ticket with SiteManager remarks.	Approval Number - Sample ID from M&T Testing For lots of 201 to 1500 units, one sample (6 units).	SM9004 - Sample ID
74	03 of 03	905.02 or 905.03	BRICKS AND BLOCKS	JOBSITE or SOURCE	BRICK AND BLOCK. Verify Delivery Ticket with SiteManager remarks.	Approval Number - Sample ID from M&T Testing For lots > 1500 units, 10 units for each lot of 100,000 except for lots of more than 500,000 units, five units shall be taken from every 100,000 units.	SM9004 - Sample ID
75	01 of 01	904.04e	PRECAST RIPRAP	SOURCE	Certified Precast Concrete Producers.	Approval Number- Source Number	SM9004
76	01 of 02	600 (numerous subsections apply)	PRECAST CONCRETE UNITS	SOURCE	PRECAST PARKING BARRIERS, PRECAST CONCRETE CURBING, BENCH-MARK POSTS, CABLE MARKERS, AND MONUMENTS. Certified Precast Concrete Producers.	Approval Number- Source Number	SM9004 SM1004 (attach Buy America certification(s) in SM)
76	02 of 02	615.03	PRECAST CONCRETE UNITS	SOURCE	RIGHT-OF-WAY MARKERS. Certified Precast Concrete Producers.	Approval Number - Source Number Certification - Type C	SM9004 SM9003 SM1004 (attach Buy America certification(s) in SM)
77	01 of 01	905.06	PRECAST CONCRETE UNITS	SOURCE	OTHER CONCRETE ITEMS.	Visual Inspection	No Sample ID required. SM1004 (attach Buy America certification(s) in SM)
78	01 of 02	602.03a	PRECAST MEDIAN BARRIERS	SOURCE	PERMANENT. Certified Precast Concrete Producers.	Approval Number- Source Number	SM9004 SM1004 (attach Buy America certification(s) in SM)
78	02 of 02	602.03a	PRECAST MEDIAN BARRIERS	SOURCE	PERMANENT. Strength (2 cylinders) per 100 units and Absorption (2 cores for wet cast only) per 50 units.	Certification-Type A	SM9003 SM1004 (attach Buy America certification(s) in SM)
79	01 of 03	801.10	TEMPORARY TRAFFIC BARRIERS (PRECAST)	ANY LOCATION PRIOR TO USE	CONCRETE. Produced after March 1, 2003 and prior to January 1, 2007	Visual Inspection based on required markings and condition.	No Sample ID required.
79	02 of 03	801.10	TEMPORARY TRAFFIC BARRIERS (PRECAST)	ANY LOCATION PRIOR TO USE	CONCRETE. Produced January 1, 2007 or thereafter. Certified Precast Concrete Producers.	Approval Number- Source Number	SM9004

79	03 of 03	801.10	TEMPORARY TRAFFIC BARRIERS (TEMPORARY - FHWA APPROVED)	ANY LOCATION PRIOR TO USE	TYPE 2 TRAFFIC BARRIER - OTHER THAN PRECAST CONCRETE - FHWA APPROVED.	External Document (Manufacturer's FHWA eligibility letter stating NCHRP 350 or MASH TL-2 or TL-3 Compliance)	SM1002
80	01 of 05	707.02	PRECAST/PRESTRESSED CONCRETE MEMBERS	PRODUCER	One slump, one air test shall be made for each set of cylinders, per bed, per day, to a maximum of 3 tests per beam.	Approval Number-Sample ID number by Structural Fabrication Supervisor	SM7005
80	02 of 05	707.02	PRECAST/PRESTRESSED CONCRETE MEMBERS	PRODUCER	AGGREGATE by Structural Fabrication Supervisor	Approval Number	SM9004
80	03 of 05	707.02	PRECAST/PRESTRESSED CONCRETE MEMBERS	PRODUCER	CEMENT by Structural Fabrication Supervisor	Approval Number	SM9004
80	04 of 05	707.02	PRECAST/PRESTRESSED CONCRETE MEMBERS	PRODUCER	REINFORCING STEEL by Structural Fabrication Supervisor: One random verification sample required per year per manufacturer as directed. One 5 ft sample for each 15 T of each size and deformation.	Approval Number	SM9004 SM1004 (attach Buy America certification(s) in SM)
80	05 of 05	707.02	PRECAST/PRESTRESSED CONCRETE MEMBERS	PRODUCER	STRAND (Prestressed beams only) by Structural Fabrication Supervisor.	Certification-Type A and verification/receipt of Buy America documentation.	SM9003 SM1004 (attach Buy America certification(s) in SM)
81	01 of 06	910.14a 910.14b 910.14e	POLES AND POSTS	JOBSITE or SUPPLIER	SIGN POSTS (STEEL). Inspect for dimensions and workmanship.	Certification-Type B	SM9003 SM1004 (attach Buy America certification(s) in SM)
81	02 of 06	910.14c 910.14d	POLES AND POSTS	JOBSITE or SUPPLIER	STRUCTURAL STEEL AND STRUCTURAL ALUMINUM. Inspect for dimensions and workmanship.	Certification-Type C	SM9003 SM1004 (attach Buy America certification(s) in SM)
81	03 of 06	910.15	POLES AND POSTS	JOBSITE or SUPPLIER	DELINEATOR POSTS (METAL).	For ≤ 200 units, no sampling required. Certification - Type B	No Sample ID required. SM9003 SM1004 (attach Buy America certification(s) in SM)
81	04 of 06	910.15	POLES AND POSTS	JOBSITE or SUPPLIER	DELINEATOR POSTS (METAL).	For > 200 units, one 6 ft for each 1,000 units per shipment. For P.O.'s, one sample for each 1,000 units. Certification - Type B	SM6008 SM9003 SM1004 (attach Buy America certification(s) in SM)
81	05 of 06	910.15	POLES AND POSTS	JOBSITE or SUPPLIER	DELINEATOR POSTS (METAL) (TEMPORARY).	Visual Inspection	No Sample ID required.
81	06 of 06	926	POLES AND POSTS	JOBSITE or SUPPLIER	DELINEATOR POSTS (PLASTIC).	Approval Number	SM9004
82	01 of 01	910.19	OVERHEAD SIGN STRUCTURES	JOBSITE	ALUMINUM OR STEEL. Inspect for dimensions and workmanship.	Certification-Type C	SM9003 SM1004 (attach Buy America certification(s) in SM)

83	01 of 02	920.01d	HIGHWAY ILLUMINATION MATERIALS	JOBSITE	LUMINAIRES (Underpass, Roadway, and High Mast) Inspect for dimensions and workmanship.	Certification-Type C (For contracts let prior to 9/1/2017) Approval Number-W# (For contracts let on or after 9/1/2017)	SM9003 SM9004
83	02 of 02	920	HIGHWAY ILLUMINATION MATERIALS	JOBSITE	LIGHTING STANDARDS AND MAST ARMS, HIGH MAST STANDARDS, WIRE AND CABLE, ANCHOR BOLTS, ETC. Inspect for dimensions and workmanship.	Certification-Type C	SM9003 SM1004 (attach Buy America certification(s) in SM)
84	01 of 03	919 (various subsections)	TRAFFIC SIGNS	JOBSITE	SHEET SIGNS, PANEL SIGNS, FLEXIBLE ROLL-UP PRISMATIC REFLECTIVE SIGNS, LETTERS, NUMERALS, SYMBOLS, AND ACCESSORIES. Inspect for dimensions and workmanship.	Certification-Type C	SM9003
84	02 of 03	919.01b1	TRAFFIC SIGNS	JOBSITE	REFLECTIVE SHEETING.	Approval Number	SM9004
84	03 of 03		TRAFFIC SIGNS (TEMPORARY)	JOBSITE	ALL TYPES EXCEPT NON- GROUND MOUNTED SIGNS.	Visual Inspection	No Sample ID required.
85	01 of 01	801.04	CONSTRUCTION SIGNS	JOBSITE	Visually inspect for dimensions and workmanship.	Visual Inspection	No Sample ID required.
86	01 of 01	923.03	CONSTRUCTION WARNING LIGHTS	JOBSITE	Check brightness.	Visual Inspection.	No Sample ID required.
87	01 of 04	922.02 922.03 922.04(a) 922.12 922.13	TRAFFIC SIGNAL EQUIPMENT	JOBSITE and LAB	TRAFFIC SIGNAL CONTROLLER, INTERCONNECT EQUIPMENT, LED SIGNAL HEAD AND PEDESTRIAN SIGNAL HEAD COMPONENTS, EXTERNAL TIME CLOCKS, VEHICLE DETECTION SYSTEMS.	Approval Number (External Document shall be submitted with approval numbers listed for each component when applicable)	SM1002 SM1004 (attach Buy America certification(s) in SM)
87	02 of 04	922.04(b)	TRAFFIC SIGNAL EQUIPMENT	JOBSITE	PEDESTRIAN PUSH BUTTON (APS and Non- APS)	Certification - Type D	SM9003 SM1004 (attach Buy America certification(s) in SM)
87	03 of 04	801.15(d)1	TRAFFIC SIGNAL EQUIPMENT (TEMPORARY)	SOURCE	FIXED TEMPORARY SIGNAL. For new or used controllers, select from Approved Traffic Signal and ITS Control Equipment.	Approval Number	SM9004
87	04 of 04	801.15(d)2	TRAFFIC SIGNAL EQUIPMENT (TEMPORARY)	SOURCE	PORTABLE TEMPORARY SIGNAL. Selected from Approved Portable Signals	Approval Number	SM9004
89	01 of 02	805.02 922.17(a)	TRAFFIC SIGNAL HANDHOLE AND COVER	SOURCE	CONCRETE. Certified Precast Concrete Producers.	Approval Number-Source Number	SM9004
89	02 of 02	805.02 922.17(b)	TRAFFIC SIGNAL HANDHOLE AND COVER	JOBSITE	POLYMER CONCRETE.	Certification-Type C	SM9003

90	01 of 01	922.08 (References 910.05b)	TRAFFIC SIGNAL EQUIPMENT	JOBSITE	TRAFFIC SIGNAL HANDHOLE RING AND COVER. Inspect for dimensions and workmanship.	Certification-Type C	SM9003
91	01 of 01	926.02a	ACRYLIC PLASTIC DELINEATORS	JOBSITE		Approval Number	SM9004
92	01 of 01	926.02b	REFLECTIVE SHEETING DELINEATOR	JOBSITE	Inspect for dimensions and workmanship.	Certification-Type C	SM9003
93	01 of 01	926.02c	BARRIER DELINEATOR	JOBSITE		Approval Number	SM9004
94	01 of 11	909.05	PAVEMENT MARKINGS (TEMPORARY)	JOBSITE	TRAFFIC PAINT: for temporary markings.	Visual Inspection	No Sample ID Required
94	02 of 11	808.02 909.05 ITM 931	PAVEMENT MARKINGS	JOBSITE or SUPPLIER	TRAFFIC PAINT: for permanent markings.	Certification - Other (Environmental Properties per 808.02) Longitudinal Lines \geq 50,000 Linear Feet (total for all painted marking lines <i>per contract</i>); Template required for exception or retroreflectometer testing.	SM9003 IT931
94	03 of 11	921.02a ITM 931	PAVEMENT MARKINGS	JOBSITE	THERMOPLASTIC.	Certification - Type C Longitudinal Lines \geq 10,000 Linear Feet (total for all thermoplastic type marking lines <i>per contract</i>); Template required for exception or retroreflectometer testing.	SM9003 IT931
94	04 of 11	921.02b ITM 931	PAVEMENT MARKINGS	JOBSITE	PREFORMED PLASTIC.	Certification - Type C Longitudinal Lines \geq 10,000 Linear Feet (total for all preformed plastic type marking lines <i>per contract</i>); Template required for exception or retroreflectometer testing.	SM9003 IT931
94	05 of 11	921.02b	PAVEMENT MARKINGS (TEMPORARY)	JOBSITE	PREFORMED PLASTIC.	Visual Inspection	No Sample ID required.
94	06 of 11	921.02a 921.02b	PAVEMENT MARKINGS (SPECIAL MARKINGS)	JOBSITE	<i>THERMOPLASTIC AND PRE-FORMED PLASTIC</i> PAVEMENT MARKING MATERIALS. Transverse markings, Stop Bars, Pavement Message Markings, Railroad Markings, Bicycle Markings etc.	Certification-Type C	SM9003
94	07 of 11	921.02c ITM 931	PAVEMENT MARKINGS	JOBSITE	MULTI COMPONENT	Certification - Type C Longitudinal Lines \geq 10,000 Linear Feet (total for all multi-component type marking lines <i>per contract</i>); Template required for exception or retroreflectometer testing.	SM9003 IT931

94	08 of 11	923.01	PAVEMENT MARKINGS	JOBSITE and SOURCE	TEMPORARY PAVEMENT MARKING TAPE, TYPE I. (Removable)	Approval Number	SM9004
94	09 of 11	921.02e	PAVEMENT MARKINGS (TEMPORARY)	POINT OF DELIVERY	BEADS.	Visual Inspection	No Sample ID required.
94	10 of 11	921.02e	PAVEMENT MARKINGS	POINT OF DELIVERY	BEADS. Bagged.	Certification for Glass Beads- Type C Certification for Supplemental Elements- Type D	SM9003 SM9003
94	11 of 11	921.02e	PAVEMENT MARKINGS	POINT OF DELIVERY	BEADS. Bulk. One quart from each of three randomly selected bulk containers when sampling is required by QPA.	Certification for Glass Beads- Type C Certification for Supplemental Elements- Type D	SM9003 SM9003
95	01 of 01	921.02d	SNOWPLOWABLE RAISED PAVEMENT MARKERS	JOBSITE	Inspect for dimensions and workmanship.	Approval Number - Prismatic Reflectors and Cast Metal Base Certification for Epoxy Adhesive - Type B	SM9004 SM9003 SM1004 (attach Buy America certification(s) in SM)
96	01 of 01	923.02	TEMPORARY RAISED PAVEMENT MARKERS	JOBSITE	Visually inspect for dimensions and workmanship.	Visual Inspection	No Sample ID required.
97	01 of 02	923.04(b) 923.04(c) 923.08	FLASHING ARROW SIGN	JOBSITE	Visually inspect for dimensions and workmanship.	Visual Inspection	No Sample ID required.
97	02 of 02	923.04(a) 923.05	SOLAR POWERED TRAFFIC CONTROL DEVICES	JOBSITE	Flashing Arrow Sign, Portable Changeable Message Sign	Approval Number	SM9004
98	01 of 01	801.07	STANDARD BARRICADES	JOBSITE	Visually inspect for dimensions and workmanship.	Visual Inspection	No Sample ID required.
99	01 of 01	910.02	STEEL STRUCTURES	JOBSITE or SOURCE	STRUCTURAL STEEL. Inspect for dimensions and workmanship.	External Document-Mill Test Report	SM1002 SM1004 (attach Buy America certification(s) in SM)
100	01 of 02	910.02g	STEEL STRUCTURES	ANY LOCATION	HIGH STRENGTH BOLTS, NUTS, AND WASHERS. Two bolts, two washers and two nuts from each heat number for each size.	Test Results	Sample ID (Templates by M&T) SM1004 (attach Buy America certification(s) in SM)
100	02 of 02	910.02g	STEEL STRUCTURES	ANY LOCATION	HIGH STRENGTH BOLTS, NUTS, AND WASHERS. For diaphragm connections on prestressed concrete beams.	External Documents-Rotational Capacity, Mill Report and Galvanization when applicable (Attach Documents)	SM1002 SM1004 (attach Buy America certification(s) in SM)
101	01 of 01	910.02h	STEEL STRUCTURES	JOBSITE	BOLTS OTHER THAN HIGH STRENGTH. Inspect for dimensions and workmanship.	Certification-Type C	SM9003 SM1004 (attach Buy America certification(s) in SM)

102	01 of 03	910.03	PERMANENT METAL FORMS	JOBSITE or FABRICATOR	PANEL: One series of field tests for each gauge and corrugation pattern/size per shipment.	Sample ID Certification-Type A	A90 SM9033 SM1004 (attach Buy America certification(s) in SM)
102	02 of 03	910.03	PERMANENT METAL FORMS	JOBSITE or FABRICATOR	ACCESSORIES: One series of field tests for each gauge and type per shipment.	Sample ID Certification-Type A	A90 SM9033 SM1004 (attach Buy America certification(s) in SM)
102	03 of 03	910.03	PERMANENT METAL FORMS	JOBSITE or FABRICATOR	CLIPS: One series of field tests for each shipment.	Sample ID Certification-Type A	A90 SM9033 SM1004 (attach Buy America certification(s) in SM)
103	01 of 01	910.04	STEEL FORGINGS AND SHAFTINGS	JOBSITE	Inspect for dimensions and workmanship.	External Document-Mill Test Report	SM1002 SM1004 (attach Buy America certification(s) in SM)
104	01 of 01	910.05a 910.05b	CASTING (STEEL AND IRON)	JOBSITE	Inspect for dimensions and workmanship.	Certification-Other (Certified Inspection Report)	SM9003 SM1004 (attach Buy America certification(s) in SM)
105	01 of 01	910.06a	BRONZE CASTINGS	JOBSITE	Inspect for dimensions and workmanship.	Certification-Type A	SM9003
106	01 of 01		SHEET LEAD AND ZINC	JOBSITE	Sample when directed.	Visual Inspection	No Sample ID required.
107	01 of 01	711.33	STEEL STRUCTURES	JOBSITE	STUD SHEAR CONNECTORS. Inspect for dimensions and workmanship.	External Document-Mill Test Report	SM1002 SM1004 (attach Buy America certification(s) in SM)
108	01 of 03	707.09 714.06(b) 723.11	GROUT	JOBSITE	PRE-PACKAGED. Non-shrink in accordance with ASTM C1107. For precast members and box culverts.	Certification-Type C	SM9003
108	02 of 03	714.06(b) 723.11	GROUT	JOBSITE	CONVENTIONAL FINE. In accordance with ASTM C476. For box culverts.	Air Content, One per Structure	T152
108	03 of 03	714.06(b) 723.11	GROUT	JOBSITE	SELF-CONSOLIDATING FINE. In accordance with ASTM C476. For box culverts.	Air Content, One per Structure Slump Flow, One per Structure Visual Stability Index, One per Structure	T152 (Note in remarks. Tests in accordance with ASTM C476.)
109	01 of 01	901.06	SEALER HEALER (LATEX OVERLAYS)	JOBSITE	FOR SHRINKAGE CRACK REPAIR AS DIRECTED. One 1 qt random verification sample required per year per manufacturer as directed.	Approval Number	SM9004
110	01 of 03	213	FLOWABLE BACKFILL	JOBSITE	MIX DESIGN APPROVAL. One flow consistency, one lightweight dynamic cone penetration test and one dry unit weight test.	N/A	No Sample ID required.
110	02 of 03	213	FLOWABLE BACKFILL	JOBSITE	FIELD APPLICATION Approved mix design required.	Visual (For PLN quantity ≤ 100 cyd).	No Sample ID required.

110	03 of 03	213	FLOWABLE BACKFILL	JOBSITE	FIELD APPLICATION Approved mix design required.	For PLN quantity > 100 cyd: Flow Test 1/100 cyd Lightweight DCP 1/pour location Yield 1/100 cyd if using continuous mixer.	D6103 IT216 SM7009
111	01 of 01	216	CELLULAR CONCRETE FILL	JOBSITE	A lot is 300 cyd placed.	Approval Number Four 3 in. by 6 in. cylinders per lot for compressive strength.	SM9004 C495
112	01 of 01	725.07	CELLULAR CONCRETE GROUT	JOBSITE	Four 3 in. by 6 in. cylinders for compressive strength for each 100 cyd by Contractor.	Certification-Type A	SM9003
113	01 of 01	905.05	DETECTABLE WARNING SURFACES	JOBSITE	Inspect each element.	Approval Number	SM9004
114	01 of 01	411	MICROSURFACING (WARRANTY)	JOBSITE	One DMF required per course.	Approval Number-DMF Number	SM9004
115	01 of 01	414	ULTRATHIN BONDED WEARING COURSE (WARRANTY)	JOBSITE	One DMF required per course.	Approval Number-DMF Number	SM9004
116	01 of 01	907.08 907.09 907.11	CLAY PIPE OR TILE	JOBSITE	Inspect for dimensions and workmanship.	Certification-Type C	SM9003
117	01 of 03	RSP 627-R-546	CABLE BARRIER SYSTEM	JOBSITE	SYSTEM	Approval Number	SM9004 SM1004 (attach Buy America certification(s) in SM)
117	02 of 03	RSP 627-R-546	CABLE BARRIER SYSTEM	JOBSITE	WIRE ROPE. Inspect for dimensions and workmanship.	Certification-Type A including thickness of zinc coating, minimum breaking strength, the modulus of elasticity and the force applied to pre-stretch the wire rope. One certification per each spool.	SM9003 SM1004 (attach Buy America certification(s) in SM)
117	03 of 03	RSP 627-R-546	CABLE BARRIER SYSTEM	JOBSITE	INTERMEDIATE LINE POSTS, THREADED TERMINALS, TURNBUCKLES, ANCHOR FITTINGS AND RETROREFLECTIVE SHEETING. Visually inspect for dimensions and workmanship.	Certification-Type C	SM9003 SM1004 (attach Buy America certification(s) in SM)
118	01 of 01	920.01 922.19	CONDUIT	JOBSITE	CONDUIT FOR LIGHTING. Polyethylene (MDPE or HDPE). CONDUIT FOR SIGNALS.	Certification-Type C	SM9003
119	01 of 01	702.03 906.08	HIGH DENSITY BEARING STRIP	JOBSITE	Multipolymer plastic.	Certification - Type B	SM9003
120	01 of 01	RSP 205-C-231	EROSION CONTROL	JOBSITE	TEMPORARY TURBIDITY CURTAIN. For water quality.	Certification - Type B	SM9003
121	01 of 01	720.04	MANHOLE GRADE RINGS	JOBSITE	GRADE RINGS. Other than precast concrete.	Certification-Type C	SM9003 SM1004 (attach Buy America certification(s) in SM)

122	01 of 01	RSP 738-B-297	POLYMERIC CONCRETE BRIDGE DECK OVERLAY	JOBSITE	AGGREGATE EPOXY POLYMER. EPOXY OVERLAY.	Certification - Type A Approval Number Final Pull-Off Test Results (ITM 407)	SM9003 SM9004 External Document (Attach external document in SM)
123	01 of 03	RSP 620-R-483	SOUND BARRIER SYSTEMS	JOBSITE	ALL TYPES.	Approval Number	SM9004
123	02 of 03	RSP 620-R-483	SOUND BARRIER SYSTEMS	JOBSITE	COMPONENTS. (Joint mortar, Structural Aluminum Posts, Structural Steel Posts.) (Structural Steel)	Certification - Type C Mill Certification	SM9003 External Document SM1004 (attach Buy America certification(s) in SM)
123	03 of 03	RSP 620-R-483	SOUND BARRIER SYSTEMS	JOBSITE	CONCRETE MASONRY UNITS.	Certification -Type A	SM9004
124	01 of 02	RSP 625-R-194	GABIONS AND REVET MATTRESS	JOBSITE	GABIONS.	Certification -Type A	SM9003 SM1004 (attach Buy America certification(s) in SM)
124	02 of 02	RSP 625-R-194	GABIONS AND REVET MATTRESS	JOBSITE	REJET MATTRESS. SOIL ANCHOR STAKES.	Certification -Type A Certification -Type C	SM9003 SM9003
125	01 of 01	807.15	SERVICE POINT	JOBSITE	ALL TYPES. Includes components such as poles, conduit, weatherhead, ground rod/cable, meter box, etc.	Certification -Type C	SM9003
126	01 of 03	907.23 715.02(l)	ROADWAY DRAIN CASTING EXTENSION	JOBSITE	SMOOTH WALL PVC PIPE.	Pipe (Certification-Type C) Mounting Hardware (Certification-Type C)	SM9003 SM9003
126	02 of 03	907.28 715.02(l)	ROADWAY DRAIN CASTING EXTENSION	JOBSITE	REINFORCED THERMOSETTING RESIN PIPE	Pipe (Certification-Type A) Mounting Hardware (Certification-Type C)	SM9003 SM9003
126	03 of 03	908.10 715.02(l)	ROADWAY DRAIN CASTING EXTENSION	JOBSITE	CAST IRON SOIL PIPE. Field check for dimensions and weight.	Pipe (Certification-Type C) Mounting Hardware (Certification-Type C)	SM9003 SM9003 SM1004 (attach Buy America certification(s) in SM)
127	01 of 02	908.10 715.02(n)	BRIDGE DECK DRAIN SYSTEM	JOBSITE	CAST IRON SOIL PIPE. Field check for dimensions and weight.	Pipe (Certification-Type C) Mounting Hardware (Certification-Type C)	SM9003 SM9003 SM1004 (attach Buy America certification(s) in SM)
127	02 of 02	907.28 715.02(n)	BRIDGE DECK DRAIN SYSTEM	JOBSITE	REINFORCED THERMOSETTING RESIN PIPE	Pipe (Certification-Type A) Mounting Hardware (Certification-Type C)	SM9003 SM9003
128	01 of 02	901.07	CONCRETE PATCHING MATERIALS	JOBSITE	RAPID SETTING PATCH MATERIAL	Approval Number (W Number)	SM9004
128	02 of 02	901.08 710.02	CONCRETE PATCHING MATERIALS	MIX DESIGN SUBMITTAL	PACKAGED PATCHING PRODUCTS	Certification-Type B (Submitted to State Concrete Engineer with proposal)	No Sample ID required.

129	01 of 01	Unique Special Provision	PIPE LINERS	JOBSITE	CURED-IN-PLACE-LINER (CIPP). Testing of CIPP in accordance with ASTM D 5813, Section 7.3. Report Flowable Backfill, Non- Removable, and/or Cellular Concrete Grout, as applicable.	Certification-Type A (Referencing ASTM D 5813, Section 7.3)	SM9003
130	01 of 01	708.02	PNEUMATICALLY PLACED MORTAR	JOBSITE	All mixture constituents must come from approved lists.	Portland Cement - Approval Number (W#) Fine Aggregate - Approval Number (CAPP Q and D) Fly Ash (If Used) - Approval Number	SM9004 IT211 SM9004
131	01 of 01	206.08	PREPARATION OF FOUNDATION: SPREAD FOOTING ON ROCK		Drilling three 2 in. diameter holes 5 ft depth into rock	One per abutment	TBD
132	01 of 01	217.09	SOIL DRYING OR SUBGRADE FOUNDATIONS		12 in. per lift	2 DCP tests per 1000 ft One moisture test per 4 hours of lime soil mixing One gradation test per 2500 ft	IT509 IT506 IT516
133	01 of 01	203.26	PROOFROLLING		Complete coverage	One test to cover the complete surface	TBD
134	01 of 01	906.01	FLEXIBLE FOAM EXPANSION JOINT	JOBSITE	Visual Inspection	Certification Type C	SM9003