Grant County Health Department
401 South Adams Street
Marion, 46953
Office - (765)651-2401

Swimming Pool Inspection Report

Owner
N/A
Grant County Family YMCA
123 Sutter Way
Marion, IN 46952

Facility
Grant County Family YMCA
123 Sutter Way
Marion, IN 46952
License Number :

The Grant County Family YMCA Family Pool was inspected on 07/08/2026 by Cassie Leech & Jeff Couch.

The pool is in reasonable compliance with 410 IAC 6-2.1 and 675 IAC 20; however, the following violations were observed and must be corrected by August 7, 2026.

1. A copy of Rule 410 IAC 6-2.1, Public and Semi-Public Swimming Pools, is not kept on site at the facility. This is a violation of 410 IAC 6-2.1-25(d).

2. A test kit was not readily available for use by the pool operator. This is a violation of 410 IAC 6-2.1-30(j).

3. The alkalinity of the water was 50ppm. This is out of the acceptable range of least 80 and no more than 120 part per million (mg/l). This is a violation of 410 IAC 6-2.1-30(n).

4. The pool water was not tested for pH/disinfectant residuals daily (before the pool is open for use and at least 1 other time during the hours of pool use). This is a violation of 410 IAC 6-2.1-30(o) (1).

5. The pool water was not tested for combined chlorine at least twice a week. This is a violation of 410 IAC 6-2.1-30(o) (2).

6. The pool water was not tested for total alkalinity at least once a week. This is a violation of 410 IAC 6-2.1-30(o) (3).

7. The pool water was not tested for cyanuric acid at least once a week. This is a violation of 410 IAC 6-2.1-30(o) (4).

8. A meter to measure the flow of water through the pool water was not working at the time of inspection. This is a violation of 410 IAC 6-2.1-32(c).

9. The depth of the pool water was not plainly and conspicuously marked at or above the water surface/ on the vertical pool wall. This is a violation of 410 IAC 6-2.1-34(f) and 675 IAC 20-2-26(c).

After the compliance date, if the violations remains uncorrected; an enforcement action may be initiated to obtain the correction of these violations.

If you have questions, please contact the Grant County Health Department.

Field Data

Free Disinfectant Level : 2.6 mg/l Total Alkalinity : 50 mg/l

Total Disinfectant Level :	N/A	Total Dissolved Solids :	N/A
pH :	7.4	Temperature :	N/A
Combined Chlorine :	.5 mg/l	Saturation Index :	N/A
Cyanuric Acid Level :	N/A	Maximum Bather Load :	N/A
Calcium Hardness :	N/A		