Grant County Health Department
401 South Adams Street
Marion, 46953
Office - (765)651-2401

Swimming Pool Inspection Report

Owner
N/A
Mayor Bill Rock
211 E Main St
Gas, IN 46933

Facility
Gas City
1001 Evans Rd
Gas, IN 46933
License Number :

The Gas City Spray Pad was re-inspected on 06/16/2026 by Jeff Couch.

The previous critical violations were corrected, and the spray pad is open. The following violations of 410 IAC 6-2.1 and/or 675 IAC 20-5 were observed and listed in order of priority. Violations 1 and 2 must be corrected within the 30-day period stated in last report. All other violations must be corrected as soon as possible, but before the 2027 season.

1. Electronic monitoring equipment was not in place and operating to shut off the spray nozzles in the patron area when the free Cl level was outside of the acceptable range. There was no direct Cl measurement probe installed. It is not reasonable to rely on an ORP correlation to determine free Cl concentrations for the purpose of this required safety shutoff. This is a violation of 410 IAC 6-2.1-26(a) and specifically 675 IAC 20-5-23(c)(1).

2. The UV system has reportedly not worked until recently, but actuators failed to stop water flow to the spray nozzles in the patron area. A safety may have been bypassed by the pool operator. There must be an actuator to stop the flow to the patron area any time the UV system is inoperable or fails to deliver the required UV dose. This is a violation of 410 IAC 6-2.1-26(a) and specifically 675IAC 20-5-23(c)(2).

3. The riser to the balance tank seems to be allowing sand and soil to enter the tank at the joint between the poly riser and the lockable lid. This is a violation of 410 IAC 6-2.1-26(a) and 410 IAC 6-2.1-37.

4. There is no unisex restroom with a sink and flush toilet within 300'; there is only a portable toilet. There is also no rinse off shower. This is a violation of 410 IAC 6-2.1-29(e) and 675 IAC 20-5-25(c).

5. There is no dressing area nor baby changing station within 300'. This is a violation of 410 IAC 6-2.1-26(a) and 675 IAC 20-5-25(a).

6. There is no drinking fountain. This is a violation of 410 IAC 6-2.1-26(a) and 675 IAC 20-5-25(e).

7. A frost-free farm-style hydrant with a below grade drain/weep hole is immediately adjacent to the spray pad and is occasionally used to add water to the system. The below grade weep hole is the problem as this can introduce shallow ground water through venture suction. This is a violation of 410 IAC 6-2.1-27(h) Note that there appears to be a below grade water leak associated with this given the significant ponded water surrounding it.

8. User sanitation and safety rules were not posted within the enclosure with letters at least 1 inch high. This is a violation of 410 IAC 6-2.1-36(b).

9. Signs warning "DANGER–HAZARDOUS CHEMICALS" with 4" letters are not posted on the chemical feed structure and the lids to the subsurface chemical tanks. This is a violation of 410 IAC 6-2.1-36(a) (1).

If you have questions, please contact the Grant County Health Department.

Field Data

Free Disinfectant Level :	6.4 mg/l	Total Alkalinity :	290 mg/l
Total Disinfectant Level :	N/A	Total Dissolved Solids :	N/A
pH :	7.4	Temperature :	N/A
Combined Chlorine :	0 mg/l	Saturation Index :	N/A
Cyanuric Acid Level :	0 mg/l	Maximum Bather Load :	N/A
Calcium Hardness :	N/A		